


LB/DON/106/2011



IMPACT OF INTERNAL AND EXTERNAL FACTORS IN BUILDING ENERGY CONSUMPTION IN SRILANKA

A dissertation submitted to the Department of Electrical Engineering, University of Moratuwa In partial fulfillment of the requirements for the Degree of Master of Science in Electrical Installations



University of Moratuwa, Sri Lanka. Electronic Theses & Dissertations www.lib.mru.ac.lk

HEWAGE RUCHIRA DAMINDA PERERA (06/8424)

Supervised by: Dr. J. P. Karunadasa Senior Lecturer in Electrical Engineering University of Moratuwa

621.3 "10"
696.6(043)

TH

Department of Electrical Engineering University of Moratuwa, Sri-Lanka October 2010

University of Moratuwa



100848

100848




100848

DECLARATION

The work submitted in this dissertation is the result of my own investigation, except where otherwise stated.

It has not already been accepted for any degree, and is also not being concurrently submitted for any other degree.


..Hewage Ruchira daminda perera

Name of Candidate

Date: 2011/08/01



University of Moratuwa, Sri Lanka.

Electronic Theses & Dissertations

We/I endorse the declaration by the candidate.

Name of each Supervisor

1.....  27/7/2011..

2.....

3.....

CONTENTS

Declaration	(i)
Abstract	(vi)
Dedication	(vii)
Acknowledgement	(viii)
List of Figures	(ix-x)
List of Tables	(xi-xiii)
List of Principle symbol	(xiv)
1. Introduction	
1.1 Background survey and previous work	1
1.2 Srilankan climate	2
1.3 Objective and scope	3
1.4 Motivation	3
1.5 Research design	3
1.5.1 Steps of research	3
1.5.1.1 Identification of topic and scope	3
1.5.1.2 Research methodology	4
2. Statement of problem	
2.1 Significance of the research	5
3. Theoretical background	
3.1 Literature review	6
3.1.1 The room cooling load	6
3.1.2 The cooling load calculations	7
3.1.3 Room heat gains	7
3.1.3.1 Conduction through exterior structure	7
3.1.3.2 Conduction through interior structure	11
3.1.3.3 Solar radiation through glass	12
3.1.3.4 External shading effect	14
3.1.3.5 Design conditions	14
3.1.3.6 Lighting	14
3.1.3.7 People	15
3.1.3.8 Equipment and appliances	16
3.1.3.9 Infiltration and ventilation losses	16
3.1.4 The room cooling load	19
3.1.5 Room peak cooling load	19
3.1.6 Building peak cooling load	19
3.1.7 Diversity	19
3.1.8 Cooling load	19
3.1.9 Psychometric chart	20
3.1.10 The RSHR or condition line	22

3.1.11 Determine supply air condition	22
3.1.12 The complete psychometric analysis	23
3.2 Simulation	
3.2.1 Simulation software DEROB-LTH	24
3.2.1.1 Energy transmission	24
3.2.1.2 Solar radiation	25
3.2.1.3 Heating and cooling	25
3.2.1.4 Ventilation	25
3.2.1.5 Simulation method and technique	26
3.2.2 Simulation input data	28
3.2.2.1 Wall	28
3.2.2.2 Door	29
3.2.2.3 Window	30
3.2.2.4 Roof	30
3.2.2.5 Slab	32
3.2.2.6 Floor	33
3.3 Simulation results	
3.3.1 Peak cooling load of walls for different building orientations	33
3.3.2 Peak cooling load of timber(doors) for different building orientations	34
3.3.3 Peak cooling load of windows (Glass) for different building orientations	34
3.3.4 Peak cooling load of roofs for no of hours per day	35
3.3.5 Peak cooling load of floors for no of hours per day	36
3.3.6 Cooling load in watts with respect to no of people	36
3.3.7 Cooling load in watts with respect to area	37
3.4 Mathematical /Graphical derivatives	
3.4.1 Mathematical derivatives for different walls	37
3.4.2 Mathematical derivatives for different timber	42
3.4.3 Graphical derivatives for different glasses	45
3.4.4 Graphical derivatives for different walls	47
3.4.5 Graphical derivatives for different floors	47
3.4.6 Graphical derivatives for peoples	48
3.4.7 Graphical derivatives for different lights	48
3.5 Validation of software	
3.5.1 Case study –residential house	49
3.5.2 Cooling load calculations(Residential) –Theoretical approach	49
3.5.2.1 Residential cooling load	50

3.5.2.2	Cooling load from heat gain through structure	50
3.5.2.3	Calculation for U values as follows	52
3.5.2.4	Cooling load from heat gain through windows	52
3.5.2.5	People and appliances	54
3.5.2.6	Infiltration and ventilation	54
3.5.3	Cooling load calculations(Commercial)–Theoretical approach	56
3.5.4	Cooling load calculations–simulated results	58
3.5.4.1	Volume 1 –kitchen area	58
3.5.4.2	Volume 2 –dinning area	59
3.5.4.3	Volume 3 –living area	60
3.5.4.4	Volume 4 –Bed room 2	61
3.5.4.5	Volume 5 –Bed room 3	61
3.5.4.6	Volume 6 –Bedroom 1	62
3.5.5	Comparison between simulated and calculated	62
4.	Proposed solution	
4.1	Results	63
4.2	Conceiving feature of relevant solution	66
4.3	Result application-Method and techniques	67
5.	Application of proposed method	
5.1	Case study –supermarket commercial building	69
5.1.1	Wall	70
5.1.2	Commercial cooling load calculation with different wall	73
5.1.2.1	One layer brick type only	75
5.1.2.2	Improved wall type	78
5.1.2.3	Cost for different wall	81
5.1.2.4	Prices of different air-conditions	82
5.1.3	Glasses	83
5.1.4	Commercial cooling load calculations with different glass material	84
5.1.4.1	Air-condition capacity calculations	86
5.1.4.2	Plain glass	86
5.1.4.3	Double glass	89
5.1.4.4	Prices for different glasses	92
5.1.5	Door	93
5.1.6	Roof	94
5.1.7	Floors	94
6.	Results	

6.1 Technical analyzing	
6.1.1 Different RSCL with A/C capacities and operational cost	95
6.1.2 Total electricity charges per month for different material with RSCL values	96
6.1.3 Total electricity charges per month for different material with RSCL values	97
6.1.4 Electricity prices with respect to RSCL for different consumers in srilanka	98
7. Conclusions	
7.1 Conclusions, remarks and discussions	100
7.2 Recommendations	101
References	
Appendix A- Electricity tariff	103
Appendix B	106



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Abstract

This research describes work that covered both theoretical and practical aspects of impact of internal and external factors in building energy consumption. It gives a brief introduction of various concepts related to psychometric and cooling load of air-conditioning system which is useful for an energy optimization in building.

Various mathematical and graphical models were developed to assess the impacts and implementation issues.

An economic analysis was also carried out to help prospective users on energy savings ideas.

In addition to the direct financial savings on energy bills, various other indirect benefits to the building and environment such as extended life time of air conditioning unit reduced emission and pollution, fewer burdens on the national utility grid etc.



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Dedication

The basic idea behind this research work is to identify various possibilities, to conserve energy on an air conditioning system. Various energy optimizations were identified through mathematical modeling. Mathematical equations were derived related to the scope of the research and compared common material used in building envelope.

My dedication was focused to building envelope which is transfer media. This passes heat from outdoor to indoor and indoor to outdoor.

Results of this research may contribute to future improvements in energy consumption of buildings in srilanka.



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

Acknowledgement

First of all, my gratitude must go to my principal supervisor, Dr. J. P. Karunadasa who believed in my ideas and empowered me to achieve this goal. His kind support, encouragement, advice and guidance are most greatly appreciated. My sincere thanks also goes to faculty members/my lecturers, Dr. Narendra De Silva and Dr. R. U. Halwathura for their understanding and supportive role in my academic works. Their advice, remarks and encouragement are most greatly acknowledged. The advice of Mr. D. G. R. Fernando is also greatly appreciated.

I also wish to acknowledge the generous support, assistance and encouragement of several friends and staff members of University of Moratuwa. In particular, my special thanks go to Mr. M. G. M. S. Udayashantha for helping in various ways to clarify things and solving some problems. My appreciation also goes to my post graduate collegeous for creating such a harmony, inspiring and supporting environment where I really enjoyed being part of it.

I am grateful to my mother and father for all their support and encouragement. In particular, to my wife Mrs. Kumari Perera who lives in many miles away but never failed to show her moral support encouragement. My family's expectation, sacrifices, understanding and support enabled me to fulfill my dream.



University of Moratuwa, Sri Lanka
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

List of Figures

Figure	Page
3.1 Room heat gain component	6
3.2 Psychometric Chart	21
3.3 Process of air-conditioning system	23
3.4 Inside view of simulated models	26
3.5 Simulated model appearance	27
3.6 View of roof in simulated building	31
3.7 View of floor in simulated building	32
3.8 Peak cooling load for different walls through Square meter area	37
3.9 Linear regression of A and B for walls	38
3.10 Error in peak cooling load in Btu/h per square feet area for walls	39
3.11 peak cooling load for different timber material through square meter area	41
3.12 Linear regression for A and B for timber	42
3.13 Error in peak cooling load in watts per square feet area for timber	43
3.14 Peak cooling load variation for different glasses through square meter area	44
3.15 Glass load factor for different glasses	45
3.16 Peak cooling load variation for different roofs through per square feet area	46
3.17 Peak cooling load variation through different floors per square meter area	46
3.18 Cooling load in watts with respect to number of peoples	47
3.19 Cooling load in watts with respect to floor area in m ²	47
3.20 Simulated residential house	48
4.1 Different improved architectural view	67
5.1 Plan view of supermarket	68

5.2 Sketch of air conditioning process for one brick layer type	74
5.3 Application of psychometric chart for one layer brick type	75
5.4 Sketch of air conditioning process for improved wall type	77
5.5 Application of psychometric chat for improved wall type	78
5.6 Sketch of air conditioning Process for plain glass type	85
5.7 Application of psychometric chart for plain glass type	86
5.8 Sketch of air conditioning process for double glass type	88
5.9 Application of psychometric chart for double glass type	89
6.1 Changes in A/C due to RSCL change	94
6.2 Electricity prices with respect to RSCL for different consumers in Srilanka	97
6.3 Net pay back period for both selected glass and wall	98



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk

List of Tables

Table	Page
1.1 Temperature variations among major cities	2
3.1 Heat components of building	7
3.2 Cooling load temperature difference (CLTD) for calculating load from walls	8
3.3 Cooling load temperature difference (CLTD) for flat roof	9
3.4 Cooling load temperature difference (CLTD) for flat roofs continue	10
3.5 Maximum solar heat gain factor (SHGF)	13
3.6 Recommended indoor air design conditions for human comfort	14
3.7 Rates of heat gain from occupants of conditioned spaces	16
3.8 Input properties of wall	18
3.9 Input properties of doors	29
3.10 Input properties of windows	30
3.11 Input properties of roof with ceiling	31
3.12 Input properties of slab	32
3.13 Input properties of floors	33
3.14 Peak cooling load in watts for different walls with different facing angle	33
3.15 Peak cooling load in watts for different timber with different facing angle	34
3.16 Peak cooling load in watts for different glasses with different facing angle	34
3.17 cooling load in watts for different room	35
3.18 cooling load in watts for different floors	36
3.19 cooling load in watts with respect to no of people	36

3.20 Cooling load in watts with respect to area	37
3.21 A and B values with respect to U	38
3.22 Errors in cooling load in BTU/hft ² through square feet area	39
3.23 Errors in cooling load as mathematical expression	40
3.24 corrected cooling load comparison	40
3.25 A and B Values with respect to U	42
3.26 Error peak cooling load in watts	44
3.27 Error peak cooling load in watts with U values	45
3.28 GLF values for different glass with different facing angle	46
3.29 Outdoor range with difference class	51
3.30 Calculated CLTD values	51
3.31 Calculated values for different materials	52
3.32 Window glass load factor	53
3.33 Air change rates as a function of outdoor design temperature	54
3.34 Residential cooling load calculation form	57
3.35 Peak cooling load from equation and simulation for –Kitchen	58
3.36 Peak cooling load from equation and simulation for –Dinning room	59
3.37 Peak cooling load from equation and simulation for –Living area	59
3.38 Peak cooling load from equation and simulation for Bed room 2	60
3.39 Peak cooling load from equation and simulation for Bed room 3	61
3.40 Peak cooling load from equation and simulation for Bed room 1	61
3.41 Comparison between simulated and calculated cooling loads	62
4.1 Results (Graph)	65

4.2 Conceiving feature of a relevant solution	66
5.1 Peak cooling load in watts through square meter area	71
5.2 Peak cooling load in BTU/h ft ² through square feet area	72
5.3 Some values of peak cooling load in BTU/h ft ² through square feet area	72
5.4 Commercial cooling load calculation for comparative wall	74
5.5 Properties compare for one layer brick wall with improved wall	75
5.6 Cost comparison for construction of walls	81
5.7 Cost comparison of air conditioners for comparative walls	81
5.8 Prices for different air condition capacities	82
5.9 Calculated cooling load through different glasses (W/m ²)	83
5.10 Calculated cooling load through different glasses (Btu/h)	83
5.11 Commercial cooling load calculation with different material of glass	85
5.12 Market prices for different glasses	92
5.13 Cost comparison selected glasses with air conditioners	92
5.14 Prices for different air conditioners	92
6.1 A/C and operational cost for different RSCL values	95
6.2 Total electricity charges per month for different material with RSCL values	96
6.3 Total electricity charges for different consumers	97
6.4 Electricity bill and net investment of improved wall and glasses	99



List of principle symbol

TR= Tone of Refrigeration
Km=kilometers
Sqkm=Square kilometers
° C = Celsius
F = Fahrenheit
A.C =Air-conditioning
HVAC =Heating Ventilating and Air-conditioning
DB= Dry Bulb Temperature
T= Temperature
V= Volume
WB= Wet Bulb Temperature
kw= Kilo watt
CLTD= Cooling Load Temperature Difference
TFM= Transfer Function Method
Y= Year
M=Month
D=Day
H= Hour
DEROB-LTH= Dynamic Energy Response of Building
T=Time
RSCL =Room sensible cooling load
HVAC =Heat, Ventilation and Air conditioning
SHGF=Solar Heat gain Factor
RH =Relative humidity
BTU= British thermal unit
CLF=Cooling Load Factor
ACH= Air changes per hour
RTCL =Room total Cooling load
GLF= Glass factor
OA- Outside Air
EA=Exhaust Air.
RA =Return Air
TOU =Time of use
CLTD_c= Corrected cooling load temperature difference
BF =Ballast factor
W =Watts
CFM= Air infiltration rate to room
Q_L=Latent heat
Q_S = Sensible heat
V= Room volume
RLCL= Room latent cooling load
U= Overall coefficient of heat transmission
Θ =Rotated angle from south