

**POTENTIAL FOR ENERGY CONSERVATION IN
NWSDB WATER SUPPLY SCHEMES**

K. G. N. Saman Kumara

128369U

Degree of Master of Engineering

Department of Mechanical Engineering

University of Moratuwa

Sri Lanka

February 2017

**POTENTIAL FOR ENERGY CONSERVATION IN
NWSDB WATER SUPPLY SCHEMES**

K. G. N. Saman Kumara

128369U

Degree of Master of Engineering

Department of Mechanical Engineering

University of Moratuwa

Sri Lanka

February 2017

Declaration

I declare that this is my own work and this thesis does not incorporate without acknowledgement any material previously submitted for a degree or diploma in any other University or institute of higher learning and to the best of my knowledge and belief, it does not contain any material previously published or written by another person except where the acknowledgement is made in the text.

Also, I hereby grant to University of Moratuwa the non-exclusive right to reproduce and distribute my thesis, in whole or part in print, electronic or other medium. I retain the right to use this content in whole or part in future works (such as articles or books).

Signature:

Date:

K. G. N. Saman Kumara

The above candidate has carried out research for the Master's Thesis under my supervision.

Signature:

Date:

Dr. R. A. C. P. Ranasinghe
Senior Lecturer,
Department of Mechanical Engineering,
University of Moratuwa

Acknowledgement

First my sincere gratitude should equally be delivered to Dr. H. K. G. Punchihewa, Course Coordinator, MEng/PG Diploma in Energy Technology and Dr. R. A. C. P. Ranasinghe, Senior Lecturer, Department of Mechanical Engineering, University of Moratuwa for their continuous motivation exerted towards me with valued advices and kind assistance throughout the research. Their constant supervision behind make my effort worth towards completion the thesis and my professional capacity improved.

My mammoth appreciation is paid hereby to National Water Supply and Drainage Board for providing the opportunity and the financial assistance to attend the master of engineering programme.

I further appreciate the support and the guidance received towards the fulfilment of my carrier with master's degree programme from the lecturing staff in Mechanical Engineering Department of University of Moratuwa.

Special appreciation should go to Mr. S. D. L. Sandanayake and Mr. Priyantha Upul, members of the mechanical department for their valued assistance to the students in every activity for the fulfilment of the Master's degree.

I must extend my sincere appreciation to Eng. P. P. Kahaduwa, Project Director, Ruhunupura Water Supply Project for the immense support exerted towards my effort to fulfill the target and to Eng. J. K. S. Pathiranage, Deputy General Manager, Regional Support Centre, Southern Province of National Water Supply and Drainage Board for supporting me and arranging to collect data and to carry out the research.

Finally, I express my sincere gratitude and appreciation to Eng. Mrs. M. K. J. Prabodhini, Chief Engineer at Regional Support Centre, for her assistance exerted towards my carrier success.

Abstract

This research was aimed to study the potentials for conservation of energy in main schemes of NWSDB in Southern Province. The results are usable on benchmarking energy usage on water supply schemes those operating under NWSDB. From the history of operation of NWSDB over 40 years, energy audits for the recent past were studied for water supply schemes. Specific energy consumption is used to benchmark the energy consumption of each category of operations which leads to identify the potentials for energy conservation. An energy audit was carried out in Southern Province, region-wise Matara, Galle and Hambantota to evaluate the energy conservation potentials.

In electrical energy form, kinetic energy around 25 % of the total consumed is used for pumping raw water. Other 75% is used for major components including water treatments, treated water pumping and distribution networks. Apart from the energy usage on water treatment and pumping, component from total energy as high as 12% was identified as loss on non-revenue water, an area to work on reduction of energy usage.

The main area identified as need for improvements was pumping and transmission equipment and their unit operations where around 14% energy could be targeted for energy saving.

It is worth to improve water sources for free from algae, impurities, pollution and contamination through community awareness, national policy planning and programmed long term vision to meet huge energy conservation in future and to harvesting healthy generation out in danger with numerous diseases.

Direct distribution of water to consuming terminals with continuous pumping is better option to focus to save energy in vigorous amounts instead of distribution through elevated towers yet not ready to be implemented with prevailing electricity pattern in the country.

TABLE OF CONTENTS

| | |
|------------------------------------------------------------------|------|
| Declaration | i |
| Acknowledgement | ii |
| Abstract | iii |
| Table of content | iv |
| List of Figures | viii |
| List of tables | xi |
| List of Abbreviations | xiii |
| List of appendices | xiv |
| 1 INTRODUCTION | 1 |
| 1.1 Background | 1 |
| 1.2 Aim and Objectives | 4 |
| 1.3 Scope of Study | 4 |
| 2 LITERATURE REVIEW | 5 |
| 2.1 Energy Factor | 5 |
| 2.2 Energy on Water | 6 |
| 2.3 Treatment Process | 7 |
| 2.3.1 Water quality | 7 |
| 2.3.2 Dissolved substances | 8 |
| 2.4 Availability of Electricity in Sri Lanka | 13 |
| 2.5 Energy Consumption behavior in Water Supply Schemes | 14 |
| 2.5.1 Overall cost of energy consumption in water supply schemes | 14 |
| 2.5.2 Energy consumption in operations | 15 |
| 2.6 Benchmarking | 20 |
| 2.6.1 Benchmarking history and definitions | 20 |

| | | |
|--------|--------------------------------------------------------------------------------------------|----|
| 2.6.2 | Types of benchmarking | 22 |
| 2.6.3 | Benchmarking process | 22 |
| 2.7 | Energy Benchmarking | 25 |
| 2.8 | Energy Auditing | 29 |
| 2.8.1 | Introduction | 29 |
| 2.8.2 | Types considered for energy audit | 30 |
| 2.8.3 | Process components for energy audit | 31 |
| 2.9 | Energy Consuming Equipment of Water Supply Schemes | 37 |
| 2.10 | Energy Consumption Assessment of Pumps | 37 |
| 2.11 | Assessment of Energy Consumption for Motors | 40 |
| 2.12 | Energy Conservation Methods | 42 |
| 2.12.1 | Schedule adjustments for pump operation | 42 |
| 2.12.2 | Reduce in pipe frictions in pumping lines | 42 |
| 2.12.3 | Throttling of pumping lines | 43 |
| 2.12.4 | Implementation of capacitor banks | 43 |
| 2.12.5 | Adjusting operation schedules to take advantage of tariff structure | 44 |
| 2.12.6 | Introduction of Variable Frequency Drives (VFD) | 44 |
| 2.13 | Energy Conservation Potential by Reducing Water Losses at Treatment Plant and Distribution | 45 |
| 2.13.1 | Reducing water losses in treatment plant | 46 |
| 2.13.2 | Reduction of Non-Revenue Water (NRW) in the distribution network | 47 |
| 3. | METHODOLOGY | 49 |
| 3.1 | Introduction | 49 |
| 3.2 | Selection of Water Supply Schemes for the Study | 50 |
| 3.3 | Primary and secondary data collection through energy audit | 51 |

| | | |
|--------|---------------------------------------------------------------------------------------------------------------------------------|----|
| 3.4 | Secondary Data Collection for Creating Benchmarks | 53 |
| 3.5 | Calculation of Energy Consumption and Efficiencies | 54 |
| 3.6 | Energy Balance of Water Supply Schemes | 54 |
| 3.7 | Benchmarking of Energy Consumption in Unit Processes | 55 |
| 3.8 | Calculation of Energy Conservation Potential of Reducing Non-Revenue Water | 57 |
| 3.9 | Investigate the Energy Conservation Methods | 58 |
| 4 | RESULTS AND DISCUSSION | 59 |
| 4.1 | Electricity Consumption of Schemes and Benchmarking of Power Consumption in Water Treatment Unit Processes | 59 |
| 4.1.1 | Preliminary audit of energy consumption in water supply schemes | 60 |
| 4.1.2 | Boundary and the time frame for total specific energy consumption for drinking water supply schemes using surface water sources | 63 |
| 4.1.3 | Total specific energy consumption for drinking water supply schemes using surface water sources | 63 |
| 4.1.4 | Energy consumption of major components in water supply schemes | 64 |
| 4.1.5 | Energy consumption for raw water and distribution pumping | 65 |
| 4.1.6 | Energy consumption for surface water treatment | 69 |
| 4.1.7 | Benchmarking of energy consumption of water treatment unit processes of surface water sources | 71 |
| 4.1.8 | Benchmarks for energy consumption in water treatment unit processes for surface water sources | 76 |
| 4.1.9 | Potentials of energy conservation through modification of the water treatment process | 76 |
| 4.1.10 | Potentials for energy conservation through improving the energy efficiency of equipment such as pumps and motors | 80 |
| 4.1.11 | Energy conservation potential of reducing NRW | 85 |

| | | |
|--------|---------------------------------------------------------------------------------------------------------------|-----|
| 4.1.12 | Cost Saving from Ceylon Electricity Board Tariff Structure | 90 |
| 4.1.13 | Comparison of identified energy conservation potentials in the audited WSSs | 92 |
| 4.1.14 | Total energy conservation and cost reduction potentials of identified options in audited water supply schemes | 92 |
| 5. | CONCLUSIONS AND RECOMENDATIONS | 98 |
| 5.1 | Conclusion | 98 |
| 5.2 | Recommendations and proposals | 99 |
| | References | 101 |
| 6. | Appendix A | 106 |
| 7. | Appendix B | 115 |
| 8. | Appendix C | 151 |

LIST OF FIGURES

| | | |
|-------------|--------------------------------------------------------------------------------------------------|----|
| Figure 2.1 | Energy usage levels in water treatment | 7 |
| Figure 2.2 | Conventional drinking water treatment processes for surface water sources | 10 |
| Figure 2.3 | Load shape objectives of demand side management | 14 |
| Figure 2.4 | Breakdown of expenses in National Water Supply and Drainage Board in 2012 | 15 |
| Figure 2.5 | Cost break down of Regions in Southern Province in year 2013 | 17 |
| Figure 2.6 | Energy use in Harris water treatment facility in City of Toronto | 17 |
| Figure 2.7 | Graphic representation of power triangle | 40 |
| Figure 2.8 | Effect of reducing pipe friction | 43 |
| Figure 2.9 | The effect of installing a Variable Speed Drive | 44 |
| Figure 2.10 | Non revenue water in major cities in Asia | 48 |
| Figure 3.1 | Overall research plan | 49 |
| Figure 3.2 | Typical energy consumption points in WSS | 55 |
| Figure 3.3 | Typical energy consumption points in a drinking water treatment plant | 56 |
| Figure 4.1 | Major components of energy consumption in a water supply scheme | 59 |
| Figure 4.2 | Total specific energy consumption for water supply schemes using surface water sources | 64 |
| Figure 4.3 | Energy consumption of major components in selected water supply schemes | 65 |
| Figure 4.4 | Specific energy consumption for raw water and distribution pumping in kWh/m ³ | 66 |
| Figure 4.5 | Specific energy consumption for raw water and distribution pumping in kWh/m ³ /m lift | 67 |

| | | |
|-------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------|----|
| Figure 4.6 | Specific energy consumption for raw water and distribution pumping in kWh/m ³ /m lift /km | 68 |
| Figure 4.7 | Specific energy consumption of conventional drinking water treatment for surface water sources | 69 |
| Figure 4.8 | Conventional gas chlorination arrangement | 70 |
| Figure 4.9 | The Omohundro plant alum feed system, showing the feed pumps, pulsation dampeners, flow meters, carrier water system, isolation valves, and pressure relief valves | 70 |
| Figure 4.10 | Specific energy consumption of water treatment unit processes in audited water supply schemes | 73 |
| Figure 4.11 | Existing chlorinator arrangement at Hallala WSS | 77 |
| Figure 4.12 | Modification of chlorinator arrangement at Hallala WSS | 78 |
| Figure 4.13 | Proposed process for filter backwash recovery | 80 |
| Figure 4.14 | Overall efficiency of pump and motor systems in audited water supply schemes | 82 |
| Figure 4.15 | Annual energy saving potential of improving overall efficiency of pumps and motors | 83 |
| Figure 4.16 | Percentage energy saving potential of improving overall efficiency of pump and motor systems | 84 |
| Figure 4.17 | Percentage of average non-revenue water in audited water supply schemes in 2012 | 86 |
| Figure 4.18 | Reduction potential of physical losses in audited Sri Lankan Water Supply Schemes | 87 |
| Figure 4.19 | Reduction potential of commercial losses in audited Sri Lankan Water Supply Schemes | 88 |
| Figure 4.20 | Energy conservation potential for reducing NRW | 89 |
| Figure 4.21 | Percentage energy saving potential of reducing NRW for unit volume of treated water | 89 |
| Figure 4.22 | Annual cost saving from shifting the operation from peak to off Peak | 91 |

| | | |
|-------------|-----------------------------------------------------------------------------------|----|
| Figure 4.23 | Percentage of total energy conversation potential in audited water supply schemes | 94 |
| Figure 4.24 | Annual total energy conversation potential for audited water supply schemes | 95 |
| Figure 4.25 | Annual total cost saving potential for audited water supply schemes | 96 |
| Figure 4.26 | Annual total cost reduction potential for water supply regions | 97 |

LIST OF TABLES

| | | |
|------------|--------------------------------------------------------------------------------------------------------|----|
| Table 2.1 | Energy Consumption Pattern for Different Capacity Water Treatment Plants | 18 |
| Table 2.2 | Total Energy Use and GHG Emissions in Water Sector | 18 |
| Table 2.3 | Range of Specific Energy Consumption for California Water Supply Schemes | 19 |
| Table 2.4 | Specific Energy Consumption in Typical Urban Water Systems in California | 19 |
| Table 2.5 | Organizations Engaged in Benchmarking of Water Supply Utilities | 25 |
| Table 2.6 | Specific Energy Consumption for Drinking Water Supply in Different Cities of Australia and New Zealand | 26 |
| Table 2.7 | Overall Specific Energy Consumption in Water Supply Schemes in Sri Lanka | 26 |
| Table 2.8 | Specific Energy Consumption of Major Components of Drinking Water Supply in Bangkok, Thailand | 27 |
| Table 2.9 | Specific Energy Consumption of Water Supply Processes in Different Regions in USA | 27 |
| Table 2.10 | Specific Energy Consumption in Water Treatment and Supply in Different Cities of the World | 28 |
| Table 2.11 | Specific Energy Consumption of Conventional Water Treatment Process | 28 |
| Table 2.12 | Specific Energy Consumption of Water Treatment Unit Processes | 29 |
| Table 2.13 | Energy Audit Data Required in Water Utilities | 34 |
| Table 2.14 | Energy Conservation Potential of Reducing NRW in Hapugala Water Supply Scheme | 46 |
| Table 3.1 | Comparison of Selected Water Supply Schemes as at 31 December 2015 | 52 |
| Table 3.2 | Primary and Secondary Data Collected During the Preliminary Energy Audit | 53 |

| | | |
|------------|----------------------------------------------------------------------------------------------------------------------------|----|
| Table 3.3 | Primary and Secondary Data Collected During the Detailed Energy Audit | 53 |
| Table 4.1 | Volume Flow Balance and Energy Balance of Selected Water Supply Schemes during Preliminary Energy Audit | 61 |
| Table 4.2 | Comparison of Observed Range of Variation in Specific Energy Consumption of Water Treatment Unit Processes with Literature | 74 |
| Table 4.3 | Benchmarks for Energy Consumption in Drinking Water Treatment Unit Processes for Surface Water Sources | 76 |
| Table 4.4 | Filter Backwash Frequency of Audited Water Supply Schemes | 78 |
| Table 4.5 | Effect on Filter Performance due to Changing of Filter Backwash Frequency | 78 |
| Table 4.6 | Energy Saving Potential of Changing Filter Backwash Frequency | 79 |
| Table 4.7 | Identified Potentials to Improve Overall Pump and Motor Efficiency | 87 |
| Table 4.8 | Possible Technical and Management Solutions to Reduce NRW | 90 |
| Table 4.9 | Tariff Structure of Ceylon Electricity Board | 90 |
| Table 4.10 | Comparison of the Effect of Identified Energy Conservation Potentials in Audited Water Supply Schemes | 93 |

List of Abbreviations

| Abbreviation | Description |
|---------------------|------------------------------------------|
| ADB | Asian Development Bank |
| AWWA | American Water Works Association |
| BPH | Booster Pump Hour |
| CARL | Current Annual Real Losses |
| CEB | Ceylon Electricity Board |
| DAF | Dissolved Air Flootation |
| DMS | Demand Side Management |
| ELL | Economic Level of Leakage |
| EPRI | Electrical Power Research Institute |
| GHG | Green House Gasses |
| GOSL | Government of Sri Lanka |
| ILI | Infrastructure Leakage Index |
| IWA | International Water Association |
| KPI | Key Performance Indicator |
| LECO | Lanka Electricity Company |
| LKR | Sri Lanka Rupee |
| NRW | Non-Revenue Water |
| NWSDB | National Water Supply and Drainage Board |
| PI | Performance Indicator |
| SCADA | Supervisory Control and Data Acquisition |
| SEC | Specific Energy Consumption |
| UARL | Unavoidable Annual Real Losses |
| VFD | Variable Frequency Drive |
| WHO | World Health Organization |
| WOP | Water Operators Partnership |
| WSS | Water Supply Scheme |
| WTP | Water Treatment Plan |

List of Appendices

| Appendix | Description | Page |
|------------|----------------------------------------------------------------------------------------|------|
| Appendix A | Data on Selected Water Supply Schemes and Overall Energy Cost of Drinking Water Supply | 106 |
| Appendix B | Preliminary Audit Data and Benchmarking Calculations | 115 |
| Appendix C | Detailed Audit Data and Calculations for Energy Conservation Potentials | 151 |

1. INTRODUCTION

1.1 Background

By 2035, energy consumption will increase by 50% which will increase the energy sector's water consumption by 85%. Today 15% of global water withdrawals are for energy production. Hydropower supplies about 20% of the world's electricity, a share that has remained stable since the 1990s. Energy requirements for surface water pumping are generally 30% lower than for groundwater pumping. It can be expected that groundwater will become increasingly energy intensive as water tables fall in several regions (WWAP, 2012).

Energy and water are intricately connected. Every living human sense the future with water scarcity. Consumption of water could undoubtedly be considered as the most important human requirement. Humans habitually tend not only to use water, but also consume it in various ways. Water is a basic requirement for all types of functions in every stages of every living creature. Besides the basic requirement it is required for preparation of raw food and their stages of processing, preparation of consumable items, cleaning requirements, fulfilment of transportation needs and various fueling requirements. No longer water is a primitive requirement to human.

Water management is a factor being developed by the human continuously. Water sector has a co-relation with energy sector to explore or extract the quantity wise requirement directly or indirectly and for transmission too. The initial power source and water nexus interlinked basically as the interdependencies comparatively. The whole world is bound to survive only when water is protected. The extraction or the generation of energy has marginal effect when the basic concept of kinetic energy is converted to electricity. Global warming due to human activities will come in to effect in return. However, water processes much higher validity of its own at the interest of generating power or power –water combined activities.

Human consume water for drinking, bathing, washing/cleaning, cooling off, heating, cooking, growing food, swimming, painting and creating art, boating and skiing on, getting rid of wastes, making electricity, transportation of goods, putting out fires,

making products like paper and steel and many more in categories as production, washing, sanitation and in other various forms.

Water availability in sufficient quantities is becoming severe threat to living creatures with population growth, and climate changes which are co-related with development through human desire. Water demand has a direct relationship with energy consumption. Energy is used within the water cycle in every stage. The indicator, intensity of energy consumption (kWh/m^3) is an important measure at each of the water production stage. Energy conservation directly effects the water conservation. It therefore opens human eyes to look for possibilities with modern technology to make drinking water availability with low intensity of energy consumption.

Development of energy is vital when the water factor is concerned in dealing with energy. Strategically much concern is necessary to be paid in inserting the water factor in energy development since the water is a paramount requirement to consider while protection water with its sources is equally important.

Globally availability of natural water is very rare to be used in safe drinking purposes. Water treatment processes are removing contaminants in raw water to make it suitable for human needs. Conventional drinking water treatment process includes solids separation used in water treatment plants as a physical process such as lamella plate settling and filtration, as well as chemical treatment used in water sector such as disinfection and clog coagulation. Chlorination process is used in many water treatment plants for disinfection.

Water pumping stations and treatment facilities are significant energy consumers representing approximately between 2 to 3 percent of the world's energy consumption. Water Supply Schemes (WSSs) are among the largest energy consumers for many electricity providers around the world (EPRI, 1994). Energy consumption in most water systems worldwide could be reduced by at least 25 percent through cost-effective efficiency actions. Energy costs draw precious budgetary resources from other important municipal functions such as education, public transportation, and health care. In the developing world, energy consumed to

supply water may easily consume half of a municipality's total budget. In municipal water systems in developed countries, energy is typically the second largest cost after labour. Unfortunately, relatively little attention has been given to reduce energy use and to improve energy efficiency in municipal water systems (James et al, 2002).

Energy must be carefully handled for future investments as future generation will be ahead with more effective tools to face energy efficiency related activities. Global population already feel the environmental impact on come in return to burning of fossil fuels and drawing out the energy. Air becoming polluted when generating power for supplying drinking water. Emissions from power plants contribute to high levels of pollutants in the urban environment and also in lakes and forests. In addition, millions of tons of carbon dioxide are emitted every year, contributing to global climate change, adversely affecting the quality of life of the people. Global climate change is likely to reduce water tables and affect water supplies in many areas, making water even more costly and energy intensive to obtain in the future (James et al, 2002).

Benchmarking originated as business management practice designed to systematically evaluate product, services and work process of organisations for the purpose of improvement. The evaluation often centres on comparison to similar organisations that operate well or exhibit best practices. The basic steps involved in benchmarking are to properly identify the issue or define the operational metrics, assemble internal data to define current operations, collect external data for comparison, analyse the differences, implement changes and monitor the impact. The project was born out of the need to define useful matrices for comparing energy use among utilities.

For water sector, energy and cost reduction and improvement of energy performance are targeted for benchmarking with key tools of energy consumption in drinking water supply schemes at scheme level and process level. This is achieved through identifying possible energy savings opportunities initially to fix existing energy consumption processes through a technical energy survey. This will figure out unit-

vice energy demands in each process, then will determine the most appropriate operation or units, and determine factors on specific energy usage per quantity of water. The specific energy is assessed and measured in kWh/m³ targeting efficiency improvements of the operation.

National Water Supply and Drainage Board (NWSDB) holds the sole authority as the local organisation for providing safe drinking water and sanitation facilities for local population as the most important social and economic objectives and the responsibility of the Government of Sri Lanka (GOSL). Currently NWSDB provides with pipe borne water supply through water supply schemes in operation throughout with surface water in Sri Lanka and dug wells, hand wells and rainwater harvesting.

1.2 Aim and Objectives

The Aim:

The aim of this research project is to study for potential energy consumption in each unit process of drinking water treatment plants to improve energy performance and to minimise energy costs in water supply

The objectives:

1. To investigate the potentials to minimise energy consumption on water treatment and supply by conducting energy audits in selected water supply schemes in Southern Province
2. To benchmark the energy consumption of water treatment and supply processes

1.3 Scope of Study

1. Conducting energy audits with five selected drinking water schemes in Southern Province to find out the energy consumption of treatment processes and to identify the best practices and potentials for energy conservation
2. Benchmarking the energy consumption of water treatment processes based on the data of the above energy audit

2. LITERATURE REVIEW

2.1 Energy Factor

When physically analysed, energy is the property that must be transferred to an object in order to perform work on or to heat the object, and can be converted in form, but not created or destroyed. The SI unit to measure energy is the Joule, which is “energy transferred to an object by the mechanical work of moving it a distance of 1 metre against a force of 1 newton”.

Common energy forms include the kinetic energy of an object, the potential energy stored by an object's position, the elastic energy stored by stretching solid objects, the chemical energy released when a fuel burns, the radiant energy carried by light, and the thermal energy due to an object's temperature. Kinetic energy of an object is the energy which it possesses due to its motion and quantified by the work needed to accelerate a body of a given mass from rest to its stated velocity. Potential energy is the energy of a body or a system due to the position of the body or the arrangement of the particles of the system and it is the energy difference between the energy of an object in a given position and its energy at a reference position. Many familiar types of energy are a varying mix of both potential and kinetic energy. Energy may be transformed between these forms, with varying conversion efficiencies. Equipment that transforms energy between these forms are called energy transducers. Mechanical energy is transformed to mechanical energy by lever, thermal energy by breaks, electric energy by dynamo, electromagnetic radiation by synchrotron, chemical energy by matches and nuclear energy by particle accelerator.

Electrical energy is the energy newly derived from electric potential energy or kinetic energy. When loosely used to describe energy absorbed or delivered by an electrical circuit "electrical energy" talks about energy which has been converted from electric potential energy. This energy is supplied by the combination of electric current and electric potential that is delivered by the circuit. At the point that this electric potential energy has been converted to another type of energy, it ceases to be electric potential energy. Thus, all electrical energy is potential energy before it is

delivered to the end-use. Once converted from potential energy, electrical energy can always be called another type of energy.

Mechanical energy is identified as the sum of kinetic energy and potential energy. It is the energy linked with the position and motion of an object. The principle of conservation of energy as in mechanical form states that in an isolated system that is only subject to conservative forces the mechanical energy is constant. If an object is moved in the opposite direction of a conservative net force, the potential energy will increase and if the speed of the object is differed, the kinetic energy of the same is differed as well. However, when real system is concerned, Non-Conservative forces, like brake (frictional) forces, is present, but when figures are of smaller values, it can be being constant can be treated as valued approximation. In collisions, the mechanical energy is conserved, some mechanical energy is converted into heat. James Prescott Joule discovered the equivalence between lost mechanical energy and an increase in temperature. In modern devices, like motor or in steam engine, similar mechanism today for conversion of mechanical energy into their different forms of energy.

The unit used for everyday electricity, particularly for utility bills, is the kilowatt-hour (kWh); one kWh is equivalent to 3.6×10^6 J (3600 kJ or 3.6 MJ). Electricity usage is often given in units of kilowatt-hours in a time. This is actually a measurement of average power consumption, i.e., the average rate at which energy is transferred. One kWh/yr is about 0.11 watts.

2.2 Energy on Water

Connection between water and Energy just is complicate to analyse. Electricity is produced using water with potential it acquired. Water and energy are used by human in many ways. Cultivation is the basic and main process that the human start usage water and different types of energy. Cleaning is another primitive process the human gets the use of it. Transportation, food preparation also among the major activities energy and water is equally used.

About 55% to 78% of human body is water, compared to body size. Also body needs one to seven litres of water in a day to avoid the human from dehydration. However, it may depend on other governing factors of atmospheric conditions, weather, humidity, temperature, etc. and also human activities. Direct water consumption and water from fruits or food are major sources are the main water intake of a human being to be comfort. Though different figures are spoken as water intake. Medical background favours a lesser water consumption as better performance to be undergone as a human in spite the activities are holding the major component for a human being to be dependent in the field of for example, athlete who dissipates much energy in the activities,

Transportation and treatment processes require energy in different rates as illustrated in Figure 2.1.



Figure 2.1: Energy usage levels in water treatment

Once raw water is available to be treated is initially collected or pumped depending upon the elevation to water treatment plant from primary source. Sometimes, though it is rare, gravity feeding may be possible where no raw water pumping energy required. In cases where water treatment plant is located far from primary source or at a higher elevated location, much higher rates of energy may be necessary or in some occasions boosting or multi stage elevations are required. Lifting raw water to a higher elevation for treatment sometimes has benefits in return where distribution process is not necessary and gravity distribution could be used for particular zones.

2.3 Treatment Process

2.3.1 Water quality

One of the unique characteristics of water is its capacity to dissolve a variety of substances. As water moves through its cycle, called the hydrological cycle, comprising of rainfall, runoff, infiltration, impounding, use and evaporation, it

comes into contact with many different substances that may be found in non-purified water to some extent or that may be suspended in the water. Very small suspended particles and colloidal substances collectively determine water quality level and its suitability factor to be consumed for domestic purposes.

The types of contaminants or substances of concern that may occur in water sources vary over a wide spectrum and include inorganic salts, micro-organisms, clay particles and organic material. Those with similar characteristics that can be treated by the same type of treatment process are normally grouped together for design purposes and for general discussion. It is normally not possible to consider each individual substance of concern with the view to treatment. There are exceptions, however, for example the removal of a toxic substance from water is often specific for the particular substance.

The principal objective of water treatment is to produce water that is fit for domestic use reliably and consistently from a raw water source at a cost that is reasonable to the consumers. A water treatment plant employs many individual treatment processes (sometimes called unit processes and unit operations) that are linked in a process train to produce water of the desired quality.

The substances of concern in water can be categorised in different ways, e.g. as dissolved or suspended, as inorganic or organic, as macro or micro substances, as natural or synthetic substances, suspensions of micro-organisms etc.

2.3.2 Dissolved substances

Most substances are to a greater or lesser extent dissolved by water. Substances that are dissolved in water are such as ammonia (NH_3), carbon dioxide (CO_2), calcium sulphate (CaSO_4), oxygen (O_2), sodium chloride (NaCl), acids and carbohydrates. Dissolved substances are generally more difficult to remove from water than suspended substances, since they must either be converted into the solid form by means of precipitation, or to the gas form by means of oxidation so that the gas can escape or be stripped from water. A further possibility to remove dissolved

substances is by using advanced processes such as reverse osmosis or activated carbon adsorption.

The conventional drinking water treatment process for surface water sources is shown in Figure 2.2 (Kalaimathie, 2012).




Figure 2.2: Conventional drinking water treatment processes for surface water sources
 Source: Kalaimathie, 2012).

Raw water is contaminated with dissolved particles and non-dissolvable large particles as well. Screening is the primary process at the initial stage to strain such as rubbish, leaves, sticks which may cause the damages to the equipment and system. There are two types of screens; Two strains, coarse screen and fine screens could be employed depending on the requirement. Screens are employed directly across the water lead to block the impurities. Manual or mechanical arrangement may be employed in removing the rubbish collected periodically.

Since the water in raw stage are lesser contacted with air it may contain odour, iron or toxins, the water is run through air. This aeration process removes odour, taste, toxins and any irons which are in soluble form. In general cascade or tank aeration with or without air bubbling is implemented in water treatment industry.

In coagulation, colloidal suspensions are destabilized at the addition of coagulant and then coagulation takes place. In flocculation, polymers are added in to water that is subjected to the treatment and particles are destabilized and form into bigger aggregates being easy to become larger aggregates to remove from water. The formation of flocs which is known as flocculation has no involvement with neutralization of the particles charge. In the general sequence of water treatment, coagulation and flocculation is done as an intermediate process to assist filtration for water as clarification requirement and prior to sedimentation process. and Iron is widely used in water treatment sector as a coagulant. Aluminium salts are also used as a coagulant because of zirconium and titanium salts also found as other metals as highly effective. Particles settle at lower rates or not at all in a colloidal suspension due to the particles acquire electrical charges of the surface that repel each other. A coagulant (in general, one of metallic salt) having the opposite charge is allowed to be mixed to overcome the charge to be repulsive the suspension. The colloidal are negatively charged particles and coagulant is added for example, alum as a to set ions as positively charged. When the repulsive charge has been neutralized, van der Waals forces act and the agglomeration takes place. Other processes like oxidation are also take part in completion of the treatment processes of wastewater or raw water in line with filtration and sedimentation. Coagulant aids as polymers that bridge the colloids together are also often used to the of the process. Polymers are

also use to add to the treatment process colloids gathering method as a clog thereby the efficiency of the process gets increase.

Clarification is the first treatment barrier against particles and protozoan passage during conventional water treatment (Edzwald and Kelley, 1998). This process is accomplished through sedimentation, which allows large floc-particle masses to settle prior to filtration (Olson et al, 2002). Nowadays it is common to use dissolved air flotation or sludge blanket clarifier to accomplish clarification (Binnie et al, 2002). Sedimentation is basically a hydraulic process and plane sedimentation tanks and plate/tube settler sedimentation tanks are the commonly used options. Dissolved air floatation consumes energy for creating air bubbles and sludge blanket clarifiers utilize energy for providing slow mixing.

Physical removal of turbidity and microorganisms from water is ultimately accomplished by filtration. Filters within a conventional water treatment process are considered as the last barrier to the release of particles and protozoan cysts into the distribution system (Cornwell et al, 2003). During filtration, water passes through a pore structure made up of a variety of bed materials that can be composed of the following: (i) a bed of sand (sand filtration) or (ii) a layer of diatomaceous earth (diatomaceous earth filtration), or (iii) a combination of coarse anthracite coal overlying finer sand (dual- and tri-media filtration) (Trojan and Hansen, 1989). The removal of particles in suspension occurs by straining through the pores in the filter bed, by adsorption of the particles to the filter grains, by sedimentation of particles while in the media pores, by coagulation while traveling through the pores, and by biological mechanisms such as slow sand filtration (Trojan and Hansen, 1989). The latter is accomplished by the filtering action of the *schmutzdecke*. The *schmutzdecke* is the top layer (a few centimetres in depth) of sand and particulate materials (fine soil particles, plant debris, algae, free-living or non-pathogenic protozoa) that have been removed from the water as it percolates downward through the sand filter bed (Fox, 2006). Filter backwashing of rapid sand filters is an energy consuming process.

Disinfection is the process by which an organism's viability/infectivity is destroyed with a specific percentage of the population dying over some time frame defined as

a rate. Water disinfection is accomplished with chemical or physical disinfectants and the most common of these is chlorine (added to water as a gas or solid) and the specific disinfection referred to as chlorination (Betancourt and Rose, 2004). Alternative disinfectants including ozone and ultra violet (UV) irradiation are also widely used now (Peeters et al, 1989). Motive water pumps are the main energy consuming equipment of gas chlorinators.

2.4 Availability of Electricity in Sri Lanka

Power requirement in Sri Lanka is fulfilled by mainly from hydro power. In addition to that and when scarcity of water in catchments are experienced, other thermal sources as coal power plants or diesel generators are run. Wind power in Sri Lanka in initial stage and so as to photovoltaics. However nuclear or geothermal power are not in the power scope in Sri Lanka yet.

There are two on-grid electricity providers in Sri Lanka; Ceylon Electricity Board (CEB) and Lanka Electricity Company (LECO). The CEB is the main electricity company in Sri Lanka and it controls all major functions of electricity generation, transmission, distribution and retailing in Sri Lanka. The CEB use both hydropower and thermal power as main energy sources. The LECO is engaged mainly in distribution and retailing in certain areas of the country (CEB, 2013).

CEB provides electricity to all five audited WSSs.

Hydroelectricity is the oldest and historically the principal source of electricity generation in Sri Lanka, holding a share of 48% of the total available grid capacity in December 2013 and 58% of power generated in 2013. Hydroelectric power generation has been constantly under development since the introduction of the national grid itself, but its market share is declining because suitable new sites are scarce. Currently, ten large hydroelectric power stations are in operation, with the single largest hydroelectric source being the Victoria Dam. Although a large portion of the country's hydroelectric resource are tapped, the government continues to issue small hydro development permits to the private sector, for projects up to a total

installed capacity of 10 MW per project. The peak demand is approximately 2050 MW (CEB, 2013).




Figure 2.3: Load shape objectives of demand side management
Source: CEB, 2013

The CEB promotes demand side management (DSM) among its consumers. DSM encompasses “systematic utility and government activities designed to change the amount and/or timing of the customer’s use of electricity” for the collective benefit of the society, the utility and its customers. As such, it is an umbrella term that includes several different load shape objectives, including load management and energy efficiency. DSM options generally primarily address one of the following specific load shape objectives; peak clipping, conservation, load building, valley filling, flexible load shapes and load shifting. (CEB, 2013). These options are graphically illustrated in Figure 2.3. This study investigates on the conservation, peak clipping and load shifting opportunities available at the audited WSSs.

2.5 Energy Consumption behaviour in Water Supply Schemes

2.5.1 Overall cost of energy consumption in water supply schemes

Energy cost is a major component for NWSDB as shown in Figure 2.4. The relevant cost data are attached in Table A.2 of Appendix A. The overall cost of energy consumption in NWSDB in 2012 was 23.7% and it is the second largest cost component of the total annual cost. The largest cost component is the personnel cost which is very difficult to reduce without engaging transformational changes in the

utility organization. Therefore, the largest controllable cost component in NWSDB is the cost of energy.

The breakdown of cumulative expenses of 2012 in the water supply regions of which the selected WSSs are located is attached in Table A.3 of Appendix A and shown in Figure 2.5. Percentage cost of energy consumption of Malimbada, Hapugala and Tangalle schemes in 2012 are 36.6%, 19.3% and 25% of the total cost of the relevant water supply schemes. Therefore, any attempt to reduce the operation cost in NWSDB as an organization or as regions, should concentrate more on conservation of energy consumption.




Figure 2.4: Breakdown of expenses in National Water Supply and Drainage Board in 2012
Source: Kalaimathie, 2012

2.5.2 Energy consumption in operations

Inefficient pumping system causes the technical and commercial losses resulting in higher cost of delivery of water and as well as poor realization of water charges contributing to bad financial performances of water utilities. Approximately 2 to 3% percent of the total electricity generated by the electric power industry is consumed by water industries for pumping and treatment activities for urban residents and industries globally (EPRI, 1994). Energy consumption in the operation and

maintenance phase of the urban water network is directly related to both the quantity and the desired quality of the supplied water and in other words, to maintain the level of service to the consumers. Energy efficiency improvements at water and wastewater treatment facilities can have high rates of return, and can significantly reduce costs at a water facility since energy costs typically constitute 25 to 30% of the operations and maintenance costs at water facilities (Kalaimathie, 2012). Energy consumption for water conveyance to lift water from river and groundwater sources is 26% and 30% is consumed for the treatment and then 43% is consumed for pumping it to service reservoirs (Bunn and Reynolds, 2009).

The energy intensity of treatment required for different types of water source is found to vary widely between the extremes of relatively fresh surface waters, which use energy mainly in pumping, and seawater which requires desalination. Generally, the water industries use either surface or ground water as its water source for drinking water production processes. In a typical water facility treating groundwater only, 1% of electricity is used for chlorination and the balance 99% is used for pumping activities. The onsite energy use of the groundwater supply system is approximately 27% greater than the surface water supply system due to more extensive pumping requirements. On the other hand, the groundwater system uses approximately 31% less indirect energy than the surface water system, mainly because of fewer chemicals used for treatment (Mo et al., 2011).

The average energy consumption in Wisconsin surface water system was 1500 kWh per million gallons of water (0.33 Wh/m^3). Out of this, 73% of energy was consumed for pumping water and 19% of energy was consumed for filter backwashing. Application of advanced water treatment systems lead to increase the electricity consumption in water industries. After introduction of ozonation the estimated energy consumption increased by 0.12 kWh/m^3 and for micro filtration it was increased by 0.16 kWh/m^3 (Elliott et al, 2003). In addition, energy consumption pattern varies with the treatment capacity of the WSSs. The percentage contribution of the electricity consumption in different components of Harris water treatment plant in Toronto city is illustrated in Figure 2.6 (Racoviceanu et al, (2007). It shows that a significant percentage (73%) of energy was consumed for raw water

and treated water pumping and filtration consumed the largest portion (22%) of the energy consumed for water treatment process.




Figure 2.5: Cost break down of Regions in Southern Province in year 2013,
Source: NWSDB, 2013




Figure 2.6: Energy use in Harris water treatment facility in City of Toronto
Source: Rcoviceanu et al. 2007

The specific energy consumption for a smaller plant is higher than the specific energy consumption for a larger plant (Elliott et al, 2003). The energy consumption per unit production for different plant capacities are presented in Table 2.1.

Table 2.1: Energy Consumption Pattern for Different Capacity Water Treatment Plants

| Number of consumers | Energy consumption /(kWh/m^3) | Energy consumption /(kWh/m^3) |
|---------------------|-------------------------------------------------|-------------------------------------------------|
| | Mean Value | Range |
| < 1000 | 0.42 | 0.30 - 0.62 |
| 1000 - 4000 | 0.40 | 0.30 - 0.52 |
| > 4000 | 0.34 | 0.26 - 0.45 |

Source: Elliott et al, 2003

The water, energy and greenhouse gas emissions are interlinked and estimated 8% of greenhouse gas emissions in cities are accounted for water related energy consumption. Rising concerns over scarce energy resources and global climate change has forced the water industry to reduce its energy consumption. Life cycle inventories focusing on energy use and greenhouse gas (GHG) emissions were developed for many WSSs. Toronto municipal WSS burdens, 60% of energy attributed to on-site pumping, accounted for 94% of total energy use and 90% of GHG emissions. The normalized energy use of the system was found to be in between 2.3 and 2.5 MJ/m³ (Racoviceanu et al., 2007). The energy consumption and related GHG emission in different process in a water treatment plant is stipulated Table 2.2.

Table 2.2: Total Energy Use and GHG Emissions in Water Sector

| Process | Total energy use (TJ/year) | GHG emissions (t CO ₂ eq/year) | Specific energy use (MJ/m ³ .year) | Specific GHG emissions (t CO ₂ eq/m ³ .year) |
|------------------------------------|----------------------------|-------------------------------------------|-----------------------------------------------|--------------------------------------------------------------------|
| Chemical Manufacturing | 71 | 4622 | 0.14 | 8.87 |
| Chemical Transportation | 16 | 1018 | 0.03 | 1.95 |
| Operation of water treatment plant | 1271 | 61156 | 2.44 | 117.31 |

| | | | | |
|-------|------|-------|------|--------|
| Total | 1359 | 66796 | 2.62 | 128.13 |
|-------|------|-------|------|--------|

Source: Racoviceanu et al, 2007

United States water systems and waste water systems consume 75 billion kWh/yr nationally and it is about 3% of annual USA electricity consumption. However as per a case study done in San Diego, the energy consumption for water treatment is quite small. The range of variation of specific energy consumption of each component of the water supply schemes in California are presented in Table 2.3 (Cohen et al, 2004).

Table 2.3: Range of Specific Energy Consumption for California Water Supply Schemes

| Water supply component | Range of Specific Energy Consumption/ (kWh/MG) | |
|------------------------|------------------------------------------------|--------|
| | Low | High |
| Raw water pumping | 0 | 14,000 |
| Water treatment | 100 | 16,000 |
| Treated water pumping | 700 | 1,200 |

Source: Cohen et al, 2004

Energy in water supply and conveyance was near zero cause of gravity-fed systems in Northern California. On the other hand, Central and Southern California has higher energy consumption especially in South because it is needed to transport water more than 3,000 feet up over mountains, which is the highest lift of any water system in the world (Cohen et al, 2004). A comparison of specific energy consumption for above components for Northern and Southern California is presented in Table 2.4.

Table 2.4: Specific Energy Consumption in Typical Urban Water Systems in California

| Water-Use Cycle Segments | Energy Use/ (kWh/MG) | |
|--------------------------|----------------------|----------|
| | Northern | Southern |
| Raw water pumping | 150 | 8,900 |
| Water treatment | 100 | 100 |

| | | |
|-----------------------|------|--------|
| Treated water pumping | 1200 | 1,200 |
| Total | 3950 | 12,700 |

Source: Cohen et al, 2004

For California urban water systems; raw water pumping in Northern California consumes energy of 150 kWh/MG while 8,900 kWh/MG was consumed for Southern. This is more than 50 times of Northern California's and also 5 times the national average. The difference is due to the location of water resources, the distance and level of raw water transportation. The amount of energy used to deliver drinking water to residential customers in Southern California is equivalent to approximately one-third of the total average household electric use in the region (Cohen et al, 2004).

2.6 Benchmarking

2.6.1 Benchmarking history and definitions

Xerox Corporation introduced benchmarking in 1980s (Stapenhurst, 2009) as its productivity and market enhancement tool. Over the past few decades benchmarking has evolved into a very robust and popular technique to improve quality, productivity and management improvement. Benchmarking was first used in water utilities by Water Service Regulatory Authority of UK (OFWAT)) in 1989. Benchmarking has been extensively used in many production and service sector to improve performance and extensively used in water and wastewater utilities worldwide. In Southeast Asia benchmarking was first initiated in 2004 by Southeast Asia Water Utilities Network (SEAWUN).

Benchmarking has resulted in more than 100 publications not only in Europe, but also worldwide and it demonstrates the interest of such a tool within the research community (Jeppsson, et al, 2006). In the last few years benchmarking has no longer made headlines, but that is quite possibly because it has now become an established part of business life (Stapenhurst, 2009). Benchmarking has been used in many industry and service sector due to its flexibility of use and as a tool to share and

learn from the best in industry. It also helps to increase the scope of every participating organisation. For learners it means new knowledge and for instructors it means new business opportunity.

Benchmarking is a tool of performance evaluation through comparison within and/or outside the organisation. For some industry it just involves comparison of performance metrics, whereas for some industry the process of achieving performance is more important. Benchmarking can be applied to any area where we want to compare performance and/or learn from others (Stapenhurst, 2009). Roger Milliken, CEO Milliken states that benchmarking definitely is not stealing, but it involves adapting to good ideas, practices and technology with due permission from other benchmarking partners.

Water utilities started adapting benchmarking from early 1990's and since then it has been extensively used worldwide with varying degrees of success. Two major consortium of benchmarking of water utilities has taken place, the European benchmarking initiative and the American initiative. But in most cases the performance indicators and method of assessment are similar for both. Benchmarking of water utilities has evolved, matured as industry standard. Water utilities need to improve performance and performance improvement is no more considered to be more sales or high profit. Especially in water and wastewater utilities it is also about ecology and equity.

Benchmarking is defined as the continuous process of measuring products, services and practices against the toughest competitors or those companies recognised as industry leaders (Camp, 1989). Benchmarking is also defined as a process of gathering standards for improvement and insights, which may lead the organization to better performance (Venetucci, 1992). Benchmarking is also described as an external focus on internal activities in order to obtain continuous improvement (McNair and Leibfried, 1992).

Benchmarking was defined by the American Water Works Association as a systematic process of searching for best practices, innovative ideas, and highly effective operating procedures that lead to superior performance.

2.6.2 Types of benchmarking

There are different approaches to benchmarking depending on the objective and the availability of data. The common feature of all these approaches is that certain parameters relevant for the observed processes are quantified, and then compared with the best practice. The data are usually compiled by surveying, and are then statistically processed and compared.

Benchmarking can be differentiated as internal, external and functional (Karlof and Ostblom, 1993). When comparisons are made within the organisation (between different branch offices), it is termed as internal benchmarking. Internal benchmarking helps to find the better performing units and factors that influence the performance. External Benchmarking is done with competitors or similar units outside the domain of the organisation. Functional benchmarking is when the process and the function is benchmarked in different industry (it might not be doing the same function) and it is a process to find the best wherever possible.

Metric benchmarking is a quantitative comparative assessment of company performance and process benchmarking is a mechanism of identifying specific work procedures to be improved (Parena and Smeets, 2001). In Metric Benchmarking Performance Indicators (PI) are set to assess the comparison between different utilities; reference points like cost per unit, people per unit production are used.

Process benchmarking on other hand relates to specific business processes with better performing organisation or industry standards. Process benchmarking not only observes the cost comparisons, financial ratios or statistical analysis but also allows organisations to understand the operational perspective like level of automation, training needs, management operations etc. Process Benchmarking is the task of improving the way processes performed every day (Bogan and Michael, 1994).

2.6.3 Benchmarking process

Generally benchmarking exercises are done as standalone projects within a time frame but the integration of lessons learned is a continuous process. Running the

water utility in the changing scenario of legal requirements, environmental guidelines, customer satisfaction, technology in use, and management principles need constant performance improvement to provide better service and return on investments. Steps undertaken for benchmarking involve stakeholder objective setting (planning), training of key individuals, data collection, data analysis, report drafting, setting improvement strategy and individual actions followed by monitoring and planning for next stage.

Planning the benchmarking exercise is the critical step and its design influences the success of the initiative; planning process can be externally or internally driven and it is important to consider the benefits and area of interest of individual utility. A paramount sector of planning sequence is to frame the guidelines of the exercise. The guidelines need to identify the responsible people for the work and their specific roles. It also mentions the steering committee which is responsible to provide the required infrastructural support to the exercise.

Once the planning process is set, the second important steps are capacity building and development of tools for the benchmarking exercise. At this stage it is critical to determine the tools that will be used this will depend on the objectives set earlier and the type of data available. The orientations and trainings are not only introduction of key staff and participants but also setting of questionnaires, software orientation, and communication protocols.

The third step of a benchmarking exercise is data compilation and validation. This step can be differentiated into 3 steps determining comparable data, data acquisition and data validation. Comparable data is very critical as it leads to the risk of comparing apples with oranges. It is necessary to have clear questionnaires with precise definitions in data element system along with records of data origin.

In a benchmarking study, the information and data collected is to be valued and compared. To be able to measure the quality of the data and to understand the value of the information given, a performance indicator (PI) system is used.

KPI which is identified as key performance indicator is a nonsense as a measurement of performance. When an industrial organisation is considered, KPI in general, evaluate the success of it or an activity of it. Success is defined Sometimes in terms of making progress towards targeted aims, but sometimes success is simply meet as perfect achievements as 100% or 0 rejects etc. Selection of KPI is intensively 'what is important' to the organisation. It depends on measure of the performance of the department. KPIs for finance and KPIs assigned for sales are different from each other. First it is important to identify what is important, because it is a requirement to develop a sound understanding to identify the real importance of the selection of the performance indicator. It is basically associated with techniques to assess the current state of the industrial goals, and their major activities.

Data analysis and reporting is the first outcome of the benchmarking exercise, and it involves various forms of analysis depending on the objectives and the data availability. Clustering of utilities based on likely comparators is done to match benchmarking indicators, normalisation of Figures is also done wherein certain factor is cost-effective than other, like power is cheap in one country and costly is another. Different reports are generated which serve the purpose of different people; managers tend to have synopsis report which help them to take actions based on facts.

Performance improvement stage is the most challenging stage and requires efforts from every participant, it needs open introspection of performance gaps and sharing knowledge for improvement actions. Improvement actions can range from optimisation to new technology or change in management style.

Benchmarking is defined as a continuous process and without a review of the improvement actions the process becomes stand alone. Review of benchmarking exercise is needed to identify if the performance gaps and possible performance improvement strategy are rightly identified and to assess if the benchmarking has helped to address the identified performance gaps.

There are many government and non-government organisations involved in benchmarking of water utilities in world in different zones and details of these organisations are summarised in Table 2.5.

Table 2.5: Organizations Engaged in Benchmarking of Water Supply Utilities

| Organization | Country/Region |
|--------------------------------------------------------------|-----------------------|
| Water Services Regulation Authority (OFWAT) | United Kingdom |
| 6-Cities Group | Scandinavia |
| International Benchmarking Network (IBNET) | Worldwide |
| Southeast Asia Network of Water Utilities (SEAWUN) | Southeast Asia |
| National Water and Wastewater Benchmarking Initiative (NEBC) | Canada |
| European Benchmarking Cooperation (EBC) | Europe |
| World Bank (WB) | South Asia |
| Asian Development Bank (ADB) | South Asia |
| Water Operators Partnership (WOP) | Africa |

2.7 Energy Benchmarking

The benchmarking of water and wastewater treatment plant at site level or process level, is a key tool to improve performance and to reduce costs in particularly to reduce energy costs. The first step in identifying opportunities for energy savings is to establish current energy consumption patterns through a comprehensive energy audit. An audit will establish the energy demands of each part of the water treatment process, determine the most energy intensive equipment and processes, and provide information on energy use per throughput of water. This baseline assessment will also provide information to evaluate the benefits of any equipment or process changes to improve efficiency of the operation. The usual energy performance indicator is the electrical energy consumed in kilowatt hours divided by flow (kWh/flow). This indicator is used as a benchmark for water companies to measure their performance. The internationally recognized average energy consumption for water supplied under normal conditions are equal to 0.4 – 0.5 kWh/m³ with a total system

pumping head of 100 meters (Jantzen, 2002). Specific energy consumption for drinking water supply in different cities of Australia and New Zealand is presented in Table 2.6.

Table 2.6: Specific Energy Consumption for Drinking Water Supply in Different Cities of Australia and New Zealand

| City | Sydney | Melbourne | Brisbane | Gold Coast | Adelaide | Auckland |
|---------------------------------------------------|--------|-----------|----------|------------|----------|----------|
| Population Served (millions) | 4.300 | 3.621 | 1.006 | 0.449 | 1.095 | 1.232 |
| Specific energy consumption (kWh/m ³) | 1.0238 | 0.0928 | 0.2072 | 0.9806 | 1.9116 | 0.2061 |

Source: modified from Kenway et al, 2008

Sydney required very much water for the steadily increasing population. The specific energy consumption of water supply in Sydney in 2006/2007 has increased by 300% since 2000. The highest energy consumer, Adelaide needs to maintain extra water storage during drought conditions. Gold Coast energy demand has been gradually increasing while the water supplied has varied in response to reduced rainfall and subsequent low storage levels (Kenway, et al, 2008).

Energy consumption of a significant proportion of water treatment plants in Sri Lanka has been studied and the overall energy benchmarks have been produced as per different categories of water sources. These values are presented in Table 2.7. (Kalaimathie, 2012).

Table 2.7: Overall Specific Energy Consumption in Water Supply Schemes in Sri Lanka

| Water Source | Specific Energy Consumption (kWh/m ³) | | |
|--------------|---------------------------------------------------|---------|---------|
| | Average | Minimum | Maximum |
| Surface | 0.44 | 0.07 | 0.76 |
| Ground | 0.51 | 0.37 | 0.82 |

Source: Kalaimathie, 2012

Table 2.8: Specific Energy Consumption of Major Components of Drinking Water Supply in Bangkok, Thailand

| Water supply component | Range of Specific Energy Consumption/ (kWh/m ³) | |
|------------------------|----------------------------------------------------------------|---------------|
| | MWA, 2011 | Anusart, 2012 |
| Raw water pumping | 0.006 | 0.0097 |
| Water treatment | 0.1378 | 0.0469 |
| Treated water pumping | 0.075 | 0.1772 |
| Total | 0.152 | 0.2338 |

Source: Anusart, 2012

Rothausen and Conway reviewed the energy consumption of different components of water supply schemes from the studies of energy use and GHG emissions in the water sector. They summarized their findings into a table which present the region, audit method, water sector processes, Energy consumption and measured unit. Table 2.9 was adapted to present only the energy use (Rothausen and Conway, 2011).

Table 2.9: Specific Energy Consumption of Water Supply Processes in Different Regions in USA

| Author | Region | Water-Sector Processes | Energy Consumption | Unit |
|---------------------|------------|-------------------------|--------------------|--------------------|
| Cohen et al., | San Diego | Supply and treatment | 80-4,200 | kWh/acre foot |
| Klein et al., | California | Raw water pumping | 0-14,000 | kWh/MG |
| | | Water treatment | 100-16,000 | kWh/MG |
| | | Water distribution | 700-1,200 | kWh/MG |
| Goldstein and Smith | California | Surface-water treatment | 0.371-0.392 | kWh/m ³ |

Source: modified from Rothausen and Conway, 2011

The results of various energy benchmark studies regarding water industry in different cities in the world are presented in Table 2.10. Very high amount of energy consumption is observed for sea water desalination compared to conventional water treatment.

Table 2.10: Specific Energy Consumption in Water Treatment and Supply in Different Cities of the World

| City | Treatment option | Benchmark (kWh/m ³) | References |
|------------|-------------------------------------------------------------|---------------------------------|-------------------------------|
| Oslo | Conventional | 0.40 | Venkatesh and Brattebo,(2011) |
| California | Imported water | 5.00 | Strokes and Horvarth,(2009) |
| | Desalination of ocean water with conventional pre treatment | 11.67 | |
| | Desalination of ocean water with membrane pre treatment | 11.39 | |
| | Desalination of brackish ground water | 7.50 | |
| | Recycled water | 4.72 | |
| Wisconsin | Conventional | 0.33 | Elliott et al.,(2003) |
| Toronto | Conventional | 0.59 – 0.64 | Racoviceanu et al., (2007) |

Source: Kalaimathie, 2012

The specific energy consumption of conventional water treatment varies significantly for different countries and Table 2.11 presents the data for several countries around the world (Plappally and Lienhard, 2012).

Table 2.11: Specific Energy Consumption of Conventional Water Treatment Process

| Country | Specific Energy Consumption ranges (kWh/ m ³) | Reference |
|-------------|-----------------------------------------------------------|-------------------------------|
| Australia | 0.01 – 0.2 | Cammerman,2009 |
| Taiwan | 0.16 – 0.25 | Chang, 2002 |
| USA | 0.184 – 0.47 | World Energy Foundation, 2010 |
| Canada | 0.38 – 1.44 | Mass,2010 |
| Spain | 0.11 – 1.5 | Munoz et al.,2010 |
| New Zealand | 0.15 – 0.44 | Kneppers et al.,2009 |

Source: Plappally and Lienhard, 2012

The specific energy consumption for water treatment unit processes was reviewed by Plappally and Lienhard (2012) for USA and values are presented in Table 2.12.

Table 2.12: Specific Energy Consumption of Water Treatment Unit Processes

| Unit Process | Specific Energy Consumption ranges (kWh/ m ³) | Reference |
|-----------------------|-----------------------------------------------------------|------------------------------------|
| Raw water pumping | 0.02 - 0.05 | Goldstein and Smith, 2002 |
| Chemical Feeding | 0.0005 - 0.001 | World Environment Foundation, 2009 |
| Rapid mixing | 0.008 - 0.022 | World Environment Foundation, 2009 |
| Flocculation | 0.001 – 0.004 | Cammerman,2009 |
| Sedimentation | 0.0005 - 0.001 | World Environment Foundation, 2009 |
| Filtration | 0.005 – 0.014 | World Environment Foundation, 2009 |
| Chlorination | 0.0024 – 0.0025 | Arpke and Hutzler, 2006 |
| Treated water pumping | 0.0024 – 0.0025 | World Environment Foundation, 2009 |

Source: Plappally and Lienhard, 2012

2.8 Energy Auditing

2.8.1 Introduction

Water utilities are intensive energy users and continually seek ways to improve their productivity through the effective and judicious use of energy. An effective manner of reducing energy consumption is to conduct an energy audit. An energy audit involves a critical examination of an energy consuming facility. It determines the performance of a facility in terms of energy use and relates its energy consumption to production and compares it with the performance of similar organizations. An energy audit is an imperative first step for any organization interested in implementing an energy management program within their facilities. It assists with identifying areas where potential savings can be made (EPRI, 1994).

The results of an energy audit can improve the energy efficiency of a facility. Increasing the energy efficiency will enhance the facility's operations and products in numerous ways:

- It can reduce energy costs. Depending on the process, energy costs amount to 15% to 40% of the production cost.
- It can help the company improve the quality of its product.
- It can lead to corollary benefits such as reduced maintenance costs and improved worker safety. Many energy efficient technologies are more reliable than their inefficient counterparts.
- It can help reduce pollution. With reduced pollution, payment of any existing environmental fees and fines can be minimized (Alliance to Save Energy, 2002).

2.8.2 Types considered for energy audit

The types considered for energy audit are basically dependant of on resources available to observe, physical parameters to be observed, working environment and final outcome from preliminary audits. Thereafter detailed audits are conducted.

An audit has basically two parts, namely recording and analysing. Since the audit is aimed on energy, energy usage is considered over a particular period of time. (purchased energy) in a facility over a fixed period of time. Initial attention is in general could be started from utility bills, general rates etc. over a reliable period depending on practical pattern or complexity in two-three days. Simply the energy usage is focused to the events directly the energy consumption is visible and accountable to be recorded in a cost centre, a small sector for monitoring.

A detailed audit consists of recording both purchased and generated energy use data for every cost centre in the water district over a fixed period of time and also calculating the energy balances and efficiencies. This audit may require back-up portable measuring instruments referred to as “energy audit equipment”. It may take 1 to 2 weeks to complete a detailed audit depending on the size and type of the facility. The procedure for energy audit is stipulated in Energy Audit Guidebook for Water Utilities in the Philippines (James et al, 2002).

2.8.3 Process components for energy audit

The four (4) process stage components for energy auditing:

- Procedure for planning
- data collection on energy consumption
- analysis gathered data
- initial recommendations

The above stages are discussed below:

a. Planning

b. Different implementing stages are possible for water sector energy audit management programmes are brought to for analysing. As the initial stage prior to the implementation several phases are considered:

Step 1: Commitment from management

Step 2: Assignment of an audit team

Step 3: Formation of objective and goal

Step 4: Measuring equipment as audit tools

Step 1: Commitment from management

Commitment is required to be granted from relevant management levels for a successful energy management. This has to be a successful programme prior to attend the energy audit and that is a must in order the programme not to be failed to reach the goals targeted.

In general, when the programme is presented to the authorised management with the facts and figures for the financial savings and benefits to the factory or the organisation, permission could be achieved for the implementation. It could contain historical data of a similar programme attended by some related parties and the successful results that they have achieved. Among those figures, utility bills would prove the initial flow for the requirement. Since the energy audit program is targeting the reduction of energy consumption and cost component as well, the real

benefit could be highlighted. Support from the relevant management authority levels are really focused only when the contribution from them are felt worth.

Step 2: Assignment of an audit team

Once the support from management is attained, audit team is created to visit and attend relevant activities for the establishment of energy audit programme. Those components include:

- Collecting data for energy consumption
- Gathering real stage of activity performance
- Measuring equipment efficiencies
- Forming standards for activities
- Assessing opportunities for energy conservation
- Presenting an energy audit report

Step 3: Formation of objective and goal

Every energy audit is targeted with an objective and a goal and that is presented by a real statement. The formation of the statement for the objective and the goal will announce the road to define related standards. The management sector is willing to look for proceedings that audit team being attended to see how effective their findings are. They may consist of opportunities for conservation of investment and energy, future goals on saving time and duration of implementation, method for capitalisation of programme etc.

Step 4: Measuring equipment as audit tools

Equipment are required to measure parameters governing the audit survey. When it is basic parameters, standard devises could be used, and when they are secondary or other measurements. Then technically known devises could be implemented. These measurements are very important in. Measuring devises normally use to determine efficiencies are mentioned as follows:

Flowmeter: Device to measure a quantity of fluid over a specific period and also cumulative quantity of flow of the liquid could be measured with flowmeter. Also flow rates and flow velocities could be derived over the reading.

Voltmeter: Electrical potential difference of an electrically driven device is measured by the voltmeter. The audit team need not to be worried about the data printed in the name plate data sometimes in an occasion that they were gone with time or due to the way the device has been conducted to get the performance by deferent employees over a period of time. Sometimes more sophisticated device like multi-meter could be used to measure all Voltage, Current and Resistance.

Wattmeter: Technically the rate of energy is used is measured with this device and it is some mode of product of voltage and current.

Power Factor Meter: Technically this measure gives the figure or the factor of real efficiency compared to total power or energy used.

Thermometers: It measures the temperature and different measures and devises are required to get different measurements of high low levels and also on humidity factor related measures.

Meter Ruler/ Tape: Length is a vital measurement for every application of energy measurement. In water sector energy audit activities, pipe lengths or in compartment dimensions with device arrangements for different aspects of user could be measured and recorded.

Collecting energy consumption data

When all plans are covered data gathered are established in a proper management establish system. Initial meetings and gatherings are held to convey knowledge to the management and the personals those involved in the audit. These gathering result healthy success towards the successful end of the programme. Sometimes attending every activity with top management simply does not give total success. In a factory for example, technical staff, equipment operators are more effective in data

collection aspects. Data may be in different categories, technical data like dimensions of the factory premises for ventilation, comfort etc. dimension of the equipment like blowers surge vessels etc. Sometimes all expenses recorded in bills vouchers are among the needs for energy audit. What type of data are aiming to gather is given in table 2.13 as a summery. Proper approach with reduced expenses over an activity to be implemented in future could be focused with these gathering, implementation and utilisation of the data. Bench marks are fixed by the outcome of the energy audit which will be more and more for the future implementation and required goal achievements.

Table 2.13: Energy Audit Data Required in Water Utilities

| General | Pumps | Electric Motors |
|------------------------|---------------------------------------|------------------------|
| Utility bills | Rated head | Motor application |
| Fuel bills | Discharge and shaft speed (nameplate) | Name plate data |
| Facility bills | Actual discharge | Rated power |
| Facility layout | Pump suction pressure | Rated voltage |
| Production output | Discharge pressure | Current |
| Operating hours | Pump shaft speed | Full load amps |
| Inventory of equipment | Pipe sizes | Power factor |
| | Water level (source) | Load profile |
| | Flow velocity | |

Source: James et al, 2002

c. Analysing energy audit data

Having data is collected, energy managed pattern and equipment efficiencies are calculated. Energy is utilising by different systems in different ways. It may not necessarily be the same audit concocting pattern or the same category of equations are involved to assess the final results or recommendations,

- **Energy Utilisation Calculation**

Calculating to determine energy utilisation explains different dimensions on energy management. Energy is used by machineries but the same machinery gives or dissipates heat still the heat not being among the required component. Someone to

recognise with cost comparison whether the water is a media to use as incompressible fluids than developed other oils. Management of system will explore the engineering practice like thermodynamics or application of Bernoulli's equation is more helpful to continue the programme.

- **Efficiency Calculation**

Efficiency is determined over the energy input to a system simply to energy balance among input and losses, and derive a figure for implementation of a system to achieve better results:

$$\text{Energy Efficiency (\%)} = \frac{\text{Energy input} - \text{Energy Losses}}{\text{Energy input}} \times 100 \quad \text{Equation (2.1)}$$

Equipment wise the result achieved from the audit components as the efficiency could be used to compare with industry norms. When any of the results for an example, efficiency, is weak against the industry norms set out by some industrial, supply or factory basis figures, then it would be a sign to go for the improvements that may be for a single or for a category, step wise:

First Step : Calculate the difference between normal value and result obtained from energy audit.

Second Step : Above difference is multiplied with input of total energy. It is called energy saving potential

It could be considered as a goal for energy conservation and this result is for one type or category.

d. Evaluating opportunities and making recommendations

Different approaches are possible to carry out with energy reduction opportunities. In one energy audit, different opportunities could be approached to have better results. When multiple number of opportunities are executed to attend with programme, improvement is possible with better overall efficiency as an integrated or as a whole plant together.

- Capital requirement to implement recommendation?
- Saving of energy and capital to implement recommendation?
- Saving time to implement recommendation?

The whole outcome of the energy audit is a talent dependant for when the team is more experienced and more skilful, then it is very much easier to identify and implement some more effective measures. Desperate decisions are a team dependant, identifying which component to replace or which equipment to remove is time, capital, energy effected activities. Second consideration is necessary to be focused whether to need additional skill training to new implementation of equipment which is costly. When new plant or equipment is placed. all literature on the installation, operation and operational and break-down maintenance related catalogues logs guidelines are required to be arranged and examined.

- Benefits should be calculated
- Baseline estimate should be prepared
- Energy usage must be compared for new implementation
- Accurate baseline must be set
- Software support will be beneficial
- All must be implemented to one-time programme

e. Report writing

The main receiver of the audit report is the higher management that the consent is given to the energy audit to be carried out. The content of the audit report must be concisely condensed as a report and there:

- process to be implemented must be described
- recommendations must be clearly emphasised
- summary for possible savings
- facility used for auditing
- provision of graphs and tables
- audited

Management must be well convinced with the facts through how decision are made.

When the auditing team comes up with assumptions, the must be brought to the notice by their report in order to consider in reviewing. Sometimes rates referred to material or equipment as a whole may have changed with time change.

2.9 Energy Consuming Equipment of Water Supply Schemes

In municipal water utilities, the biggest consumers of energy are the pumps and electric motors. Therefore, assessing of energy efficiencies of motors and pumps is required in the identification of energy saving opportunities (EPRI, 1994).

2.10 Energy Consumption Assessment of Pumps

Pumping is the main power consuming motor application in general potential energy of water is converted into kinetic energy. Unique pumping sets are used to the situation. Generally, Centrifugal pumps are implemented for water pumping.

- single-stage centrifugal
- multi-stage centrifugal
- axial
- mixed-flow pumps

Other types of pumps are used on different occasions

- Centrifugal split casing
- Positive displacement pumps
- Diaphragm pumps
- Gear pumps
- Rotary pumps

Pump characteristic dependants:

- capacity
- pump head
- water power
- pump shaft power

- net positive suction head
- pump efficiency
- specific speed

Mainly a pump consists of suction port and delivery port in the pump housing, pump shaft and impeller. When impeller rotates water is centrifugally pushed to delivery port. The pumping head could be defined as the net work done on a unit gravity mass of water by the pump impeller.

The head of a pump is defined by Bernoulli equation:

$$h_p = H_1 - H_2 + h_L \quad \text{Equation (2.2)}$$

where:

H_1 = Total delivery head

h_p = Pump head

H_2 = Total suction head

h_L = Total head loss

Water power of a pump is the power gained by water by pump. It is in turn, elevation of water column. Water power is measured in SI units:

$$P_{water} = \frac{\gamma Q h_p}{1000} \quad \text{Equation (2.3)}$$

where:

P_{water} = Water power/ kW

γ = Specific weight of water, 9.81 N/m³

In the event of water power calculation requirement both pump capacity and the pump head must be known.

The pumping set overall efficiency is derived as:

$$\eta_{total} = \frac{P_{water}}{P_{input}} \quad \text{Equation (2.4)}$$

Pump efficiency is calculated as a fraction of shaft power. Therefore, its efficiency is shown as:

$$\eta_{pump} = \frac{P_{water}}{P_{shaft}} \quad \text{Equation (2.5)}$$

The motor likewise has its own efficiency rating:

$$\eta_{motor} = \frac{P_{shaft}}{P_{input}} \quad \text{Equation (2.6)}$$

Therefore the efficiency:

$$\eta_{total} = \frac{P_{water}}{P_{input}} = \frac{P_{water}}{P_{shaft}} \times \frac{P_{shaft}}{P_{input}} = \eta_{water} \times \eta_{motor} \quad \text{Equation (2.7)}$$

This equation shows that the overall efficiency for a particular pumping set could be considered as multiplication of the efficiency of the motor and efficiency of the pump. When modern pumping sets are considered they are in efficiencies in higher side and as a figure around 80%. To achieve such a higher efficiency for a pumping set, their individual motor and pump efficiencies must lie around 90% which is a good combination.

In addition, losses could be incurred due to excessive pressure of water that is pumped. If the water delivered in the reservoir has too much kinetic energy, it is all dissipated as heat in the reservoir. If the system was more properly designed, a smaller pump and motor could do the same work instead of using bigger size pump and motor which consume more energy.

As a general statement, pumping sets with 100% is not practical for no perfect motion is ever met. An energy component is separated in the event of sound generation and other component is for generation of heat in both motor section and pump section.

2.11 Assessment of Energy Consumption for Motors

Generally, pumping sets available in the market are about 81 to 92% energy is used by motor as electrical power. Two types of motors are in practice used for pump coupling, one is general-purpose capacitor start and the other type is typical poly-phase design. In national water sector utilities, it is common practice higher capacities are obtained with high voltage panel operations. Medium capacities up to about 500m³/hr are operated with low voltage panel operations. Motor variety concept can be obtained from Figure 2.7:




Figure 2.7: Graphic representation of power triangle
Source: Alliance to Save Energy, 2002

As displayed in the figure 2.7, a horse is pulling a rail cart. At any time, the horse is pulling the cart along the railroad, the effort the horse put to pull the cart works to the work. But when the horse is pulling the cart perpendicular to the rail hardly any work could be done. Therefore, as illustrated in the figure, horse is pulling the cart to a direction that a portion of the effort goes for movement of the cart and that force could be named as active power. Perpendicular component to road does nothing to pull the cart along the road and hence that component is called reactive power.

As the power components are said then active power and reactive power are identified. The ratio real power to total power is called the power factor. When from

outside the horse is observed, though horse is giving its total effort to pull the cart only a portion of its effort works. This power factor to become 1, horse must pull the cart along the rail road. Then reactive power component become zero. When horse is pulling the cart to perpendicular direction to the road, then the power factor value become one. However, at both occasions, horse is making his full effort to pull the cart, whether the effort is successful or not.

$$\text{Power Factor} = \frac{\text{Real Power}}{\text{Apparent Power}} \quad \text{Equation (2.8)}$$

$$\text{Real Power} = \sqrt{3} \cdot V \cdot I \cdot \cos \phi \quad \text{Equation (2.9)}$$

$$\text{Apparent Power} = V \cdot I \quad \text{Equation (2.10)}$$

Where:

V : Voltage (V)

I : Current (A)

Cos ϕ : Power factor

Several benefits are achievable with improvement of power factor.

- capacity of the plant could be increased
- “penalty” could be eliminated on charges over reduced power factor by Ceylon electricity board
- power losses are reduced and supply voltage is improved
- nationally feeders’ effort become less in distribution, transformers and other related equipment.

Power factor improvements possibilities:

- Installation of capacitor banks parallel with motor supply to reduce the reactive power component in the AC circuit
- Eliminating operation of idling or less loaded motors.
- Replacements with efficient motors for inefficient motors as much as possible
- Operating the equipment at its specified operating point
- Make sure that specification for operation is correct

2.12 Energy Conservation Methods

2.12.1 Schedule adjustments for pump operation

Usually for a three phase power supply, the electricity bill consists of two types of charges. One is the charge for the load on the power supply system which is measured in kVA. The other is the charge for electricity consumption measured in kWh (active power). By adjusting the pump operation schedules the load on the system could be reduced and cost savings can be gained. For an example when backwashing filters, backwash pumps and air compressor have to be operated. This will increase the load on the electricity supply and the monthly kVA charge will be increased. If the distribution pumps were turned off before switching on backwash pumps and air compressor the maximum load on the system will not increase. However, this does not have any effect on kWh.

2.12.2 Reduce in pipe frictions in pumping lines

Several factors are affected to pipe internal friction to flow; due to roughness of the pipe with ageing, corrosion, hardness and causing reduction of internal diameter, due to scaling. These cause increases the energy requirement for pumping water. Cleaning or replacing these pipe lines can provide significant energy savings. A cost benefit analysis considering the useful lifetime of pipes should be carried out to understand whether the replacement is cost effective.

The effect of pipe friction on motor power can be described using Figure 2.8. The proposed operating point is OP1 (Q1, H1) on system curve 1. If the friction is reduced the operating point will be shifted to and OP2 (Q2, H2). The efficiencies of pump at these two operations are E1 and E2 (James et al, 2002).

$$\textit{The change of pump power} = (\gamma Q_1 H_1 / E_1) - (\gamma Q_2 H_2 / E_2) \quad \text{Equation (2.11)}$$

For constant speed pumps we can assume the motor efficiency (E_m) to be constant over the operation range.

$$\begin{aligned} \textit{The change in motor input power} & \quad \text{Equation (2.12)} \\ & = \{(\gamma Q_1 H_1 / E_1) - (\gamma Q_2 H_2 / E_2)\} / E_m \end{aligned}$$

2.12.3 Throttling of pumping lines

Throttling is done to reduce the flow in a fixed speed pumping system when the pump delivers more quantity than required. Pump throttling shifts the operating point of the pump curve to another point where the efficiency shifts from the desired point. This causes additional consumption of energy which is a waste. This energy can be conserved by introducing a VFD to a fixed speed pumping system or by trimming the impellers.




Figure 2.8: Effect of reducing pipe friction
Source: Modified from James et al, 2002

2.12.4 Implementation of capacitor banks

Higher ampere rated equipment are in general uses three phase power supply source which consists of two kinds of power, active and reactive. The reactive power depends on the power factor and the power consumed during the various periods. The active power does the real work. The power factor improvement helps to reduce reactive power component of the electric device. Capacitor bank installation assists the system to reduce the power factor closer towards 1.

2.12.5 Adjusting operation schedules to take advantage of tariff structure

Some countries have different electricity tariffs for peak and off peak times of electricity consumption. If the operation schedules of the WSS could be adjusted accordingly to take the benefit of this tariff structure, significant cost savings can be achieved.

2.12.6 Introduction of Variable Frequency Drives (VFD)

Water demand of a distribution system with direct pumping operation varies according to instantaneous demand pattern and pumps with fixed operating frequency maintains water at the same head and flow rate curve which leads to vary the head depending on the flow rate. This is a waste of energy and equipment and by installing VFD the energy could be saved. VFD helps to adjust the motor speed to the required level with the demand and flow matching with head of the pump, reducing the energy losses.




Figure 2.9: The effect of installing a Variable Speed Drive
Source: Modified from James et al, 2002

The effect of reducing pump friction and the function of VSD is shown in Figure 2.9. For an example a pumping system operates at OP1 (Q_1, H_1) at pump efficiency E_1 (system curve 1 and pump curve 1). At this operating point the pump is running at lesser than maximum efficiency also. If the friction of the pumping system can be reduced, the system curve will change as system curve 2 and the operating point will shift to OP2 which will cause the reservoir to overflow due to increased flow. A VSD can shift the pump curve down as shown in pump curve 2. The operation point is OP3 (Q_1, H_3). At OP3 the flow rate is equal to the required flow rate, head is reduced to H_3 and the pump is running at maximum efficiency. The energy saved could be calculated as follows (James et al, 2002)

$$\text{The change of pump power} = (\gamma Q_1 H_1 / E_1) - (\gamma Q_1 H_3 / E_2) \quad \text{Equation (2.13)}$$

For constant speed pumps we can assume the motor efficiency (E_m) to be constant over the operation range.

$$\begin{aligned} \text{The change in motor input power} & \quad \text{Equation (2.14)} \\ & = \{(\gamma Q_1 H_1 / E_1) - (\gamma Q_2 H_3 / E_2)\} / E_m \end{aligned}$$

$$\text{Energy saved} = [\{(\gamma Q_1 H_1 / E_1) - (\gamma Q_2 H_3 / E_2)\} / E_m] N \quad \text{Equation (2.15)}$$

2.13 Energy Conservation Potential by Reducing Water Losses at Treatment Plant and Distribution

Reduction of water losses at the water treatment plant and the distribution will reduce the energy consumption of a water supply scheme. There are two strategies to reduce the water losses: reducing water losses in treatment plant and reduction of Non-Revenue Water (NRW) in the distribution network. The energy saving from water losses in the treatment plant is due the elevation difference between the WTP and the intake.

The energy saving from NRW is due to the reduction of daily/monthly production. Table 2.14 presents the energy conservation potential of incremental reductions of NRW at Hapugala WSS considering the total specific energy consumption of

surface water supply scheme as 0.78 kWh/m³ and average daily production as 9000m³/d.

Table 2.14: Energy Conservation Potential of Reducing NRW in Hapugala Water Supply Scheme

| NRW Reduction (%) | Quantity saved (m ³ /month) | Reduction in production (m ³ /month) | Reduction in energy consumption (kWh/month) |
|-------------------|----------------------------------------|-------------------------------------------------|---------------------------------------------|
| 1 | 5169 | 5169 | 4032 |
| 2 | 10338 | 10338 | 8064 |
| 3 | 15508 | 15508 | 12096 |
| 4 | 20677 | 20677 | 16128 |
| 5 | 25846 | 25846 | 20160 |
| 6 | 31015 | 31015 | 24192 |
| 7 | 36185 | 36185 | 28224 |
| 8 | 41354 | 41354 | 32256 |
| 9 | 46523 | 36288 | 46523 |
| 10 | 51692 | 40320 | 51692 |

Source: Modified from Kalaimathie, 2012

2.13.1 Reducing water losses in treatment plant

The water losses in a water treatment plant usually ranges from 2 to 5% of total volume of treated water. The major portion of this water loss is through filter backwash. The energy consumed in pumping this water from the source to WTP is wasted due this water loss.

Reducing the frequency of filter backwashing is one possible option to save energy. However, this has to be done without compromising the flow rate through the filter and required effluent quality.

The other option is the recovery of backwash water. The major concern in backwash water recovery is the removal of Cryptosporidium and Giardia which is concentrated in filter backwash waters. To meet the challenges of the stringent drinking water regulations established to improve controlling of Cryptosporidium and Giardia, additional physical and chemical water treatment processes are required. Pressure-driven membrane processes such as microfiltration and ultrafiltration are playing an

important role in drinking water production in the USA and in Europe (Betancourt and Rose, 2004).

Ceramic micro filters have the higher potential for removing *Cryptosporidium* and *Giardia* which exists in natural water sources and in filter backwash waters. In addition, ceramic microfiltration can provide high removal for colour, turbidity, iron, manganese and aluminium for 0.1 and 1µm membranes. Ceramic microfiltration facilitates high water recovery leading to minimize the wastewater volume for sludge dewatering process (Kalaimathie, 2012).

As per a pilot plant study carried out in Netherland energy consumption for treating backwash water using dead end micro filtration is 0.15 kWh/m³ (Willemse and Brekvoort, 1999). The Dutch Foundation for Water Research (STOWA) specifies that the energy consumption for micro filtration ranges from 0.1 to 0.2 kWh/m³ (STOWA, 2013).

2.13.2 Reduction of Non-Revenue Water (NRW) in the distribution network

Water losses in the treated water transmission and distribution network are indicated using the key performance indicator Non-Revenue Water (NRW). NRW represents the difference between net production and the net water quantity sold.

$$\begin{aligned} \text{Non Revenue Water (NRW)} & \qquad \qquad \qquad \text{Equation (2.16)} \\ & = \frac{(\text{Net water production} - \text{Net water quantity sold})}{\text{Net water production}} \times 100 \end{aligned}$$

NRW consists mainly of two components: physical losses (real losses) and commercial losses (apparent losses). The physical losses are the water lost through pipe breaks and leakage, overflows of distribution tanks and house connection leaks. Commercial losses are water consumed but not paid for due to meter under-registration, illegal connections or unbilled authorized consumption (IWA, 2000). NRW in major cities in Asia are shown in Figure 2.10 (ADB, 2004). The NRW of these cities are more than 10% except for Osaka. However, the American Water Works Associations (AWWA) benchmark for NRW is 10% (AWWA, 1998).

The level of losses from water systems is often considered by observers from outside the industry to be unacceptable. Environmentalists and regulators have expressed concerns at the level of losses, and believe that lower levels should be achievable. However, any water company has to work within current operating budgets and seek additional finance if these are not sufficient. Leakage control can be expensive, and water companies will seek to achieve an economic balance between the costs of leakage control and the benefits that accrue. Economic Level of Leakage is the acceptable level of leakage, assessed considering this economic balance (Pearson and Trow, 2005).

The range of ELL for low and medium income countries is 155 - 310 L/connection/day (Frauendorfer and Liemberger, 2010).




Figure 2.10: Non revenue water in major cities in Asia
Source: ADB,2004

3. METHODOLOGY

3.1 Introduction

The study targeted as stated in chapter 1, two main activities to reach the objectives. Activity one is to assess the potential for energy conservation by carrying out energy audits in selected Water Supply Schemes (WSSs) and second is to develop benchmarks for energy consumption processes in water supply schemes using primary and secondary data collected. Figure 3.1 shows the overall research plan.




Figure 3.1: Overall research plan

3.2 Selection of Water Supply Schemes for the Study

Five WSSs from Southern Region were selected for the study. Selected WSSs are Greater Galle – Hapugala WTP, Malimbada WTP, Ruhunupura WTP, Hallala WTP and Tangalle WTP. The scheme data selected are presented in Table 3.1. Both technical and management aspects were considered when selecting these WTPs for the study.

Selected water supply schemes use surface water from rivers and tanks as raw water. Tangalle WSS was commissioned in 2000 and all other selected Water Treatment Plants (WTPs) had been commissioned within last ten years. This was done to represent old and newly constructed WSSs in Southern Region. The schematic diagrams of the selected water supply schemes are shown in Figures A.1 to A.5 of Appendix A.

Selected WTPs produce drinking water which comply to SLS 614:1983. However, the standards are in the recommended ranges of WHO Drinking Water Guideline: 2008. Comparison of these standards with the WHO guideline is attached in Table A.1 in Appendix A (BOI, 2013; WEPA, 2013; WHO, 2011).

Design capacity ranges from 9000 m³/d to 43,000 m³/d and present production ranges from 8000 m³/d to 45,000 m³/d. Therefore, Greater Galle – Hapugala WTP and Malimbada WTP can be categorized as large scale and Ruhunupura WTP, Hallala WTP and Tangalle WTP can be categorized as medium scale according to the Sri Lankan context. All selected WTPs employ conventional water treatment process except Ruhunupura WTP where flocculation and sedimentation is performed using a pulsator clarifier and micro strainer and DAF system for algae removal. All the WTPs are situated in dry climate. Greater Galle – Hapugala WTP, Malimbada WTP and Ruhunupura WTP are operated using Supervisory Control And Data Acquisition (SCADA) systems. Other schemes are operated semi-automated.

3.3 Primary and secondary data collection through energy audit

Both primary and secondary data were collected by carrying out energy audits in selected WSSs to evaluate the specific energy consumption and to identify and quantify energy conservation potentials.

The energy audits were carried out in two stages; preliminary auditing stage and detailed auditing stage. In preliminary audit, energy consumption was analysed to identify the most likely areas for immediate improvement and estimate the scope for saving. In this stage an equipment inventory was created and the distribution of energy demand in the system was documented to find the most likely areas for immediate improvement. In addition to data required for quantifying energy consumption, data required to quantify water losses also collected. The primary and secondary data collected at preliminary audits are presented in table 3.2. The rated parameters of the equipment were collected to check whether the measured parameters were in acceptable range.

The detailed audit was carried out to check the potential for increased plant efficiency. Data required for evaluation of performance of the pumps and other energy utilizing equipment in the plants were collected at this stage. In addition, data required for quantifying the potential energy savings from reduction of leakage was also collected. The primary and secondary data collected at detailed energy audit is presented in table 3.3.

Table 3.1: Comparison of Selected Water Supply Schemes as at 31 December 2015

| Water Supply Scheme | Hallala WTP | Hapugala WTP | Malimbada WTP | Ruhunupura WTP | Tangalle WTP |
|--------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| District | Matara | Galle | Matara | Hambantota | Hambantota |
| Type of source | Surface water | Surface water | Surface water | Surface water | Surface water |
| Name of the source | Nilwala River | Gin River | Nilwala River | Ridiyagama Tank | Kirama Oya |
| Year of commissioning | 2012 | 2010 | 2008 | 2015 | 2000 |
| Treated water quality standard | SLS 614:1983 drinking water standard | | | | |
| Design capacity (m3/day) | 8000 | 32000 | 45000 | 17500 | 9000 |
| Present production (m3/day) | 7600 | 32000 | 43000 | 11000 | 8000 |
| Treatment process | <ul style="list-style-type: none"> • Rapid mixing (hydraulic jump) • Flocculator • Sedimentation tank • Rapid sand filters • Gas chlorination | <ul style="list-style-type: none"> • Aerator • Rapid mixing (hydraulic jump) • Flocculation & Sedimentation by Pulsater clarifier • Rapid sand filters • Gas chlorination | <ul style="list-style-type: none"> • Aerator • Rapid mixing (hydraulic jump) • Flocculator • Sedimentation tank • Rapid sand filters • Gas chlorination | <ul style="list-style-type: none"> • Aerator • Rapid mixing (hydraulic jump) • Flocculator • DAF • Sedimentation tank • Rapid sand filters • GAC • Gas chlorination | <ul style="list-style-type: none"> • Rapid mixing (hydraulic jump) • Flocculator • Sedimentation tank • Rapid sand filters • Gas chlorination |
| Number of connections | 11000 | 45000 | 80000 | 9000 | 9000 |
| Number of consumers | 55000 | 225000 | 365000 | 45000 | 82690 |
| Distribution length (km) | 210 | 510 | 610 | 395 | 430 |
| Topography | Plain | Plain | Plain | Plain | Plain |
| Highest elevation-MSL (m) | 78 | 102 | 88 | 78 | 71 |
| Lowest elevation-MSL(m) | 10 | 40 | 32 | 20 | 18 |
| Climate | Wet | Wet | Wet | Erid | Erid |
| Automation | Semi-automated | Semi-automated | Semi-automated | SCADA | Semi-automated |

Table 3.2: Primary and Secondary Data Collected During the Preliminary Energy Audit

| Secondary Data | | | Primary Data | |
|------------------------|--------------------|-----------------|---------------------|------------------|
| General | Motors | Pumps | Motor | Pump |
| Electricity bills | Rated power | Rated head | Actual power | Actual head |
| Schematic diagram | Rated voltage | Rated discharge | Actual voltage | Actual discharge |
| Inventory of equipment | Rated current | | Actual current | |
| Monthly production | Rated power factor | | Actual power factor | |
| Monthly consumption | Operating hours | | Operating hours | |

Table 3.3: Primary and Secondary Data Collected During the Detailed Energy Audit

| Secondary Data | | | Primary Data | |
|-----------------------------|------------------|----------------------------------------------|---------------------|----------------------------------|
| General/ NRW | Motors | Pumps | Motors | pump |
| Pipe length | Rated efficiency | Manufacturers Pump characteristic curve | Actual input power | Actual pump characteristic curve |
| Number of house connections | | Manufacturers Pump efficiency curve | Actual output power | Actual Pump efficiency curve |
| Length of house connection | | System characteristic curve for pumping main | Actual efficiency | |
| Average pressure | | Hydraulic profile | | |

As per the table 3.2 and 3.3 following parameters were measured during energy audits including basic electrical parameters; voltage (V), current (I), power factor, energy consumption (kWh), flow rate (m³/h) and pump head (Bar).

Non – contact type flow meters such as Doppler Effect flow meters or ultra-sonic flow meters and volumetric meters were used to measure the flow rate where available. Measurements of parameters namely current, voltage, power factor, active power, energy consumption related to flow were done using clip-on meters without stopping the equipment. The pump pressure head was measured using pressure gauge.

3.4 Secondary Data Collection for Creating Benchmarks

To create the benchmarks for energy consumption in water treatment unit processes, the specific energy consumption of water supply schemes in countries such USA,

Canada, UK, Australia, New Zealand, Spain and Taiwan was collected by literature review.

3.5 Calculation of Energy Consumption and Efficiencies

The calculation procedure for efficiencies is as follows:

$$\text{Water power} = P_H = Q\rho gh \quad \text{Equation (3.1)}$$

$$\text{Electric input power} = P_I = \sqrt{3}.V.I.\cos\phi \quad \text{Equation (3.2)}$$

$$\text{Pump Efficiency} = \eta_p = P_H/P_T \quad \text{Equation (3.3)}$$

$$\text{Motor Efficiency} = \eta_M = P_T/P_I \quad \text{Equation (3.4)}$$

$$\text{Overall Efficiency} = \eta_r = \eta_p * \eta_M \quad \text{Equation (3.5)}$$

Where:

| | | | |
|------------|----------------------------------------|----------------|--------------------------|
| Q | : Flow rate (m ³ /s) | PI | : Input electrical power |
| H | : Total head (m) | η_M | : Motor efficiency |
| ρ | : Density (kg/m ³) | P _T | : Motor output power |
| G | : Specific gravity (ms ⁻²) | η_r | : Overall efficiency |
| V | : Voltage (V) | η_P | : Motor efficiency |
| I | : Current (A) | P _H | : Water power |
| Cos ϕ | : Power factor | | |

3.6 Energy Balance of Water Supply Schemes

Following performance indicators were considered during benchmarking;

Energy consumption of treated water produced per unit volume in kWh/m³.
Considered individual unit processes.

For energy balance calculations, typical energy consumption points in a WSS are shown in Figure 3.2.




Figure 3.2: Typical energy consumption points in WSS

The Specific Energy Consumption:

$$\text{Total Energy Consumption (E)} = E_1 + E_2 + E_3 + E_4 + E_5 \quad \text{Equation (3.6)}$$

$$\text{Energy Consumption for Unit Volume} = E/Q \quad \text{Equation (3.7)}$$

Where:

Q : Total volume of water produced in m³

E : Total Energy consumption (kWh)

3.7 Benchmarking of Energy Consumption in Unit Processes

Likewise, for unit volume, specific energy consumption consumed at each unit process for individual unit processes were identified separately for benchmarking. The energy consumption for each unit process was estimated from the electricity readings directly when available or else from other measurements such as bulk meter readings and pressure gauge readings. When all of the above measurements were not available, the energy consumption was estimated using rated power consumption of the particular equipment being used. The sum of the energy consumption of each unit process estimated was compared with the total energy

consumption of said water treatment scheme obtained from electricity meter readings. Typical energy consumption points in a water treatment model plant are illustrated in Figure 3.3.




Figure 3.3: Typical energy consumption points in a drinking water treatment plant

The energy consumption was calculated as follows:

$$Total\ energy\ consumption\ (E) = ET1 + ET2 + ET3 + ET4 + ET5 + ET6 + ET7 + ET8 + ET9 \quad \text{Equation (3.8)}$$

$$Energy\ consumption\ for\ treatment\ of\ unit\ volume = E/Q \quad \text{Equation (3.9)}$$

Where:

Q : Total volume of water produced in m^3)

E : Total Energy consumption (kWh)

ETT1-T8 : Energy consumption of unit processes (kWh)

The energy assessed for unit processes was adjusted so that total calculated energy consumption (E) was equal to total measured from electricity meter.

3.8 Calculation of Energy Conservation Potential of Reducing Non-Revenue Water

Non-Revenue Water (NRW) is the difference in the quantity of water produced and the quantity of water sold and it was calculated using equation 3.10.

$$NRW(\%) = \frac{(\text{Net water quantity produced} - \text{Net water quantity sold}) \times 100}{\text{Net water quantity produced}} \quad \text{Equation (3.10)}$$

The major components of NRW are physical losses and commercial losses. The physical losses are the water lost through pipe breaks and leakage, overflows of distribution tanks and house connection leaks. Commercial losses are water consumed but not paid for due to meter under-registration, illegal connections or unbilled authorized consumption (IWA, 2000).

The total NRW was apportioned to above components of water losses and the potentials for reduction of water loss in above components was estimated. The potential to reduce real losses was calculated using equation 3.11 utilizing the Economic Level of Leakage (ELL) concept. The range of ELL for low and medium income countries is 155- 310 L/connection/day (Frauendorfer and Liemberger, 2010).

$$\text{Reduction potential of real losses} \left(\frac{L}{\text{day}} \right) = \text{Real Losses} - \text{ELL} \quad \text{Equation (3.11)}$$

Where:

N_p = number of service connections

The energy conservation potential of reducing NRW is calculated using equation 3.12.

$$\begin{aligned} \text{Energy saving potential of NRW reduction} & \quad \text{Equation (3.12)} \\ & = (\text{Quantity of water saved in } m^3) \\ & \times (\text{Specific energy consumption in } kWh/m^3) \end{aligned}$$

3.9 Investigate the Energy Conservation Methods

Using the results of benchmarking study and energy audit, opportunities for energy conservation using following technical options were assessed.

- Adjusting pump operation schedules – Method discussed in section 2.12.1
- Reduce resistance in pipe lines and avoid pump throttling – Calculation method discussed in section 2.12.2
- Adjusting of operation schedules to get the advantages of electricity tariff structures – Only preliminary assessment was done
- Introduction of Variable Speed Drives (VSD) - Calculation method discussed in section 2.12.6

In addition to the above direct energy savings methods, the indirect energy saving which could be gained by reducing water losses was also assessed as discussed in section 3.8.

4. RESULTS AND DISCUSSION

This research was conducted by carrying out energy audits in Ruhunupura, Hapugala, Malimbada, Tangalle WSSs and Hallala to benchmark the energy consumption of water treatment unit processes and to identify the energy conservation potentials in WSSs. The schematic diagrams of the treatment processes of these WSSs are shown in Figures A.1 to A.5 of Appendix A. Preliminary energy audits were carried out to figure the different energy consumption components and water treatment unit processes of the selected WSSs. The quantified energy consumption was used to determine the values of the KPI for energy benchmarking; specific energy consumption of the unit process expressed in kWh/m³. During the preliminary audit energy conservation potentials in the audited WSSs were identified and detailed audits was carried out as per the methodology stipulated in Chapter 3.

4.1 Electricity Consumption of Schemes and Benchmarking of Power Consumption in Water Treatment Unit Processes

There are three major energy consuming components in a WSS as shown in Figure 4.1. This study investigated the energy consumption of all components of the selected WSSs to identify the energy conservation potentials. However, benchmarking was carried out for treatment unit processes only since raw water and distribution pumping varies with many factors such as topography, length of pumping mains, characteristics of pumps and characteristics of pumping mains.




Figure 4.1: Major components of energy consumption in a water supply scheme

4.1.1 Preliminary audit of energy consumption in water supply schemes

Preliminary energy audits were carried out in all selected WSSs to evaluate the energy consumption and primary and secondary data were collected as stipulated in the Chapter 3. A volume balance analysis and an energy balance analysis were carried out to check whether the collected data were acceptable.

- **Volume flow balance analysis**

The volume flow balance analysis was carried out for the boundary from intake pump inlets to the treated water pump outlets of the WTPs using the data presented in tables B.1 to B5 of Appendix B. The volume flow balance was analyzed based on the following equation 4.1.

$$\begin{aligned} & \textit{Total raw water volume pumped} && \text{Equation (4.1)} \\ & = \textit{Total treated water volume pumped} \\ & + \textit{Total volume of backwash water} \\ & + \textit{Volume of sludge water, losses and increase in stored volume} \end{aligned}$$

Table 4.1: Volume Flow Balance and Energy Balance of Selected Water Supply Schemes during Preliminary Energy Audit

| Description | Water Supply Scheme | | | | |
|------------------------------------------------------------|-------------------------|--------------------|--------------------|----------------------|---------------------|
| | Hallala | Ruhunupura | Hapugala | Malimbada | Tangalle |
| Preliminary audit duration | | | | | |
| From | 09.00 15/12/2015 | 09.00 4/01/2016 | 7.00 7/01/2015 | 07.00. 16/01/2016 | 09.00 19/01/2016 |
| To | 09.00 16/12/2015 | 09.00 5/01/2016 | 07.00 8/01/2016 | 07.00 17/01/2016 | 09.00 20/01/2016 |
| Volume flow balance | | | | | |
| Raw water quantity (m ³) | 9680 | 8250 | 18100 | 36570 | 10632 |
| Treated water quantity (m ³) | 9655 | 8030 | 17768 | 36007 | 10464 |
| Backwash water quantity (m ³) | From service reservoir* | 201 | 225 | 450 | 136 |
| Sludge water, losses & change of storage (m ³) | 25 | 19 | 107 | 113 | 32 |
| % Losses & Change of storage (m ³) | 0.26 | 0.23 | 0.59 | 0.31 | 0.30 |
| Energy balance | | | | | |
| Total input energy (kWh) | 3857 | 5776 | 10785 | 21598 | 4371 |
| Total energy consumption (kWh) | 3830 | 5719 | 10666 | 21346 | 4331 |
| Miscellaneous and losses (kWh) | 27 | 57 | 119 | 252 | 40 |
| % Miscellaneous and losses (kWh) | 0.7 | 0.98 | 1.1 | 1.4 | 0.92 |

Note *: Backwash water is supplied from service reservoir. Therefore it has to be considered as an outflow/consumption from service reservoir

The volume flow data of preliminary audits of selected WSSs are presented in Table B.1 to B.5 of Appendix B and the volume flow balance analysis of selected WSSs are presented in Table 4.1. The volume of sludge water was considered as part of the losses since the volume of sludge water is small compared to the volume of backwash water. The component of sludge water, losses and increase in stored volume is less than 1.4% as shown in Table 4.1. Therefore, the volume flow balance was acceptable and the quantity of treated water pumped was considered for calculation of specific energy consumption.

- **Energy balance analysis**

The energy balance analysis was carried out for the boundary from intake pump inlets to the treated water pump outlets of the WTPs. The energy consumption of all the equipment were calculated using measured parameters and assigned to the equation 4.2 to check the energy balance.

$$\begin{aligned}
 & \textit{Total power consumption} && \textit{Equation (4.2)} \\
 & = \textit{Power consumption of raw water pumps} \\
 & + \textit{Power consumption of treated water pumps} \\
 & + \textit{Power consumption for water treatment} \\
 & + \textit{Unmeasured miscellaneous power consumptions and losses}
 \end{aligned}$$

The miscellaneous and loss component consisted of energy consumption of air conditioning, lighting, small equipment like hoists, SCADA panel and losses.

The inventory of energy consuming equipment, energy consumption data of above equipment and energy balance diagrams of selected WSSs are presented in Tables B.6 to B.23 and Figures B.1 to B.5 of Appendix B, and the summary of energy balance analysis of selected WSSs are presented in Table 4.1. The energy consumption of miscellaneous and losses component is around 1% as shown in Table 4.1. Therefore, the energy balance was acceptable.

4.1.2 Boundary and the time frame for total specific energy consumption for drinking water supply schemes using surface water sources

The analysis in sections 4.1.3, 4.1.4 and 4.1.5 are carried out for the following boundary and time frame. The energy consumed in a WSS consists basically of three major components: energy for pumping raw water, energy for water treatment and energy for distribution pumping. The boundary for this analysis is from the intake screens to the water meter of consumer. Energy consumption from intake screens to treated water pumps in the treatment plant was assessed using energy audits. The energy consumption of the pump houses in the distribution was assessed using the electricity bills (specific energy consumption calculated using annual cumulative production and energy consumption data). The time frame was the relevant audit time presented in relevant data tables.

4.1.3 Total specific energy consumption for drinking water supply schemes using surface water sources

The total SEC of water supply for the studied WSSs and other referenced countries in Chapter 2 are shown in Figure 4.2. As per the Figure 4.2, the total SEC for the selected WSSs varies from 0.48 kWh/m³ at Tangalle WSS to 0.851 kWh/m³ at Ruhunupura WSS. This is mainly due to the topographical variations in the areas where these WSSs are located. There is a considerable variation between the total SEC of Hallala WSS and Bankhen WSS. The Bangkok Metropolis is located at latitude 13.45° North and longitude 100.28° East with a mean elevation of about 2.31m above mean sea level (Babel and Rivas, 2011). Therefore, the mean elevation difference for Bankhen WSS is 2.31m. Whereas for Hallala WSS, the elevation difference is 54 m. This large variation in elevation difference of the service area is the main reason for the considerable variation in SEC between Hallala and Bankhen WSSs. Sydney and North California shows higher values compared to Asian countries. The variation in these values depends on many factors such as topography, distribution network length, pump and motor efficiencies, pumping main characteristics and service level etc.

The relevant calculations for specific energy consumption are shown in Tables B.17 to B.25 of Appendix B. A summary of specific energy consumption is shown in Table B.26 of Appendix B.




Figure 4.2: Total specific energy consumption for water supply schemes using surface water sources

4.1.4 Energy consumption of major components in water supply schemes

The energy consumed in a WSS consists basically of three major components: energy for raw water pumping, energy for water treatment and energy for distribution pumping. The percentages of energy consumption for the above components in selected WSSs are shown in Figure 4.3. According to the above Figure, in all studied WSSs the major portion of energy was consumed for raw water and treated water pumping. The energy consumption for water treatment varies from 0.4 to 3.3 % and this shows that any attempt on reducing energy consumption in WSSs has to concentrate more on energy conservation in raw water and treated water pumping. The percentage energy consumption for raw water pumping is significantly high at Hallala WSS because the Hallala WSS is located at the top of a

mountain which is about 1 km away from the intake. In all other audited WSSs the WTP is located near the intake.




Figure 4.3: Energy consumption of major components in selected water supply schemes

4.1.5 Energy consumption for raw water and distribution pumping

Specific energy consumption of raw water and treated water pumping can be expressed in several units: energy consumption per unit volume produced expressed in kWh/m³, energy consumption per unit volume pumped per unit lift in elevation expressed in kWh/m³/m lift and energy consumption per unit volume pumped per unit lift in height per unit length of pumping main expressed in kWh/m³/ m lift/ km. The following section analyses the SEC of raw water and treated water pumping according to above units.

- **Specific energy consumption per unit volume produced**

The SEC of raw water and treated water pumping in kWh/m³ for the studied WSSs and other referenced countries in chapter two are shown in Figure 4.4. The SEC of raw water pumping varies from 0.095 kWh/m³ in Hapugala WSS to 0.146 kWh/m³ in Malimbada WSS. Hallala WSS show the highest SEC for raw water pumping. This is partially due to the reason that Hallala has the highest elevation difference

between intake and WTP from the audited WSSs. Bankhen WSS shows the minimum SEC for raw water pumping WTP. South California shows a lower SEC for raw water pumping compared to Asian countries except Bankhen WSS.

The SEC of distribution pumping varies from 0.344 kWh/m³ in Mawanalle WSS to 0.724kWh/m³ in Ruhunupura WSS. This can be justified since the Ruhunupura distribution pumping main has the highest elevation difference of the audited WSSs. The SEC of distribution pumping in Hallala WSS and South California were also within the Sri Lankan range except the Bankhen WSS, which has the lowest SEC for distribution pumping.




Figure 4.4: Specific energy consumption for raw water and distribution pumping in kWh/m³

The SEC for raw water and distribution pumping expressed in kWh/m³ depends on many factors such as topography, service level, pump and motor efficiencies and pumping main characteristics and therefore it is not a successful indicator to compare the energy efficiency of raw water and treated water pumping.

- **Energy consumption per unit volume produced per unit elevation**

The SEC of raw water and treated water pumping in kWh/m³/ m lift for the studied WSSs are shown in Figure 4.5. The SEC for raw water pumping and distribution pumping show less variation, when it is normalized for the elevation difference. The SEC for raw water pumping varies from 0.004 kWh/m³/ m lift to 0.008 kWh/m³/ m lift. The SEC for distribution pumping varies from 0.005 kWh/m³/ m lift to 0.006 kWh/m³/ m lift. These variations are due to length of pumping main, the characteristics of pipes and efficiency of the pump and motors used for pumping etc.




Figure 4.5: Specific energy consumption for raw water and distribution pumping in kWh/m³/m lift

- **Energy consumption per unit volume produced per unit lift in elevation per unit length in pumping main**

The SEC of raw water and distribution pumping in kWh/m³/m lift/km for the studied WSSs are shown in Figure 4.6. The length of the pumping main was indicated in kilo meters because some pumping mains are several kilo meters long. The SEC for raw water pumping varies from 0.003 kWh/m³/m lift/km in Tangalle and Ruhunupura WSSs to 0.033 kWh/m³/m lift/km in Hapugala WSS. The SEC for distribution pumping varies from 0.001 kWh/m³/m lift/km in Ruhunupura WSS to 0.005 kWh/m³/m lift/km in Hallala WSS. These variations are mainly due to overall motor and pump efficiencies and pumping main characteristics such as bends, throttles and friction of pipes. Since the above factors can be controlled by designer, the above indicators can be used to benchmark energy consumption of raw water and distribution pumping. The water pumping mains have to be operated at high pressure heads because the pumping head depends on the elevation differences.




Figure 4.6: Specific energy consumption for raw water and distribution pumping in kWh/m³/m lift /km

4.1.6 Energy consumption for surface water treatment

The SEC for conventional surface water treatment process in the audited WTPs are shown in Figure 4.7. The relevant calculations for specific energy consumption are shown in Tables B.17 to B.25 of Appendix B. A summary of specific energy consumption is shown in Table B.26 of Appendix B. The SEC varies from 0.003 kWh/m³ in Ruhunupura and Tangalle WTPs to 0.018 kWh/m³ in Hapugala WTP. For Sri Lankan context the SEC for water treatment varies between 0.003 and 0.018 kWh/m³.




Figure 4.7: Specific energy consumption of conventional drinking water treatment for surface water sources

Chlorine is widely used to disinfect drinking water. Chlorine can be used as a gas or as a liquid. Calcium hypochlorite is the dry form of chlorine which can be mixed to prepare a liquid chlorine solution. The gas form of chlorine is 2.5 times heavier than air. The effectiveness of chlorine increases as temperature increases. Conversely, longer contact duration is required to disinfect treated water at lower temperatures. Selected WSSs use gas chlorine feeding arrangements with gas detection and neutralization arrangements for safety as shown in Figures 4.8.



Figure 4.8: Conventional gas chlorination arrangement

The Omohundro and K. R. Harrington conventional surface water treatment plants that provide drinking water to metropolitan Nashville the capital of Tennessee are operating new chemical feed systems. The feed systems at both plants were designed with a single brand of peristaltic feed pumps, helping to simplify maintenance, reduce parts inventories, and make it easy for staff to move between plants without requiring additional training on the chemical feed equipment shown in Figure 4.9. Both systems were installed without interrupting either plant's operations and have enhanced energy efficiency and chemical feed accuracy.



Figure 4.9: The Omohundro plant alum feed system, showing the feed pumps, pulsation dampeners, flow meters, carrier water system, isolation valves, and pressure relief valves

Hallala and Malimbada WTPs utilize motive chlorinator booster pumps for chlorinators and chemical feeding pumps to feed Alum and PAC. Therefore, the SEC of Hallala and Malimbada WTPs are higher than the Ruhunupura and Tangalle WTPs. Hapugala WTP has the highest SEC due to the pulsator clarifier in addition to motive water pumps and chemical feeding pumps.

4.1.7 Benchmarking of energy consumption of water treatment unit processes of surface water sources

The conventional surface water treatment process consists of course screening, fine screening, aeration, chemical feeding, rapid mixing, slow mixing, sedimentation, filtration and disinfection. The SEC for individual unit processes for audited WTPs is shown in Figure 4.10. Chemical feeding is the highest energy consuming unit process in Tangalle and Hapugala WTPs and second largest in Hapugala and Hallala WTPs. Slow mixing is the largest energy consuming unit process for Hapugala WTP. For Hallala and Ruhunupura WTPs the largest energy consuming unit processes respectively are sedimentation and filtration.

The comparison of observed range of variation in SEC of these unit processes and the recommended value range by relevant references is presented in Table 4.2 and the reasons for variations are discussed below.

- **Course screening**

Generally, the course screens are cleaned manually and therefore there is no energy consumption for course screening. In all the audited WTPs, course screens did not consume any energy.

- **Fine screening**

Fine screening is available at Malimbada and Hapugala WTPs. In Hapugala WTP fine screen is cleaned manually. But in Malimbada WTP the fine screen is cleaned mechanically and the SEC is 0.0002 kWh/m³.

- **Aeration**

Cascade type aeration is available at Ruhunupura, Hapugala and Malimbada WTPs. These processes do not consume electrical energy.

- **Chemical feeding**

Chemical preparation mixers are available at all WTPs but chemical feeding pumps are available only at Hallala, Hapugala and Malimbada WTPs. At Ruhunupura and Tangalle constant head gravity chemical feeding systems are used. The SEC for chemical feeding ranges from 0.00003 kWh/m³ in Ruhunupura WTP to 0.0055 kWh/m³ in Malimbada WTP. The range of energy consumption recommended by World Environment Foundation (2009) is 0.0005 - 0.001 kWh/m³. Accordingly, Ruhunupura WTP shows a lesser SEC than the lower limit but Malimbada WTP shows a higher value than the upper limit. These variations are due to the differences in elevation and the age of the equipment and the characteristics of chemical feeding line.

- **Rapid mixing**

In all audited WTPs rapid mixing is performed using hydraulic jump. Therefore, this process does not consume electrical energy.




Figure 4.10: Specific energy consumption of water treatment unit processes in audited water supply schemes

- **Slow mixing**

In all audited WTPs slow mixing is performed using baffled flocculators except for Hapugala WTP where a pulsator is installed. Baffled flocculation is a hydraulic process and does not consume electrical energy. However, pulsator consumes a considerable amount of energy compared to the energy consumption of other unit processes. The range of energy consumption recommended by Cammerman (2009) is 0.001 - 0.004 kWh/m³. The observed value for Hapugala is 0.0082 kWh/m³ and it is higher the recommended range by Cammerman (2009).

Table 4.2: Comparison of Observed Range of Variation in Specific Energy Consumption of Water Treatment Unit Processes with Literature

| Unit Process | Observed Specific Energy Consumption Range (kWh/ m ³) x 10 ⁻³ | Specific Energy Consumption Range as per Literature (kWh/ m ³) | |
|-------------------|--------------------------------------------------------------------------------------|----------------------------------------------------------------------------|------------------------------------|
| | | (kWh/ m ³) x 10 ⁻³ | Reference |
| Fine screening | 0.2 | - | - |
| Chemical feeding | 0.03 - 5.5 | 0.5 - 1 | World Environment Foundation, 2009 |
| Rapid mixing | - | 8 - 22 | World Environment Foundation, 2009 |
| Flocculation | 8.2 | 1 - 4 | Cammerman, 2009 |
| Sedimentation | 0.6 - 4.7 | 0.5 - 1 | World Environment Foundation, 2009 |
| Filtration | 0.3 - 2.2 | 5 - 1.4 | World Environment Foundation, 2009 |
| Chlorination | 0.9 - 4.5 | 2.4 - 2.5 | Arpke and Hutzler, 2006 |
| Backwash recovery | 1 - 1.6 | - | - |

- **Sedimentation**

In all audited WTPs sedimentation is performed using plain sedimentation tanks. Sludge scrapers are installed in Hallala and Malimbada WTPs which utilize electrical energy. In other WTPs sludge is removed hydraulically. Malimbada WTP utilizes 0.0006 kWh/m³ and Hallala WTP utilizes 0.0047 kWh/m³. The range of energy consumption recommended by World Environment Foundation (2009) is 0.0005 - 0.001 kWh/m³. Accordingly, Malimbada WTP shows a lesser SEC than the lower limit but Hallala WTP shows a higher value than the upper limit. The difference in the SEC is due to the type of equipment used.

- **Filtration**

Supplying backwash air and backwash water for filter backwashing is a considerable energy consuming unit process in any WTP. The observed range of SEC is from 0.0003 kWh/m³ at Tangalle WTP to 0.0022 kWh/m³ at Ruhunupura WTP. At Tangalle WTP backwash water is obtained from the backwash water tank which is fed by the treated water pumping main which reduces the energy consumption. The

SEC is high at Ruhunupura WTP due to the higher elevation difference between filters and the clear water sump. The range of energy consumption recommended by World Environment Foundation (2009) is 0.005 – 0.014 kWh/m³. Accordingly, Tangalle WTP shows a lesser SEC than the lower limit but Ruhunupura WTP shows a higher value than the upper limit.

- **Disinfection**

Gas chlorination is the technology used for disinfection in all selected WTPs. Chlorinator booster pumps is the energy consuming component of the gas chlorination process. All the selected WTPs are installed with Chlorinator booster pumps except Tangalle WTP where motive water is supplied via a tapping from the treated water main. The observed range of SEC is from 0.0009 kWh/m³ at Ruhunupura WTP to 0.0045 kWh/m³ at Malimbada WTP. The range of energy consumption recommended by Arpke and Hutzler (2006) is 0.0024 – 0.0025 kWh/m³. Accordingly, Ruhunupura WTP shows a lesser SEC than the lower limit but Malimbada WTP shows a higher value than the upper limit. The differences in SEC mainly depends on the elevation difference of pumping which depends on the location of chlorinator house and clear water tank, the pipe characteristics and the overall energy efficiency of pumping set.

- **Backwash recovery**

The filter backwash and sedimentation sludge treatment is carried out only in Malimbada and Hapugala WTPs and the supernatant from the sludge thickener is pumped back to aerator. The SEC for pumping back the supernatant water of sludge settling tank/sludge thickener is 0.001 kWh/m³ in Hapugala WTP and 0.0016 kWh/m³ in Malimbada WTP. The difference is mainly due to the elevation difference of sludge thickener/sludge thickener and aerator.

4.1.8 Benchmarks for energy consumption in water treatment unit processes for surface water sources

The study was conducted in five water treatment plants which were utilizing technologies from basic technology to state of the art modern technology. The benchmarks for energy consumption in drinking water treatment unit processes for surface water sources context are presented in Table 4.3.

Table 4.3: Benchmarks for Energy Consumption in Drinking Water Treatment Unit Processes for Surface Water Sources

| Unit Process | Observed Specific Energy Consumption Range (kWh/ m ³) x 10 ⁻³ |
|-------------------|--------------------------------------------------------------------------------------|
| Fine screening | 0.2 |
| Chemical feeding | 0.03 - 5.5 |
| Rapid mixing | - |
| Flocculation | 8.2 |
| Sedimentation | 0.6 - 4.7 |
| Filtration | 0.3 - 2.2 |
| Chlorination | 0.9 - 4.5 |
| Backwash recovery | 1 - 1.6 |

The potentials for energy conservation in WSSs can be broadly classified in to three categories as follows:

- Potentials of energy conservation through modification of the water treatment process
- Potentials for energy conservation through improving the energy efficiency of equipment such as pumps and motors
- Potentials for energy conservation through reduction of NRW

4.1.9 Potentials of energy conservation through modification of the water treatment process

(a) Removing chlorinator booster pump of gas chlorinator at Hallala WSS

The second highest energy consuming unit process in Hallala WSS is chlorination as shown in Figure 4.10. The gas chlorination system in Hallala WSS consists of

chlorine gas cylinder, chlorinator booster pump and chlorinator as shown in Figure 4.11. The water is supplied to the chlorinator through a tapping from the inlet pipe of the clear water sump and pressurized using a booster pump. If the water supply for the chlorinator is taken from the treated water pumping main the booster pump can be removed from the system as shown in Figure 4.12.

This modification will save 0.004 kWh/m³ and 1% energy saving could be obtained for the treated water produced. The annual energy saving is about 12800 kWh/year. To use this technical option, the treated water pumping main should have a pressure head of less than 6 bars due to the maximum pressure limitations of chlorinators which is about 6 - 7 bars. This technique is already used at Tangalle WSS. This technique cannot be used at the other audited WSSs since the treated water pumping mains operates under high pressure heads. The distribution pumps in the other audited WSSs had to be operated under high pressures due to high elevation differences.




Figure 4.11: Existing chlorinator arrangement at Hallala WSS

(b) Adjusting the filter backwash frequency of Tangalle and Ruhunupura WSSs

Rapid sand filtration is the second highest energy consuming process in Tangalle and Ruhunupura WSSs as shown in Figure 4.10. The energy consumption for filtration is mainly due to the air and water requirements of the filter backwash operation. The filter backwashing frequencies of the audited WSSs are presented in Table 4.4.




Figure 4.12: Modification of chlorinator arrangement at Hallala WSS

Table 4.4: Filter Backwash Frequency of Audited Water Supply Schemes

| Water Supply Scheme | Duration between Filter Backwash | Mode of Operation |
|---------------------|----------------------------------|-------------------|
| Hallala | 48 hours | Automated |
| Ruhunupura | 24 hours | Automated |
| Hapugala | 48 hours | Automated |
| Malimbada | 48 hours | Automated |
| Tangalle | 24 hours | Automated |

The effects of running the filters for 48 hours at Hallala, Hapugala and Malimbada WTPs were investigated during the audit. The results showed that the effluent quality and the flow rate of the filters did not show a significant difference compared to 24 hour run as shown in Table 4.5.

Table 4.5: Effect on Filter Performance due to Changing of Filter Backwash Frequency

| Parameter | Duration between Filter Backwash | |
|-------------------------------|----------------------------------|-----|
| | 24h | 48h |
| Influent Turbidity (NTU) | 12 | 12 |
| Effluent Turbidity (NTU) | 1 | 1 |
| Flow Rate (m ³ /h) | 73 | 71 |

The energy saving potential of this operation modification is presented in Table 4.6 and it shows that the amount of energy saved is not significant when compared with the total energy consumption.

The water level in the feed side was increased with the increased time but it was within the height provided in the structure and the backwashing time of filter backwash operation was not adjusted so the energy consumption per one filter backwash was remained constant.

Table 4.6: Energy Saving Potential of Changing Filter Backwash Frequency

| Energy Saving Potential | Tangalle WSS | Ruhunupura WSS |
|---------------------------------------------------------------------------------------|---------------------|-----------------------|
| Total energy saving per month (kWh/month) | 92 | 126 |
| Total energy saving per year (kWh/year) | 1117 | 1530 |
| Per unit volume energy saving of treated water (Specific Energy /kWh/m ³) | 0.0003 | 0.0004 |
| Per unit volume Energy saving of treated water(%) | 0.07 | 0.06 |

(c) Energy conservation potential of backwash recovery

Backwashing filters is a must with sacrificing significant amount of treated water. Recovering of this water gives an opportunity to save energy because the recovered water has to be pumped for a lesser distance and lesser head.

The major concern in backwash water recovery is the removal of *Cryptosporidium and Giardia* which is concentrated in filter backwash waters. To meet the challenges of the stringent drinking water regulations established to improve controlling of *Cryptosporidium and Giardia*, additional physical and chemical water treatment processes are required. Pressure-driven membrane processes such as microfiltration and ultrafiltration are playing an important role in backwash water recovery (Betancourt and Rose, 2004).

The proposed arrangement for filter backwash recovery is shown in Figure 4.13 including the additional treatment process of ceramic micro filtration. The SEC for ceramic micro filtration was considered as 0.15 kWh/m³ as per Willemsse and

Brekvoort (1999). The assessment of energy saving potentials of backwash recovery is presented in Table C.2 of Appendix C.

The assessment shows that there is a 0.5% energy conservation potential at Hallala WSS through filter backwash water recovery. In other audited WTPs, recovery of filter backwash water facilitates only water conservation. If the WTP is located far away from the surface water source with large elevation difference and distance, filter backwash water recovery could be an attractive option for energy conservation. If the WTP is located near the surface water source the filter backwash water recovery is not an energy conservation potential.





Figure 4.13: Proposed process for filter backwash recovery

4.1.10 Potentials for energy conservation through improving the energy efficiency of equipment such as pumps and motors

Raw water and treated water pumping consumes more than 96% of the energy consumed by the audited WSSs as shown in Figure 4.3. The energy consumption of the pumping operation mainly depends on the overall operating efficiency of the pump and motor system. At present the minimum overall efficiency prescribed when purchasing new pumps for surface water pumping at the NWSDB is 70% at the specified operating point (NWSDB, 2013). The overall operation efficiencies of the raw water and treated water pumps in the audited WSSs are calculated in Table C.3 and Table C.4 of Appendix C and shown in Figure 4.14.

The overall efficiencies of pump and motor systems in Hapugala and Malimbada WSSs are around 70%, which is the recommended value by the NWSDB at present. The overall efficiency of pump and motor systems in pumps in Hallala WSS vary from 55 to 63%. In Ruhunupura WSS, only the treated water pumping shows acceptable overall efficiency. In Tangalle WSS all the pumps operate much below the expected overall efficiency. This is due to the age of the equipment and the unplanned modifications.

The potential energy saving from improving the overall pump and motor efficiency up to 70% is shown in Figure 4.15. Tangalle and Hallala WSSs shows comparatively high energy saving potential by improving overall efficiency since the range of efficiency improvement is higher. Although the potential for improving overall pump and motor efficiency is limited at Hapugala and Malimbada WSSs, the energy conservation potential was high since the quantity of production is larger compared to the other audited WSSs.



Note: RWPS –Raw Water Pumping Set; TWPS – Treated Water Pumping Set

Figure 4.14: Overall efficiency of pump and motor systems in audited water supply schemes




Figure 4.15: Annual energy saving potential of improving overall efficiency of pumps and motors

The percentage energy saving per unit volume of treated water is shown in Figure 4.16. Hallala and Tangalle WSSs show significant potentials of 15% and 14% reductions in the total specific energy by improving the overall efficiency of pump and motor systems.

The overall efficiency of the pump and motor system can be improved by improving the mechanical and electrical performance of equipment and modifying the characteristics of pumping main.

The mechanical and electrical performance of the pumps and motors can be improved by technical options such as overhauling of pumps and motors, trimming of impellers, installation of Variable Speed Drives, and installations of new pumps and motors. Modifications to pumping main to reduce energy losses due to pipe friction, pipe specials and throttles also contributes to improve the overall efficiency of the pump and motor system by adjusting the operating point. Implementing Planned Preventive Maintenance programs immensely helps to preserve and improve the overall energy efficiency of the pump and motor systems. The

identified potentials for improving the overall efficiency of pump and motor systems in the audited WSS are presented in Table 4.7.




Figure 4.16: Percentage energy saving potential of improving overall efficiency of pump and motor systems

Table 4.7: Identified Potentials to Improve Overall Pump and Motor Efficiency

| Water Supply Scheme | Energy Conservation Potentials |
|----------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Hapugala | Introducing a VSD to raw water pumps: The raw water pump house operates 2 duties and 1 stand by. The pumps are throttled to control the flow rate around 1500 m ³ /h. But it was observed that the pump can deliver about 1800 m ³ /h without throttling. Therefore, by introducing a VSD the energy wasted on the throttling can be saved. This energy saving could be obtained through increase of efficiency gained through shifting the pump and efficiency curves. |
| Malimbada | Introducing a VFD to raw water pumps: The LL pump house operates 1 duty and 3 stand by. The pumps are throttled to control the flow rate around 1000 - 2100 m ³ /h. But it was observed that the pump head does not change significantly with the flow rate at the current flow rates. But it was observed that the river level has an annual variation of four meters. Therefore, by introducing a VSD the energy consumption changes due to river level changes can be managed properly. The pump head in general is 34m. Therefore, around 12% reductions in pump head could be achieved. The discharge head was not measured. |
| Ruhunupura | Changing treated water pumping main: Changing the pipe stretch of the first 100m from the treatment plant reducing bends. There are about seven, 90 ⁰ bends at this pipe stretch. Therefore, there was a potential to save energy by reducing bends. |
| Tangalle | Efficiency of pumps: The pumps are about 15 years old therefore energy conservations could be obtained by improving efficiencies of the pumps by overhauling or purchasing new pumps. |

4.1.11 Energy conservation potential of reducing NRW

The highest energy consuming process of all the audited WSSs is treated water and distribution pumping with more than 70% of the total energy consumption as shown in Figure 4.3. It also shows that in Ruhunupura and Hapugala WSSs, the energy consumed in treated water and distribution pumping is more than 85%. Therefore, strict measures have to be taken to conserve the water pumped using such high

proportion of energy. Therefore, reduction of NRW has a very high potential for energy conservation in WSSs. The relevant data and calculations for assessing the energy conservation potential of reducing NRW are shown in Tables C.5 to C.8 in Appendix C and average NRW Figures for audited WSSs for year 2012 is shown in Figure 4.17. Hallala WSS was not considered for NRW analysis.




Figure 4.17: Percentage of average non-revenue water in audited water supply schemes in 2012

All the audited WSSs operate with comparatively high NRW percentages compared to cities such as Osaka with 7% as shown in Figure 2.10.

NRW mainly consists of two main categories: physical losses and commercial losses. Physical losses consist of losses due to pipe breakdowns, leakage, and service connection leakage and reservoir overflow. Commercial losses consist of losses due to incorrect water meters, illegal connections and free water.

The potential to reduce NRW is the difference between the average real losses and Economic Level of Leakage. The percentage of average real losses, ELL and potential savings for audited WSSs are shown in Figure 4.18. The possible reduction of physical losses ranges from 5% at Tangalle to 12% at Ruhunupura. Since all the audited WSSs are equipped with electronic level monitoring and communication systems the water loss through reservoir overflows is negligible. Therefore,

strategies have to be implemented to reduce the water loss through breakdowns, leakage and service connections.




Figure 4.18: Reduction potential of physical losses in audited Water Supply Schemes

The reduction potential of commercial losses through reduction of defective meters down to 1% and reduction of illegal connection up to 0.1% as per the accepted practice of NWSDB is shown in Figure 4.19. All the water supplied by the WSSs operated under NWSDB is billed and therefore the losses due to free water are negligible. The possible reduction of commercial losses ranges from 1.7% at Hapugala and Malimbada WSSs to 3.8% at Tangalle WSS as shown in Figure 4.19.




Figure 4.19: Reduction potential of commercial losses in audited Water Supply Schemes

The energy saving potential from reduction of NRW by reducing physical and commercial losses is shown in Figure 4.20. The energy saving potential of reducing NRW is significant compared to the previously discussed potentials and it varies from about 0.08 million kWh/Year at Tangalle WSS to 0.93 million kWh/Year at Malimbada WSS. This assessment was done using the data obtained from Commercial Management Information System and daily data recorded book of audit water treatment plant.




Figure 4.20: Energy conservation potential for reducing NRW

The percentage energy saving varied from 5% at Tangalle WSS to 12% at Ruhunupura WSS as shown in the Figure 4.21. Therefore, reduction of NRW shows significant energy saving potential for all the audited WSSs.




Figure 4.21: Percentage energy saving potential of reducing NRW for unit volume of treated water

The possible technical and management solutions that could be applied to achieve the above NRW reductions are presented in Table 4.8.

Table 4.8: Possible Technical and Management Solutions to Reduce NRW

| Reduction of Physical Losses | Reduction of Commercial Losses |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <ul style="list-style-type: none"> • Pressure management • Reduction of time taken to repair leaks • Using leak detection equipment to identify undetectable leakage • Using good quality pipes and fittings • Proper pipe laying at construction stage including proper fittings and thrust blocks • Covering of the service connection pipes properly | <ul style="list-style-type: none"> • Maintaining the defective meters below 1% by continuous monitoring and defective meter replacement programs • Vigilant monitoring, public campaigns and incentives to keep illegal connections below 0.01% • Using good quality and durable water meters • Auditing of billing function to reduce errors by meter readers |

4.1.12 Cost Saving from Ceylon Electricity Board Tariff Structure

The electricity tariff structure of CEB has three different charges for day time, peak time and off peak time. The day and off peak time electricity charge is lower than the peak time charge. The objective of this strategy is to promote peak clipping and the consumers can gain cost reductions by shifting the electricity consuming operations to day or off peak time. The CEB tariff structure is presented in Table 4.9 (CEB, 2015).

Table 4.9: Tariff Structure of Ceylon Electricity Board

| Tariff Category | Time Period | Charge (LKR / kWh) |
|------------------------|--------------------|---------------------------|
| Peak | 18.30 – 22.30 | 20.50 |
| Off peak | 22.30 – 05.30 | 6.85 |
| Day | 05.30 – 18.30 | 11.00 |

The analysis of potential for shifting the water treatment and pumping operations of the audited WSSs from peak time to day or off peak time is shown in Tables C.9 to C.12 of Appendix C. The analysis shows that in Tangalle and Ruhunupura WSSs the intake pumps and WTP operation can be stopped for 1.5 hours in the peak time. In Hapugala and Malimbada WSSs the intake pumps and WTP operation can be

stopped for 3 hours. The reduced production capacity due to this action has to be recovered by increasing the production during off peak period.

The potential annual cost saving from above modification to the operation schedule is presented in Figure 4.22. Possible annual cost saving ranges from LKR 0.7 million in Ruhunupura and Tangalle WSSs to LKR 2.9 million in Malimbada WSSs. The percentage cost saving in term of annual electricity is 2.7, 4.9, 3.1, and 2.9% at Ruhunupura, Hapugala, Malimbada, and Tangalle WSS, respectively. This analysis is a preliminary analysis and implementation of this strategy has to be planned considering the storage capacity and daily demand pattern.




Figure 4.22: Annual cost saving from shifting the operation from peak to off Peak

4.1.13 Comparison of identified energy conservation potentials in the audited WSSs

The effect of identified energy conservation potentials is summarized in Table 4.10. As per Table 4.10 the significant energy conservation potentials for all the audited WSSs are improving overall pump and motor efficiency and reduction of NRW with up to 14 and 12% reduction potentials respectively.

Backwash water recovery is also possible energy conservation potential where the WTP is located far away from the water intake with significant elevation difference between the source and the WTP. However, the reduction potential is not significant. Modifying the chlorinator arrangement and backwash frequency are also possible options at identified WSSs, but these methods also have less conservation potential compared to NRW reduction and pump and motor efficiency improvement. Therefore, NRW reduction and improving the overall efficiency of pump and motors are the most significant energy conservation potentials.

4.1.14 Total energy conservation and cost reduction potentials of identified options in audited water supply schemes

The cumulative effect of the identified energy conservation potentials is discussed in this section and the relevant calculations for total energy conservation analysis are attached in Table C.13 of Appendix C. The percentage total energy conservation potential in audited WSSs are shown in Figure 4.23 and it shows a variation from 7.8% in Malimbada WSS to 12% at Tangalle WSS.

Table 4.10: Comparison of the Effect of Identified Energy Conservation Potentials in Audited Water Supply Schemes

| Description | Specific Energy Saving and Percentage Energy Saving Potential | | | | | | | | | |
|---------------------------------------------|---------------------------------------------------------------|-------------|--------------------|-------------|--------------------|------------|--------------------|------------|--------------------|-----------|
| | Hallala | | Ruhunupura | | Hapugala | | Malimbada | | Tangalle | |
| | kWh/m ³ | % | kWh/m ³ | % | kWh/m ³ | % | kWh/m ³ | % | kWh/m ³ | % |
| Total Specific Energy Consumption | 0.397 | | 0.851 | | 0.766 | | 0.622 | | 0.48 | |
| Energy Saving Potentials | | | | | | | | | | |
| Removing chlorinator booster pump | 0.0038 | 1 | - | - | - | - | - | - | - | - |
| Adjusting filter backwash frequency | - | - | 0.0003 | 0.04 | - | - | - | - | - | - |
| Backwash water recovery | 0.002 | 0.5 | - | - | - | - | - | - | - | - |
| Improving overall pump and motor efficiency | 0.0624 | 15.7 | 0.0212 | 2.5 | 0.0146 | 1.9 | 0.0047 | 0.8 | 0.0684 | 14 |
| Reduction of NRW | - | - | 0.1021 | 12 | 0.0459 | 6 | 0.0435 | 7 | 0.024 | 5 |
| Total specific energy saving | 0.0682 | 17.2 | 0.1236 | 14.5 | 0.0605 | 7.9 | 0.0482 | 7.8 | 0.0924 | 19 |




Figure 4.23: Percentage of total energy conservation potential in audited water supply schemes

The major contribution for energy saving in Hallala is from improving overall efficiency of pump and motors. For Ruhunupura, Hapugala and Malimbada WSSs, the major contribution for energy saving is NRW reduction. Both NRW reduction and improving efficiency of pump and motors contribute to the highest energy conservation potential at Tangalle WSS.

Total annual energy conservation potential for audited water supply schemes varies from 0.23 million kWh at Hallala WSS to 0.74 million kWh at Malimbada WSS as shown in Figure 4.24. At Malimbada WSS the energy conservation potential was high since the quantity of production is larger compared to the other audited WSSs.




Figure 4.24: Annual total energy conversation potential for audited water supply schemes

Total annual cost reduction potential for audited water supply schemes varies from LKR 4.5 million at Ruhunupura WSS to LKR 10.4 million at Malimbada WSS as shown in Figure 4.25. The cost savings were calculated using average cost of electricity as shown in Table C.13 of Appendix C.




Figure 4.25: Annual total cost saving potential for audited water supply schemes

The potential annual cost saving for Hallala WSS is approximately LKR 2.4 million.

The effect of the identified energy conservation potentials on the annual energy cost of the water supply regions which manage the audited WSSs are shown in Figure 4.26. As per Figure 4.26, percentage cost savings vary from 5.2 to 10.1% and therefore the identified energy saving potentials can significantly improve the financial performance of the water supply regions.




Figure 4.26: Annual total cost reduction potential for water supply regions

5. CONCLUSIONS AND RECOMMENDATIONS

There were two main targets behind this study. One of the target was to achieve energy conservation potentials for drinking water supply schemes to reduce the energy consumption on water treatment and supply by conducting energy audits in selected water supply schemes in Southern Province. Second task was to benchmark the energy consumption of water treatment and supply processes. Having targeted the main objectives preliminary and detailed energy audits were continued in NWSDB schemes, Ruhunupura, Hapugala, Malimbada, Tangalle and Hallala WSS. Based on the outcome of the study, target was further carried out for benchmarking for individual unit processes of water treatment. The potentials for energy conservation identified at the preliminary audit were investigated in depth at the detailed audits.

5.1 Conclusion

The following conclusions can be drawn based on the study:

- Specific energy consumption for water supply schemes in low land areas in Sri Lanka similar to Southern Province behave around 0.3 kWh/m³
- Operation and maintenance cost is the highest cost component in drinking water treatment procedure and as a percentage from total cost, that amount is 25% and it is unavoidable for a given situation.
- Not less than 70% from entire energy consumed for drinking water process is paid out for distribution process. It's in the range of 71.6 to 85.4 %.
- Treatment process of raw water has a big energy impact when it is compared with surface water treatment where energy consumption for surface water treatment is as less as 3 % compared to energy consumption for raw water distribution and pumping for treatments.
- More attention is vigilant to draw on handling raw water treatments for their saving component is bigger compared to surface water treatment.

- Specific energy consumption figures for raw water pumping for studied schemes: 0.095 – 0.267 kWh/m³, 0.004 – 0.008 kWh/m³/m lift, 0.003 -0.033 kWh/m³/m lift/ km
- Specific energy consumption for distribution pumping for studied WSSs: 0.117 – 0.724 kWh/m³, 0.004 – 0.006 kWh/m³/m lift, 0.001 – 0.005 kWh/m³/m lift/ km
- Specific energy consumption for surface water treatment: 0.003 kWh/m³ to 0.0047 kWh/m³
- Created benchmarks for energy consumption of drinking water treatment unit processes for surface raw water sources:
 - Screening : 0.0002 kWh/m³
 - Chemical feeding : 0.0027 - 0.0044 kWh/m³
 - Slow mixing : 0.0082 kWh/m³
 - Sedimentation : 0.005 kWh/m³
 - Filtration : 0.0005 – 0.0022 kWh/m³
 - Chlorination : 0.0009 -0.0045 kWh/m³
 - Backwash recovery : 0.001 -0.0016 kWh/m³
- Chlorinator booster pumps consume energy 1% of the total energy and supporting utility could be obtained for schemes with distribution lesser than 60m
- Backwashing frequency reduces energy consumption by 0.06% and applicable to time durations between backwashing less than 48 hours.
- As large as 1% to 14% energy conservation potentials are possible with overall efficiency of the pumping unit in 70% s
- NRW hides an energy conservation potential in a range of 5% to 12%.

5.2 Recommendations and proposals

Further research and improvement proposals;

- Studying for water source improvement with keeping them free from algae, impurities, pollution and contamination through community awareness,

national policy planning and programmed long term vision is worth to focus in several ways not only to meet huge energy conservation in future but also to harvesting healthy generation out in danger with numerous diseases

- Direct pumping system of treated water by eliminating distribution through elevated towers is better option to focus to save energy in vigorous amounts yet not ready to be implemented with prevailing electricity pattern in the country
- Further expansion of this type of investigations with similar countries in Asia for improvement of benchmarks in energy conservation concept
- Explore the study towards electricity usage patterns with CEB tariff structure so as to look for better possibilities to improve national power utility while saving power and equipment
- Explore the study aiming world latest technology on modern industrial pumping equipment towards improved usage of VFD, improved impeller profiles, materials and textures, frictionless motion technics, case-wise equipment design, efficient power transmission technics and material etc.
- Expand the study for better possibilities for reduction of energy loss in transmission due to friction through selection of improved materials, surface textures and profiles, associate pipe specials, flow velocities and system curves
- Further expansion of the study on monitoring for production and usage treated water quantities and to work out on areas and occasions losses occur and to implement master plan on elimination of the opportunities for the losses due to leaks or otherwise
- Expand the study towards standardizing water usage with purification level and possibilities to educate population to re-usage of water depending upon the degree of clarity of water for gardening, washing etc.

References

ADB. (2004). *Water Utilities Data Book: Asian and Pacific Region*. Manila: Asian Development Bank. ISBN 978-9-715-611-251.

Alliance to save Energy. (2005). *Energy Audit Guidebook for Water Utilities in the Philippines*. Manila: Alliance to save Energy.

Anusart, K. (2012). *Water - energy nexus: an application to the Bangkok water supply system, Thailand*. (Masters Thesis No. WM. 12-16, Asian Institute of Technology 2012). Bangkok: Asian Institute of Technology.

Arpke, A., & Hutzler, N. (2006). Domestic water use in United States. *Industrial Ecology*, 10, 169-184.

AWWA. (1998). Report of AWWA Leak Detection and Accountability Committee. *Journal of American Water Works Association*, 108-111.

Babel, M. S., Aldrin A. R., Seetharam K. (2010). Municipal Water Supply Management in Bangkok: Achievements and Lessons, *International Journal of Water Resources Development*, Vol. 26 (2), pages 193-217.

Betancourt, W. Q., & Rose, J. B. (2004). Drinking water treatment processes for removal of *Cryptosporidium* and *Giardia*. *Veterinary Parasitology*, 126, 219 -234.

Binnie, C., Kimber, M., & Smethurst, G. (2002). *Basic Water Treatment* (3rd ed.). London: Thomas Telford. ISBN 0-8540-4989-4

Bogan, C. E., & Michael, J. (1994). *Benchmarking for Best Practices: Winning through Innovative Adaptation*. New York: McGraw-Hill. ISBN 0-0700-6375-3.

BOI. (2013). Retrieved March 31, 2013, from Board of Investments Sri Lanka Website: http://www.investsrilanka.com/pdf/environmental_norms.pdf.

Bunn, S. M., & Reynolds, L. (2009). The energy efficiency benefits of pump scheduling optimisation for potable water supplies. *IBM Journal of Research and Development*, 53 (3), 1-5.

Cammerman, N. (2010). *Urban Water Security Research Alliance Technical Report No. 39*. Queensland: The University of Queensland.

Camp, R. C. (2006). *Benchmarking: The Search for Industry Best Practices that Lead to Superior Performance*. Milwaukee: ASQC Quality Press. ISBN 1-5632-7532-7.

CEB. (2013). *Demand Side Management*. Retrieved April 7, 2013, from Ceylon Electricity Board Website: <http://www.ceb.lk/sub/knowledge/demandside.html>.

CEB. (2013). Home page. Retrieved April 7, 2013, from Ceylon Electricity Board Website: <http://www.ceb.lk>.

Chang, C. L. (2002). Study of the interrelationship between water use and energy conservation for a building. *Energy and buildings*, 34, 261-266.

Cohen, R., Nelson, B., & Woff, G. (2004). *Energy down the drain: The hidden costs of California's water supply*. Oakland: Natural Resources Defence Council.

Cornwell, D. A., Macaphee, M. J., & Brown, R. A. (2003). Demonstrating *Cryptosporidium* removal using spore monitoring at lime-softening plants. *J. AWWA*, 95, 125-133.

Edzwald, J. K., & Kelley, M. B. (1998). Control of *Cryptosporidium*: from reservoirs to clarifiers to filters. *Water Science and Technology*, 37, 1-8.

EGAT. (2013). Economic and Electricity Overview. Retrieved April 7, 2013, from Electricity Generating Authority of Thailand Website: http://www.egat.co.th/images/stories/annual/reports/2554/annual2011_eng_p18.pdf.

Elliott, T., Zeier, B., Xagorarakis, I., & Harrington, G. W. (2003). *Energy Use of Wisconsin's Drinking Water Facilities*. Madison: Energy Center of Wisconsin. Report 222-1.

EPRI. (1994). *Energy Audit Manual for Water/Waste Water Facilities*. Washington: Electrical Power Research Institute. Report CR-104300.

Fox, K. R. (2006). Water quality in source water, treatment, and distribution systems. In *Manual of water supply and Practices: AWWA M 48 Water Borne Pathogens* (2nd ed.). Denver: American Water Works Association. ISBN 1-5832-1403-8.

Frauentorfer, R., and Liemberger, R. (2010). *The issues and challenges of reducing non-revenue water*. Manila: Asian Development Bank. ISBN 978-92-9092-398-5.

Gao, B. Y., Hahn, H. H., & Hoffman, E. (2002). Evaluation of Aluminium Silicate polymer composite as a coagulant for water treatment. *Water Research*, 36, 3573 - 3581.

Geldreich, E. E. (1996). *Microbial Quality of Water Supply in Distribution Systems*. Boca Raton: CRC Press. ISBN 1-5667-0194-5.

IWA. (2000). IWA Blue Pages. Retrieved December 24, 2012, from International Water Association Website: http://www.iwahq.org/content/suite/upload/iwa/Document/Losses_from_Water_Supply_Systems_2000.pdf.

James, K., Campbell, S. L., & Godlove, C. E. (2002). *Watergy: Taking Advantages of Untrapped Energy and Water Efficiency Opportunities in Municipal Water Systems*. Washington: Alliance to Save Energy.

Jantzen, J. (2009). National dialogue on financing strategy for urban and rural water supply and sanitation in Georgia. Georgia: Organisation of Economic Corporation and Development.

Jeppsson, U., Rosen, C., Alex, J., Copp, J., Gernaey, K. V., Pons, M. N., et al. (2006). Towards a benchmark simulation model for plant-wide control strategy performance evaluation of WWTPs. *Water Science and Technology*, 35, 287-295.

Kalaimathie, S. N. (2012). Investigation on ceramic membrane based filter backwash water recycling and energy conservation potential for water treatment plants . (Masters Thesis No. EV-12-18, Asian Institute of Technology, 2012). Bangkok: Asian Institute of technology.

Karlof, B., & Ostblom, S. (1993). *Benchmarking: A Signpost to Excellence in Quality and Productivity*. New York: Wiley. ISBN 978- 0-471-941-804.

Kenway, S. J., Priestley, S., Cook, S., Seo, S., Inman, M., Gregory, and Hall, M., (2008). *Energy use in the provision and consumption of urban water in Australia and New Zealand*. Sydney: CSIRO. ISBN 978-0-643-096-165.

McNair, J., & Leibfried, K. J. (1995). *Benchmarking: A Tool for Continuous Improvement*. New York: Harper Business Press. ISBN 978-0-471-132-066.

Mo, W., Zhang, Q., Mihelsic, J. R., & Hokanson, D. R. (2011). Embodied energy comparison of surface water ground water supply options. *Water Research*, 45(17), 5577-5586.

Monthakanthi, N. (2012). Influence of dissolved organic matter in ceramic membrane filtration performance in drinking water treatment. (Masters Thesis No EV-11-08, Asian Institute of Technology, 2012). Bangkok: Asian Institute of Technology.

Munoz, I., Mila, I. C., & Fernandez-Alba, A. R. (2010). Life cycle assessment of water supply plants in mediterranean Spain. *Journal of Industrial Ecology*, 14, 902-918.

National Water Supply & Drainage Board. (2012). History of National Water Supply and Drainage Board. Retrieved 08 18, 2012, from National Water Supply & Drainage Board Website: www.waterboard.lk.

NWSDB. (2013). History of National Water Supply and Drainage Board. Retrieved 03 20, 2013, from National Water Supply & Drainage Board Website: www.waterboard.lk.

NWSDB. (2013). Specifications for water pumping sets and accessories. Retrieved April 16, 2013, from National Water supply and Drainage Board Website: http://www.waterboard.lk/scripts/ASP/Documentation_Section.asp.

- Olson, B. E., Olson, M. E., & Wallis, P. M. (2002). *Giardia: the cosmopolitan parasite*. Wellingford: CABI Publishing. ISBN 0-8519-9612-4
- Parena, R., & Smeets, E. (2001). Benchmarking initiatives in the water industry. *Water Science and Technology*, 44, 103-110.
- Pearson, D., & Trow, S. W. (2005). Calculating the Economic Levels of Leakage. In *Leakage 2005 Conference Proceedings*.
- Peeters, J. E., Masschelein, W. J., & Maturana, I. V. (1989). Effect of disinfection of drinking water with ozone or chlorine dioxide on survival of *Cryptosporidium* oocysts. *J Applied Environmental Microbiology*, 55, 1519-1522.
- Plappaly, A. K., & Lienhard, V. J. (2012). Energy requirements for water production, treatment, end use, reclamation and disposal. *Journal of Renewable and Sustainable Energy Reviews*, 16, 4818 - 4868.
- Racoviceanu, A. I., Karney, B. W., Kennedy, C. A., & Colombo, A. F. (2007). Life cycle energy use and greenhouse gas emissions inventory for water treatment systems. *Journal of Infrastructure Systems*, 13, 261-270.
- Rothausen, S. G., & Conway, D. (2011). Greenhouse Gas Emissions from Energy Use in Water Sector. *Nature Climate Change*, 1, 210-219.
- Stapenhurst, T. (2009). *The Benchmarking Book: A How to Guide to Best Practices for Managers and Practitioners*. London: Taylor and Francis. ISBN 978-0-750-689-052
- Stokes, J., & Horvarth, A. (2009). Energy and air emission effects in water supply. *Environmental Technology and Science*, 43 (8), 2680-2687.
- Stowa. (2013). Microfiltration. Retrieved April 30, 2013, from Dutch Foundation for Water Research Web Site: <http://www.stowa-selectedtechnologies.nl/Sheets/Sheets/Microfiltration.html>.
- Troyan, J. J., & Hansen, S. P. (1989). *Treatment of Microbial Contaminants in Potable Water Supplies: Technologies and Costs*. New Jersey: Noyes Data Corporation. ISBN 0-8155-1214-7
- Venetucci, R. (1992). Benchmarking: a reality check for strategy and performance objectives. *Production and Inventory Management*, 33, 32-36.
- Venkatesh, G., & Brattebo, H. (2011). Energy consumption, costs and environmental impacts for urban water cycle services: Case study of Oslo (Norway). *Energy*, 36, 792-800.

Water Environment Foundation. (2009). Energy Conservation in of Water and Wastewater Facilities. New York: McGraw Hill. ISBN 978-0-071-667-944.

WEPA. (2013). Retrieved March 31, 2013, from Water Environment Partnership of Asia: http://www.wepa-db.net/policies/law/thailand/std_drinking.htm.

WHO. (2011). Guidelines for Drinking Water Quality (3rd ed.). Geneva: World Health Organisation.

Willemsse, R. J. N., & Brekvoort, Y. (1999). Full-scale recycling of backwash water from sand filters using dead-end membrane filtration. *Water Research*, 33 (15), 3379-3385.

Appendix A

Data on Selected Water Supply Schemes and Overall Energy Cost of Drinking Water Supply

Table A.1: Comparison of Drinking Water Quality Standards

| Parameter | Sri Lanka Standard 614: Part 1 and Part 2: 1983 | | WHO guideline:2008 |
|--------------------------|-------------------------------------------------|-------------------|--------------------|
| | Maximum acceptable | Maximum allowable | |
| Bacteriological | | | |
| Coliform (MPN/100ml) | 3 | 3 | Not specified |
| E Coli (MPN/100ml) | 0 | 0 | 0 |
| Physical | | | |
| Colour | 5 Hz | 30 Hz | 15 Pt-Co |
| Taste | Non objectionable | Non objectionable | Non objectionable |
| Odour | Non objectionable | Non objectionable | Non objectionable |
| Turbidity | 2 NTU | 8 NTU | 5 NTU |
| Chemical | | | |
| pH | 7.0 - 8.5 | 6.5- 9.5 | 6.5 - 8.5 |
| Electrical conductivity | 750 μ S/cm | 3500 μ S/cm | 250 mS/cm |
| Chloride (mg/L) | 200 | 1200 | 250 |
| Total Alkalinity (mg/L) | 200 | 400 | Not specified |
| Nitrate (mg/L) | 10 | 10 | 50 |
| Nitrite (mg/L) | 0.01 | 0.01 | 0.5 |
| Total Phosphate (mg/L) | 2 | 2 | Not specified |
| Total Hardness(mg/L) | 250 | 600 | 500 |
| Calcium (mg/L) | 100 | 240 | Not specified |
| Total Iron (mg/L) | 0.3 | 1 | 0.3 |
| Sulphate (mg/L) | 200 | 400 | 500 |
| Aluminium (mg/L) | 0.2 | | 0.2 |
| Fluoride (mg/L) | 0.6 | 1.5 | 1.5 |
| Residual Chlorine (mg/L) | 0.2 | 1 | 5 |




Figure A.1: Schematic diagram of Hallala water supply scheme




Figure A.2: Schematic diagram of Ruhunupura water supply scheme




Figure A.3: Schematic diagram of Hapugala water supply scheme




Figure A.4: Schematic diagram of Malimbada water supply scheme




Figure A.5: Schematic diagram of Tangalle water supply scheme

Table A.2 Operation Cost Breakdown of National Water Supply and Drainage Board in 2012

| Operation Cost Category | Cost (LKR x 10⁶) | Percentage Cost (%) |
|--------------------------------|------------------------------------|----------------------------|
| Personnel | 6465 | 53 |
| Electricity | 2891 | 24 |
| Chemical | 501 | 4 |
| Repair & Maintenance | 835 | 7 |
| Establishment | 797 | 7 |
| Security and Finance | 689 | 6 |

Table A.3: Operation Cost Breakdown of Selected Water Supply Regions

| Operation Cost Category | Operation Cost and Percentage | | | | | |
|----------------------------|-------------------------------|----|-----------------------|----|-----------------------|----|
| | Galle Region | | Matara Region | | Hambantota Region | |
| | LKR x 10 ⁶ | % | LKR x 10 ⁶ | % | LKR x 10 ⁶ | % |
| Personnel | 222 | 46 | 189 | 34 | 155 | 43 |
| Electricity | 94 | 19 | 201 | 37 | 91 | 25 |
| Chemical | 118 | 2 | 18 | 3 | 63 | 17 |
| Repair & Maintenance | 96 | 20 | 83 | 15 | 19 | 5 |
| Establishment | 23 | 5 | 19 | 3 | 11 | 3 |
| Security and Finance | 40 | 8 | 39 | 7 | 25 | 7 |

Appendix B

Preliminary Audit Data and Benchmarking Calculations

Audit Duration – From: 09.00 on 15 Dec 2015 **To:** 09.00 on 16 Dec 2015

Table B.1: Flow Meter Readings of Hallala Water Supply Scheme

| Description | Flow meter reading (m ³) | Volume (m ³) |
|----------------------------------|--------------------------------------|--------------------------|
| Raw water flow meters | | |
| Start | 654897 | 9680 |
| End | 664577 | |
| Backwash flow meters | | |
| Start | 87650 | 125 |
| End | 87775 | |
| Treated water flow meters | | |
| Start | 765489 | 9655 |
| End | 775144 | |

Audit Duration – From: 09.00 on 4 Jan 2016 **To:** 09.00. on 5 Jan 2016

Table B.2: Flow Meter Readings of Ruhunupura Water Supply Scheme

| Description | Flow meter reading (m ³) | Volume (m ³) |
|----------------------------------|--------------------------------------|--------------------------|
| Raw water flow meters | | |
| Start | 205681 | 8030 |
| End | 213711 | |
| Backwash flow meters | | |
| Start | 246908 | 201 |
| End | 247109 | |
| Treated water flow meters | | |
| Start | 987546 | 8250 |
| End | 995796 | |

Audit Duration- From: 07.00 on 7 Jan 2016 To: 07.00 on 8 Jan 2016

Table B.3: Flow Meter Readings of Hapugala Water Supply Scheme

| Description | Flow meter reading (m³) | Volume (m³) |
|----------------------------------|-------------------------------------------|-------------------------------|
| Raw water flow meters | | |
| Start | 976762 | 18100 |
| End | 994862 | |
| Backwash flow meters | | |
| Start | 14586 | 225 |
| End | 14811 | |
| Treated water flow meters | | |
| 1 - Start | 765908 | 3218 |
| 1 - End | 769126 | |
| 2 - Start | 564378 | 5128 |
| 2 - End | 569506 | |
| 3 - Start | 345097 | 754 |
| 3 - End | 345851 | |
| 4 - Start | 456985 | 5668 |
| 4 - End | 462653 | |
| 5 - Start | 765298 | 3000 |
| 5 - End | 768298 | |

Audit Duration – From: 07.00 on 16 Jan 2016 **To:** 07.00 on 17 Jan 2016

Table B.4: Flow Meter Readings of Malimbada Water Supply Scheme

| Description | Flow meter reading (m³) | Volume (m³) |
|----------------------------------|-------------------------------------------|-------------------------------|
| Raw water flow meters | | |
| Start | 408267 | 36570 |
| End | 444837 | |
| Backwash flow meters | | |
| Start | 34768 | 450 |
| End | 35218 | |
| Treated water flow meters | | |
| 1 - Start | 134598 | 15555 |
| 1 - End | 150153 | |
| 2 - Start | 986356 | 3257 |
| 2 - End | 989613 | |
| 3 - Start | 234987 | 12145 |
| 3 - End | 247132 | |
| 4 - Start | 76580 | 5050 |
| 4 - End | 81630 | |

Audit Duration – From: 09.00 on 19 Jan 2016 **To:** 09.00 on 20 Jan 2016

Table B.5: Flow Meter Readings of Tangalle Water Supply Scheme

| Description | Flow meter reading (m³) | Volume (m³) |
|----------------------------------|-------------------------------------------|-------------------------------|
| Raw water flow meters | | |
| Raw water pumping main 1- Start | 125768 | 3480 |
| Raw water pumping main 1- End | 129248 | |
| Raw water pumping main 2- Start | 876908 | 4080 |
| Raw water pumping main 2- End | 880988 | |
| Raw water pumping main 3- Start | 234785 | 3072 |
| Raw water pumping main 3- End | 237857 | |
| Backwash flow meters | | |
| Start | 36340 | 136 |
| End | 36476 | |
| Treated water flow meters | | |
| Pumping main 1- Start | 380264 | 5280 |
| Pumping main 1- End | 385544 | |
| Pumping main 2- Start | 114029 | 4320 |
| Pumping main 2- End | 118349 | |
| Pumping main 1- Start | 80954 | 864 |
| Pumping main 2- End | 81818 | |

Table B.7: Electricity Consumption of Audited Water Supply Schemes

| Description | Consumption (kWh/m³) | Remarks |
|---------------------------------------|--------------------------------------------|------------------------------------------------------|
| Hallala Water Supply Scheme | | |
| Intake pump house | 2587 | From 09.00 on 15 Dec 2015 To 09.00 on 16 Dec 2015 |
| Water treatment plant | 1270 | |
| Ruhunupura Water Supply Scheme | | |
| Intake pump house | 1009 | From 09.00 on 04 Jan 2016 To 09.00 on 05 Jan 2016 |
| Water treatment plant | 4767 | |
| Hapugala Water Supply Scheme | | |
| Intake and water treatment plant | 10785 | From 09.00 on 07 Jan 2016 To 09.00 on 08 Jan 2016 |
| Malimbada Water Supply Scheme | | |
| Intake pump house | 5290 | From 09.00 on 16 Jan 2016 To 09.00 on 17 Jan 2016 |
| Water treatment plant | 16308 | |
| Tangalle Water Supply Scheme | | |
| Intake pump house | 1407 | From 09.00 on 19 Jan 2016 To 09.00 on 20 Jan 2016 |
| Water treatment plant | 2946 | |

Table B.7: Rated Electrical Energy Related Parameters, Pump Heads and Flow Rates of Equipment in Hallala Water Supply Scheme

| Unit Process | Equipment | Brand/Model | Rated Parameters | | | | |
|----------------------|---------------------------|-------------|------------------|-------------|-------------|----------|--------------------------|
| | | | Power (kW) | Voltage (V) | Current (A) | Head (m) | Flow (m ³ /h) |
| Raw water pumping | Raw water pumps set 1 | KSB | 110 | 380 | 199 | 55 | 420 |
| | Raw water pumps set 2 | KSB | 55 | 380 | 98 | 45 | 220 |
| Chemical feeding | PAC Mixer | FLNDER | 1.5 | 380 | 3.1 | - | - |
| | PAC booster pumps | Milton Roy | 0.25 | 380 | 0.83 | | 0.4 |
| | Air Compressor* | GSD | 5.5 | 380 | 11.6 | - | - |
| Rapid mixing | Hydraulic jump | - | - | - | - | - | - |
| Slow mixing | Baffled flocculator | - | - | - | - | - | - |
| Sedimentation | Sludge scraper | Pala Drive | 0.75 | 380 | 1.7 | - | - |
| Filtration | Back wash Air Blower | KFM | 30 | 380 | 56.5 | - | - |
| | Back wash Tank Pumping | KSB | 55 | 380 | 102 | 28 | 400 |
| Disinfection | Booster Pumps | KSB | 1.5 | 380 | 3.74 | 54 | 5 |
| Distribution pumping | Treated water pumps set 1 | KSB | 55 | 380 | 102 | 28 | 400 |
| | Treated water pumps set 2 | KSB | 22 | 380 | 41 | 25 | 280 |

Note *: Air compressor is used to clean chemical tanks

Audit Duration From: 09.00 on 15 Dec 2015 **To:** 09.00 on 16 Dec 2015

Table B.8: Measured Electrical Energy Related Parameters, Pump Heads and Flow Rates of Equipment in Hallala Water Supply Scheme

| Unit Process | Equipment | Measured Parameters | | | | | Operation Schedule |
|----------------------|---------------------------|---------------------|-------------|----------|--------------------------|--------------|--------------------------------|
| | | Voltage (V) | Current (A) | Head (m) | Flow (m ³ /h) | Power factor | |
| Raw water pumping | Raw Water Pump set 1 | 390 | 180 | 54 | 420 | 0.85 | 1 duty, 1 standby, 22 h |
| | Raw Water Pump set 2 | 390 | 82 | 43 | 220 | 0.85 | 1 duty, 1 standby, 2 h |
| Chemical feeding | PAC Mixer | 390 | 2.16 | – | – | 0.85 | 1 duty, 1 standby, 24 h |
| | PAC Booster Pumps | 390 | 0.75 | 8.4 | 0.4 | 0.85 | 1 duty, 1 standby, 24 h |
| | Air Compressure | 390 | 11.18 | – | – | 0.85 | 1 duty, 1 standby, 6 min |
| Sedimentation | Sludge scraper | 390 | 1.63 | – | – | 0.85 | 2 duty, 24 h |
| Filtration | Back wash Air Blower | 390 | 52 | – | – | 0.85 | 1 duty, 1 standby, 10 min |
| | Back wash water from tank | – | – | – | – | | – |
| Disinfection | Booster Pumps | 390 | 2.67 | 30 | 4.2 | 0.85 | 1 duty, 1 standby, 24 h |
| Distribution pumping | Treated Water Pump set 1 | 390 | 87 | 24 | 420 | 0.85 | 1 duty, 1 standby, 21 h 30 min |
| | Treated Water Pump set 2 | 390 | 38 | 19.8 | 250 | 0.85 | 1 duty, 1 standby, 2 h 30 min |

Table B.9: Rated Electrical Energy Related Parameters, Pump Heads and Flow Rates of Equipment in Ruhunupura Water Supply Scheme

| Unit process | Equipment | Brand | Rated Parameters | | | | | |
|-------------------------|------------------------------|----------|------------------|---------------|----------------|----------------|------|-------------|
| | | | Motor/ Pump | Power (kW) | Voltage (V) | Current (A) | PF | Head (m) |
| Raw water pumping | Raw water pumps | KSB | 45 | 400 | 80 | – | – | – |
| Chemical Mixing | Alum mixer | Primo | 0.75 | 415 | 3.4 | – | – | – |
| | Constant head gravity feeder | – | – | – | – | – | – | – |
| | Feed water pump for mixer | Rotoflex | 1.5 | 398 | 1.5 | – | – | – |
| Rapid mixing | Hydraulic jump | – | – | – | – | – | – | – |
| Slow mixing | Baffled flocculator | – | – | – | – | – | – | – |
| Sedimentation | Sedimentation tanks | – | – | – | – | – | – | – |
| Filtration | Back wash air blower | Hico | 30 | 400 | 59 | 0.8 | – | – |
| | Back wash pump | Paco | 75 | 400 | 132 | 0.85 | 22 | 774 |
| Disinfection | Chlorination Booster Pump | Grundfos | 0.37 | 400 | 0.8 | 0.80 | 37.6 | 1.8 |
| Distribution pumping | Batampara | Grundfos | 250 | 400 | 420 | 0.85 | 155 | 285 |
| Sludge treatment | Sludge thickener | – | – | – | – | – | – | – |
| | Sludge drying beds | – | – | – | – | – | – | – |

Audit Duration – From: 09.00 on 4 Jan 2016 **To:** 09.00 on 5 Jan 2016

Table B.10: Measured Electrical Energy Related Parameters, Pump Heads and Flow Rates of Equipment in Ruhunupura Water Supply Scheme

| Unit process | Equipment | Measured Parameters | | | | | | Operation Schedule |
|----------------------|------------------------------|---------------------|-------------|-------------|------|----------|--------------------------|---------------------------|
| | | Power (kW) | Voltage (V) | Current (A) | PF | Head (m) | Flow (m ³ /h) | |
| Raw water pumping | Raw water pumps | – | 400 | 78 | 0.85 | 28 | 375 | 1 duty, 2 standby , 22 h |
| Chemical Mixing | Alum mixer | – | 408 | 3.3 | 0.82 | – | – | 1 duty, 1 standby, 4 min |
| | Constant head gravity feeder | – | – | – | – | – | – | – |
| | Feed water pump for mixer | – | 405 | 1.5 | 0.85 | – | – | 1 duty, 1 standby , 9 min |
| Filtration | Back wash air blower | – | 411 | 57 | 0.8 | – | – | 1 duty, 1 standby 6 min |
| | Back wash pump | – | 410 | 110 | 0.85 | 18 | 861 | 1 duty, 1 standby, 14 min |
| Disinfection | Chlorination Booster Pump | – | 400 | 0.6 | 0.8 | 38 | – | 1 duty, 1 standby 24 h |
| Distribution pumping | Intake | – | 400 | 400 | 0.85 | 163 | 365 | 1 duty, 2 standby , 22h |

Table B.11: Rated Electrical Energy Related Parameters, Pump Heads and Flow Rates of Equipment in Hapugala Water Supply Scheme

| Unit process | Equipment | Brand | Rated Parameters | | | | | |
|----------------------|----------------------------------------|------------------|------------------|-------------|-------------|------|----------|--------------------------|
| | | Motor/Pump | Power/(kW) | Voltage/(V) | Current/(A) | PF | Head/(m) | Flow/(m ³ /h) |
| Raw water pumping | Raw water pumps | Grundfos | 70 | 400 | 134 | – | 39 | 400 |
| Chemical feeding | PAC Booster Pumps | ProMinent | 0.75 | 415 | 2 | – | 50 | 0.79 |
| | Lime Booster Pump | Seepex | 0.75 | 400 | 2 | 0.76 | – | – |
| | Agitators | Crompton Greaves | 2.2 | 415 | 4.5 | – | – | – |
| Rapid mixing | Hydraulic jump | – | – | – | – | – | – | – |
| Pulsator/Slow mixing | Pulsator vacuum pump | Alstom | 5.5 | 415 | 10.4 | 0.83 | – | – |
| Sedimentation | – | – | – | – | – | – | – | – |
| Filtration | Back wash air blower | ABB | 30 | 415 | 55 | 0.81 | – | – |
| | Back wash air compressor | ABB | 4 | 415 | 6 | – | – | – |
| | Back wash pump | Grundfos | 7.5 | 415 | 16.2 | 0.8 | 100 | 240 |
| Disinfection | Chlorinator booster pump | Grundfos | 2.2 | 415 | 8.5 | 0.89 | 75 | 5.8 |
| Distribution pumping | Pump 1 | Grundfos | 110 | 415 | 190 | 0.87 | 92 | 279 |
| | Pump 2 | Grundfos | 150 | 415 | 290 | 0.89 | 130 | 274 |
| | Pump 3 | Grundfos | 55 | 415 | 56.2 | 0.84 | 90 | 108 |
| | Pump 4 | Grundfos | 220 | 415 | 357 | – | 105 | 417 |
| | Pump 5 | Grundfos | 150 | 415 | 275 | 0.89 | 118 | 255 |
| Sludge treatment | Settling Tank to Sludge Pit Pump | Grundfos | 1.5 | 415 | 3.8 | – | 17 | 19.5 |
| | Sludge pit to Sludge Thickener Pump | Grundfos | 3.8 | 415 | 6.5 | – | 26.9 | 80 |
| | Settling Tank to Aerator Pump | Grundfos | 4 | 415 | 10.2 | – | 16.9 | 135 |
| | Sludge Thickener to Sludge Lagoon Pump | Motovario | 3 | 415 | 6.9 | – | – | 7 |

Audit Duration – Audit Duration- From: 07.00 on 7 Jan 2016 To: 07.00 on 8 Jan 2016

Table B.12: Measured Electrical Energy Related Parameters, Pump Heads and Flow Rates of Equipment in Hapugala Water Supply Scheme

| Unit process | Equipment | Measured Parameters | | | | | | Operation Schedule |
|----------------------|-------------------------------|---------------------|-------------|-------------|--------------|----------|--------------------------|--------------------------------|
| | | Power (kW) | Voltage (V) | Current (A) | Power Factor | Head (m) | Flow (m ³ /h) | |
| Raw water pumping | Intake pumps | 69 | 406 | 125 | 0.79 | 23 | 1495 | 2 duty, 1 standby , 12 h 6 min |
| Chemical feeding | PAC booster Pump | - | 405 | 0.7 | 0.86 | - | - | 1 duty, 1 standby, 12 h 6 min |
| | Lime booster Pump | - | 409 | 1.1 | 0.82 | - | - | 1 duty, 1 standby ,12 h 6 min |
| | Agitator | - | 408 | 4.2 | 0.83 | - | - | 2 duty ,2 standby, 12 h 6 min |
| Slow mixing | Pulsator vacuum pump | - | 407 | 9.8 | 0.87 | - | - | 2 duty, 2 standby 12 h 6 min |
| Filtration | Back wash air blower | - | 406 | 52.6 | 0.87 | - | - | 1 duty, 1 standby , 9 min |
| | Back wash air compressor | - | 405 | 5.4 | 0.88 | - | - | 1 duty 1 standby 10 min |
| | Back wash pumps | - | 408 | 15.7 | 0.83 | - | - | 1 duty 1 standby 24 min |
| Chlorination | Chlorination booster pump | - | 409 | 8.2 | 0.87 | - | - | 1 duty 2 standby,12 h 6 min |
| Distribution pumping | Pump 1 | 100.8 | 407 | 168 | 0.86 | 93 | 271 | 1 duty 1 standby ,11 h 54 min |
| | Pump 2 | 155.8 | 400 | 245 | 0.87 | 128 | 285 | 1 duty 1 standby , 18 h |
| | Pump 3 | 42.3 | 400 | 72 | 0.88 | 94 | 98 | 1 duty 1 standby , 7 h 42 min |
| | Pump 4 | 168.5 | 405 | 278 | 0.83 | 100 | 405 | 1 duty 1 standby , 14 h |
| | Pump 5 | 125.8 | 408 | 214 | 0.86 | 112 | 244 | 1 duty 1 standby , 12 h 18min |
| Sludge treatment | Settling tank to sludge pit | - | 406 | 3.7 | 0.86 | - | - | 1duty 1 standby, 1 h |
| | Sludge pit to thickener pump | - | 409 | 6.5 | 0.85 | - | - | 1 duty 1 standby 1 h |
| | Settling tank to aerator pump | - | 407 | 9.9 | 0.83 | - | - | 1 duty 1 standby 9 h |
| | Thickener to sludge lagoon | - | 405 | 6.7 | 0.82 | - | - | 1 duty 1 standby 30 min |

Table B.13: Rated Electrical Energy Related Parameters, Pump Heads and Flow Rates of Equipment in Malimbada Water Supply Scheme

| Unit process | Equipment | Brand | Rated Parameters | | | | | |
|----------------------|---------------------------|----------------|------------------|------------|-------------|-------------|--------------|----------|
| | | | Pump/Motor | Power (kW) | Voltage (V) | Current (A) | Power Factor | Head (m) |
| Screening | Course screen (50mm) | - | - | - | - | - | - | - |
| | Fine screen (10mm) | Toshiba | 2.20 | 420 | 5 | 0.81 | - | - |
| | Fine screen washing pumps | Toshiba/Teco | 11 | 400 | 18 | - | 42 | 25 |
| Raw water pumping | Raw water Pumps | Kubota/Teco | 280 | 400 | 473 | - | 44 | 1600 |
| Chemical feeding | PAC mixer | Cyclo drive | 2.2 | 400 | 4.9 | - | - | - |
| | Lime mixer | Teco | 2.2 | 400 | 4.9 | - | - | - |
| | PAC dosing | Iwaki/Toshiba | 0.75 | 400 | 1.9 | - | 5 | 13 |
| | Post Lime Booster Pump | Toshiba/Warman | 5.5 | 400 | 11 | - | 60 | 12 |
| | Post Lime Dosing Pump | Nord/Wetzsch | 1.1 | 400 | 3 | 0.7 | 5 | 13 |
| Rapid mixing | - | - | - | - | - | - | - | - |
| Slow mixing | - | - | - | - | - | - | - | - |
| Sedimentation | Sludge collector | Toshiba | 1.1 | 400 | 2.8 | 0.83 | - | - |
| Filtration | Back wash air blower | Toshiba | 111.9 | 400 | 190 | - | - | - |
| | Back wash pumps | Toshiba/Teco | 37 | 400 | 69.1 | - | - | 730 |
| Disinfection | Chlorination booster pump | Toshiba/Teco | 5.5 | 400 | 10.3 | - | 45 | 132 |
| Distribution pumping | Pump 1 | Kubota/Teco | 450 | 400 | 760 | - | 134 | 720 |
| | Pump 2 | Kubota/Teco | 110 | 400 | 189 | - | 102 | 240 |
| | Pump 3 | Kubota/Teco | 270 | 400 | 458 | - | 102 | 620 |
| | Pump 4 | Ibara/Teco | 90 | 400 | 159 | - | 52 | 300 |
| Sludge treatment | Backwash recovery pumps | Toshiba/Warman | 22 | 400 | - | 0.98 | 16 | 270 |

Audit Duration – From: 07.00 on 16 Jan 2016 **To:** 7.00 on 17 Jan 2016

Table B.14: Measured Electrical Energy Related Parameters, Pump Heads and Flow Rates of Equipment in Malimbada Water Supply Scheme

| Unit process | Equipment | Measured Parameters | | | | | | Operation Schedule |
|----------------------|---------------------------|---------------------|-------------|-------------|------|----------|--------------------------|--------------------------------------|
| | | Power (kW) | Voltage (V) | Current (A) | PF | Head (m) | Flow (m ³ /h) | |
| Screening | Course screen (50mm) | – | – | – | – | – | – | 2 duty |
| | Fine screen (10mm) | – | 394 | 4.8 | 0.97 | – | – | 2 duty, 20 min/d |
| | Fine screen washing pumps | – | 394 | 18 | 0.97 | 42 | 21 | 1 duty, 1 standby, 20 min |
| Raw water pumping | Raw water pumps | – | 394 | 353 | 0.97 | 38 | 1590 | 1 duty, 2 standby, 23h |
| Chemical feeding | PAC mixer | – | 394 | 3.6 | 0.97 | – | – | 1 duty, 1 standby, 8 h |
| | Lime mixer | – | 394 | 3.5 | 0.97 | – | – | 1 duty, 1 standby, 8 h |
| | PAC dosing | – | 394 | 1.8 | 0.97 | – | – | 1 duty, 1 standby, 23 h |
| | Post lime booster pumps | – | 394 | 5.5 | 0.97 | – | – | 1 duty, 1 standby, 23 h |
| | Post lime dosing Pump | – | 394 | 2.6 | 0.97 | – | – | 1 duty, 1 standby, 23 h |
| Rapid mixing | – | – | – | 0.97 | – | – | – | |
| Slow mixing | – | – | – | 0.97 | – | – | – | |
| Sedimentation | Sludge collector | – | 394 | 2.1 | 0.97 | – | – | 2 duty, 4 h |
| Filtration | Back wash air blower | – | 394 | 125 | 0.97 | – | – | 1 duty, 1 standby, 3 m, 2 backwashes |
| | Back wash pump | – | 394 | 60 | 0.97 | – | 720 | 1 duty, 7 m : 2 duty , 10m |
| Disinfection | Chlorinator booster pump | – | 394 | 10 | 0.97 | – | – | 1 duty, 1 standby, 23 h |
| Distribution pumping | Pump 1 | 386 | 394 | 620 | 0.97 | 127 | 780 | 1 duty, 1 standby, 20 h 13 min |
| | Pump 2 | 95 | 394 | 159 | 0.97 | 96 | 220 | 1 duty, 1 standby, 20 h 45 min |
| | Pump 3 | 209 | 394 | 342 | 0.97 | 91 | 650 | 1 duty, 1 standby, 16 h |
| | Pump 4 | 62.5 | 394 | 113 | 0.97 | 56 | 260 | 1 duty, 1 standby, 20 h 17 min |
| Backwash recovery | Backwash recovery | – | 394 | 37 | 0.97 | 12 | 180 | 1 duty, 1 standby, 2 h 15 min |

Table B.15: Rated Electrical Energy Related Parameters, Pump Heads and Flow Rates of Equipment in Tangalle Water Supply Scheme

| Unit process | Equipment | Brand | Rated Parameters | | | | | |
|----------------------|----------------------------------------------|------------|------------------|------------|------------|------|---------|-------------------------|
| | | Motor/Pump | Power(kW) | Voltage(V) | Current(A) | PF | Head(m) | Flow(m ³ /h) |
| Raw water pumping | Intake Pumps | KSB | 30 | 415 | 55 | 0.8 | 26 | 150 |
| | | KSB | 30 | 415 | 55 | 0.8 | 30 | 175 |
| | | KSB | 15 | 415 | 45 | 0.8 | 24 | 130 |
| Chemical feeding | Alum mixer 1/2 | Primo | 0.85 | 415 | 2.1 | 0.9 | – | – |
| | Constant head gravity feeder | – | – | – | – | – | – | – |
| Rapid mixing | Hydraulic jump | – | – | – | – | – | – | – |
| Slow mixing | Baffled flocculators | – | – | – | – | – | – | – |
| Sedimentation | Plain sedimentation tanks | – | – | – | – | – | – | – |
| Filtration | Back wash air blower | Hico | 11 | 415 | 20.8 | 0.8 | – | – |
| | Back wash water from back wash tank | – | – | – | – | – | – | – |
| Chlorination | Motive water from treated water pumping main | – | – | – | – | – | – | – |
| Distribution pumping | Pump 1 | Grundfos | 45 | 415 | 86 | 0.80 | 52 | 225 |
| | | Paco | 45 | 415 | 77 | 0.80 | 64 | 185 |
| | Pump 2 | Paco | 15 | 415 | 25 | 0.80 | 96 | 45 |

Audit Duration – From: 09.00 on 19 Jan 2016 **To:** 09.00 on 20 Jan 2016

Table B.16: Measured Electrical Energy Related Parameters, Pump Heads and Flow Rates of Equipment in Tangalle Water Supply Scheme

| Unit process | Equipment | Measured Parameters | | | | | | Operation Schedule |
|----------------------|----------------------------------------------|---------------------|-------------|-------------|------|----------|--------------------------|---------------------------|
| | | Power (kW) | Voltage (V) | Current (A) | PF | Head (m) | Flow (m ³ /h) | |
| Raw water pumping | Intake Pumps | – | 400 | 39 | 0.75 | 27 | 145 | 1 duty, 24 h |
| | | – | 400 | 45 | 0.75 | 29 | 170 | 1 duty, 24 h |
| | | – | 400 | 28 | 0.75 | 26 | 128 | 1 duty, 24 h |
| Chemical feeding | Alum mixer | – | 414 | 2.0 | 0.8 | – | – | 1 duty, 1 standby, 24 h |
| | Constant head gravity feeder | – | – | – | – | – | – | – |
| Rapid mixing | Hydraulic jump | – | – | – | – | – | – | – |
| Slow mixing | Baffled flocculator | – | – | – | – | – | – | – |
| Sedimentation | Plain sedimentation tank | – | – | – | – | – | – | – |
| Filtration | Back wash air blower 1/2 | – | 414 | 18 | 0.9 | – | – | 1 duty, 1 standby, 15 min |
| | Back wash water from back wash tank | – | – | – | – | – | – | – |
| Chlorination | Motive water from treated water pumping main | – | – | – | – | – | – | – |
| Distribution pumping | Pump 1 | – | 414 | 84 | 0.97 | 60 | 220 | 1 duty, 2 standby ,24 h |
| | | – | 414 | 64 | 0.97 | 64 | 180 | 1 duty, 1 standby, 24 h |
| | Pump 2 | – | 414 | 26 | 0.97 | 98 | 36 | 1 duty, 1 standby ,24 h |

Audit Duration – From: 09.00 on 15 Dec 2015 **To:** 09.00 on 16 Dec 2015

Table B.17: Specific Energy Consumption of Water Treatment Unit Processes in Hallala Water Supply Scheme

| Unit Process | Equipment | Energy Consumption (kWh) | Specific Energy Consumption (kWh/ m³) | Specific Energy Consumption of Unit Process (kWh/ m³) |
|----------------------|--------------------------|---------------------------------|---------------------------------------------------------|--------------------------------------------------------------------------|
| Raw water pumping | Raw water pump set 1 | 2480 | 0.2569 | 0.2667 |
| | Raw water pump set 2 | 94 | 0.0098 | |
| Chemical feeding | PAC mixer | 29.8 | 0.0031 | 0.0042 |
| | PAC booster pumps | 10.3 | 0.0011 | |
| | Air compressor | 0.64 | 0.0001 | |
| Sedimentation | Sludge scraper | 45 | 0.0047 | 0.0047 |
| Filtration | Back wash Air Blower | 4.98 | 0.0005 | 0.0005 |
| Chlorination | Booster Pumps | 36.8 | 0.0038 | 0.0038 |
| Distribution pumping | Treated water pump set 1 | 1074 | 0.1112 | 0.1169 |
| | Treated water pump set 2 | 54.5 | 0.0056 | |

Audit Duration – From: 09.00 on 4 Jan 2016 **To:** 09.00 on 5 Jan 2016

Table B.18: Specific Energy Consumption of Water Treatment Unit Processes in Ruhunupura Water Supply Scheme

| Unit process | Equipment | Energy Consumption | Specific Energy Consumption (kWh/ m³) | Specific Energy Consumption of Unit Process (kWh/ m³) |
|----------------------|---------------------------|---------------------------|---------------------------------------------------------|--------------------------------------------------------------------------|
| Raw water pumping | Intake Pumps | 1010.55 | 0.1283 | 0.1283 |
| Chemical Mixing | Alum mixer | 0.13 | 0.00002 | 0.00003 |
| | Feed water pump for mixer | 0.13 | 0.00002 | |
| Filtration | Back wash air blower | 3.25 | 0.0004 | |
| | Back wash pump | 15.49 | 0.0020 | 0.0024 |
| Chlorination | Chlorination booster pump | 7.32 | 0.0009 | 0.0009 |
| Distribution pumping | Highlift pump | 5182.3 | 0.6577 | 0.6577 |

Audit Duration – Audit Duration- From: 07.00 on 7 Jan 2016 To: 07.00 on 8 Jan 2016

Table B.19: Specific Energy Consumption of Water Treatment Unit Processes in Hapugala Water Supply Scheme

| Unit process | Equipment | Energy Consumption (kWh) | Specific Energy Consumption (kWh) | Specific Energy Consumption of Unit Process (kWh/ m ³) |
|----------------------|----------------------------------------|--------------------------|-----------------------------------|---------------------------------------------------------------------|
| Raw water pumping | Intake pumps | 1680.50 | 0.0946 | 0.0946 |
| Chemical Mixing | PAC booster pumps | 10.22 | 0.0006 | 0.0044 |
| | Lime booster pumps | 7.73 | 0.0004 | |
| | Agitator | 59.62 | 0.0034 | |
| Slow mixing | Pulsator vacuum pumps | 145.45 | 0.0082 | 0.0082 |
| Filtration | Back wash air blower | 4.83 | 0.0003 | 0.0005 |
| | Back wash air compressor | 0.56 | 0.0000 | |
| | Back wash pumps | 3.68 | 0.0002 | |
| Chlorination | Chlorination booster pumps | 61.15 | 0.0034 | 0.0034 |
| Sludge treatment | Settling tank to sludge pit pumps | 2.24 | 0.0001 | 0.0010 |
| | Sludge pit to sludge thickener pump | 3.91 | 0.0002 | |
| | Settling tank to aerator pumps | 9.84 | 0.0006 | |
| | Sludge thickener to sludge lagoon pump | 1.93 | 0.0001 | |
| Distribution pumping | Pumps set 1 | 1544.3 | 0.0869 | 0.4882 |
| | Pumps set 2 | 2718.3 | 0.1530 | |
| | Pumps set 3 | 339.4 | 0.0191 | |
| | Pumps set 4 | 2357 | 0.1327 | |
| | Pumps set 5 | 1715.3 | 0.0965 | |

Audit Duration – From: 07.00 on 16 Jan 2016 **To:** 07.00 on 17 Jan 2016

Table B.20: Specific Energy Consumption of Water Treatment Unit Processes in Malimbada Water Supply Scheme

| Unit process | Equipment | Power consumption of equipment (kWh) | Specific Energy Consumption (kWh) | Specific Energy Consumption of Unit Process (kWh/ m ³) |
|----------------------|---------------------------|---------------------------------------|-----------------------------------|---------------------------------------------------------------------|
| Screening | Fine screen (10mm) | 2.1 | 0.00006 | 0.0002 |
| | Fine screen washing pumps | 3.9 | 0.00011 | |
| Raw water pumping | Raw water pumps | 5257.6 | 0.14602 | 0.1460 |
| Chemical feeding | PAC mixer | 19.1 | 0.00053 | 0.0054 |
| | Lime mixer | 18.5 | 0.00051 | |
| | PAC dosing | 28.6 | 0.00079 | |
| | Post lime booster pump | 87.4 | 0.00243 | |
| | Post lime dosing pump | 41.3 | 0.00115 | |
| Sedimentation | Sludge collector | 22.2 | 0.00062 | 0.0006 |
| Filtration | Back wash air blower | 8.3 | 0.00023 | 0.0009 |
| | Back wash pump | 22.5 | 0.00063 | |
| Disinfection | Chlorination Booster Pump | 158.9 | 0.00441 | 0.0044 |
| Distribution pumping | Pumps set 1 | 8297.2 | 0.23043 | 0.4338 |
| | Pumps set 2 | 2184.0 | 0.06065 | |
| | Pumps set 3 | 3622.2 | 0.10060 | |
| | Pumps set 4 | 1517.2 | 0.04214 | |
| Backwash recovery | Backwash recovery | 55.1 | 0.00153 | 0.0015 |

Audit Duration – From: 09.00 on 19 Jan 2016 **To:** 09.00 on 20 Jan 2016

Table B.21: Specific Energy Consumption of Water Treatment Unit Processes in Tangalle Water Supply Scheme

| Unit process | Equipment | Energy Consumption (kWh) | Specific Energy Consumption (kWh/ m ³) | Specific Energy Consumption of Unit Process (kWh/ m ³) |
|----------------------|----------------------|--------------------------|----------------------------------------------------|---------------------------------------------------------------------|
| Raw water pumping | Intake pumps | 486 | 0.0465 | 0.1335 |
| | | 561 | 0.0536 | |
| | | 349 | 0.0334 | |
| Chemical feeding | Alum mixer | 28 | 0.0026 | 0.0026 |
| Filtration | Back wash air blower | 3 | 0.0003 | 0.0003 |
| Distribution pumping | Pumping set 1 | 1402 | 0.1340 | 0.2776 |
| | | 1068 | 0.1021 | |
| | Pumping set 2 | 434 | 0.0415 | |

Table B.22: Specific Energy Consumption of Distribution Booster Pumping at Ruhunupura and Hapugala Water Supply Schemes

| Month | Energy Consumption (kWh) | Monthly Production (m ³) | Specific Energy Consumption (kWh/m ³) |
|---------------------------------------|--------------------------|--------------------------------------|---------------------------------------------------|
| Ruhunupura Water Supply Scheme | | | |
| Jan-12 | 28596 | 226792 | 0.126 |
| Feb-12 | 32166 | 202766 | 0.159 |
| Mar-12 | 33379 | 222886 | 0.150 |
| Apr-12 | 27353 | 214240 | 0.128 |
| May-12 | 34630 | 248589 | 0.139 |
| Jun-12 | 28107 | 216160 | 0.130 |
| Jul-12 | 30431 | 221077 | 0.138 |
| Aug-12 | 33587 | 240729 | 0.140 |
| Sep-12 | 28310 | 237349 | 0.119 |
| Oct-12 | 32288 | 229956 | 0.140 |
| Nov-12 | 31811 | 215636 | 0.148 |
| Dec-12 | 33616 | 220453 | 0.152 |
| Average | 31190 | 224719 | 0.139 |
| Hapugala Water Supply Scheme | | | |
| Jan-12 | 86710 | 525515 | 0.165 |
| Feb-12 | 91887 | 556892 | 0.165 |
| Mar-12 | 92253 | 559107 | 0.165 |
| Apr-12 | 98560 | 597335 | 0.165 |
| May-12 | 98118 | 594652 | 0.165 |
| Jun-12 | 104532 | 633527 | 0.165 |
| Jul-12 | 94847 | 574828 | 0.165 |

| Month | Energy Consumption (kWh) | Monthly Production (m³) | Specific Energy Consumption (kWh/m³) |
|----------------|---------------------------------|-------------------------------------------|--------------------------------------------------------|
| Aug-12 | 98864 | 599175 | 0.165 |
| Sep-12 | 94415 | 572215 | 0.165 |
| Oct-12 | 102497 | 617000 | 0.166 |
| Nov-12 | 98518 | 614163 | 0.160 |
| Dec-12 | 98573 | 583828 | 0.169 |
| Average | 96648 | 585686 | 0.165 |

Table B.23: Specific Energy Consumption of Distribution Booster Pumping at Malimbada and Tangalle Water Supply Schemes

| Month | Energy Consumption (kWh) | Monthly Production (m³) | Specific Energy Consumption (kWh/m³) |
|--------------------------------------|---------------------------------|-------------------------------------------|--------------------------------------------------------|
| Malimbada Water Supply Scheme | | | |
| Jan-12 | 36926 | 1269873 | 0.029 |
| Feb-12 | 32970 | 1205881 | 0.027 |
| Mar-12 | 37521 | 1293815 | 0.029 |
| Apr-12 | 35341 | 1253172 | 0.028 |
| May-12 | 39610 | 1365878 | 0.029 |
| Jun-12 | 37444 | 1291168 | 0.029 |
| Jul-12 | 37954 | 1326022 | 0.029 |
| Aug-12 | 37934 | 1308067 | 0.029 |
| Sep-12 | 36483 | 1258029 | 0.029 |
| Oct-12 | 37814 | 1329458 | 0.028 |
| Nov-12 | 37958 | 1308884 | 0.029 |
| Dec-12 | 34971 | 1205881 | 0.029 |
| Average | 36910 | 1284677 | 0.029 |

| Month | Energy Consumption (kWh) | Monthly Production (m ³) | Specific Energy Consumption (kWh/m ³) |
|-------------------------------------|--------------------------|--------------------------------------|---------------------------------------------------|
| Tangalle Water Supply Scheme | | | |
| Jan-12 | 19671 | 308559 | 0.064 |
| Feb-12 | 23274 | 335323 | 0.069 |
| Mar-12 | 19561 | 343837 | 0.057 |
| Apr-12 | 21308 | 324102 | 0.066 |
| May-12 | 19911 | 350945 | 0.057 |
| Jun-12 | 22786 | 308310 | 0.074 |
| Jul-12 | 21016 | 309727 | 0.068 |
| Aug-12 | 22759 | 315254 | 0.072 |
| Sep-12 | 21204 | 302304 | 0.070 |
| Oct-12 | 23541 | 311647 | 0.076 |
| Nov-12 | 20148 | 308483 | 0.065 |
| Dec-12 | 15594 | 298713 | 0.052 |
| Average | 20898 | 318100 | 0.066 |




Figure B.1: Energy Balance Diagram of Hallala Water Supply Scheme




Figure B.2: Energy Balance Diagram of Ruhunupura Water Supply Scheme




Figure B.3: Energy Balance Diagram of Hapugala Water Supply Scheme




Figure B.4: Energy Balance Diagram of Malimbada Water Supply Scheme




Figure B.5: Energy Balance Diagram of Tangalle Water Supply Scheme

Table B.24: Specific Energy Consumption of Distribution Pumping

| Distribution Pumping Main | Energy Consumption (kWh) | Volume Pumped (m ³) | Elevation Difference (m) | Length* (km) | Specific Energy Consumption (kWh/m ³ /m lift) | Specific Energy Consumption (kWh/m ³ /m lift/km) |
|-----------------------------------------------------------------------------------------------------|--------------------------|---------------------------------|--------------------------|--------------|----------------------------------------------------------|-------------------------------------------------------------|
| Hallala Water Supply Scheme : Duration - 9.00 A.M. (15/12/2013) - 9.00 A.M.(16/12 2012) | | | | | | |
| Distribution 1 | 1074 | 9030 | 20 | 0.95 | 0.006 | 0.006 |
| Distribution 2 | 55 | 625 | 20 | 0.95 | 0.004 | 0.005 |
| Average | | | | | 0.005 | 0.005 |
| Ruhunupura Water Supply Scheme: Duration - 9.00 A.M. on 4 Jan 2013 - 9.00 A.M. on 5 Jan 2013 | | | | | | |
| Distribution 1 | 4695 | 8030 | 131 | 5.4 | 0.004 | 0.001 |
| Distribution 2 | 476 | 520 | 128 | 3.2 | 0.006 | 0.002 |
| Distribution 3 | 640 | 1596 | 80 | 2.8 | 0.005 | 0.002 |
| Average | | | | | 0.005 | 0.001 |
| Hapugala Water Supply Scheme: Duration - 7.00 A.M. on 7 Jan 2013 - 7.00 A.M. on 8 Jan 2013 | | | | | | |
| Distribution 1 | 338 | 754 | 73.8 | 3.15 | 0.006 | 0.002 |
| Distribution 2 | 1212 | 3218 | 75.8 | 3.99 | 0.005 | 0.001 |
| Distribution 3 | 2266 | 5668 | 90 | 7.71 | 0.004 | 0.001 |
| Distribution 4 | 1600 | 3000 | 107 | 3.12 | 0.005 | 0.002 |
| Distribution 5 | 2658 | 5128 | 118.9 | 2 | 0.004 | 0.002 |
| Distribution 6 | 1030 | 3180 | 78 | 4.2 | 0.005 | 0.001 |
| Distribution 7 | 460 | 842 | 80 | 3.20 | 0.006 | 0.002 |
| Distribution 8 | 1442 | 3878 | 88 | 3.00 | 0.005 | 0.002 |
| Average | | | | | 0.005 | 0.002 |

Note: BPH – Secondary booster pump house in the distribution

Table B.24: Specific Energy Consumption of Distribution Pumping (Continued)

| Distribution Pumping Main | Energy Consumption (kWh) | Volume Pumped (m ³) | Elevation Difference (m) | Length (km) | Specific Energy Consumption (kWh/m ³ /m lift) | Specific Energy Consumption (kWh/m ³ /m lift/km) |
|-----------------------------------------------------------------------------------------------------|--------------------------|---------------------------------|--------------------------|-------------|----------------------------------------------------------|-------------------------------------------------------------|
| Malimbada Water Supply Scheme: Duration -7.00 A.M. on 16 Jan 2013 - 7.00 A.M. on 17 Jan 2013 | | | | | | |
| Distribution 1 | 8297 | 15555 | 124 | 2.47 | 0.004 | 0.002 |
| Distribution 2 | 2184 | 3257 | 92.5 | 2.26 | 0.007 | 0.003 |
| Distribution 3 | 3622 | 12145 | 79.4 | 5.43 | 0.004 | 0.001 |
| Distribution 4 | 1517 | 5050 | 49 | 1.83 | 0.006 | 0.003 |
| Distribution 5 | 1044 | 1833 | 90 | 1.70 | 0.007 | 0.004 |
| Average | | | | | 0.006 | 0.003 |
| Tangalle Water Supply Scheme: Duration - 9.00 A.M. on 19 Jan 2013 - 9.00 A.M. on 20 Jan 2013 | | | | | | |
| Distribution 1 | 1402 | 5280 | 53 | 1.3 | 0.005 | 0.004 |
| Distribution 2 | 1406 | 4320 | 53 | 1.3 | 0.006 | 0.005 |
| Distribution 3 | 434 | 864 | 90 | 4.5 | 0.006 | 0.001 |
| Distribution 4 | 691 | 1315 | 80 | 2.8 | 0.007 | 0.002 |
| Average | | | | | 0.006 | 0.003 |

* The length was measured to normalize the energy consumption of pumping over the length of pumping main

Table B.25: Elevation Head and Length of Raw Water Pumping Mains

| Description | Water Supply Scheme | | | | |
|--------------------------------|----------------------------|-----------------|------------------|-------------------|-----------------|
| | Hallala | Hapugala | Malimbada | Ruhunupura | Tangalle |
| Raw water pumping mains | | | | | |
| Elevation head | 35 | 18 | 34 | 27 | 18 |
| Length | 0.6 | 0.15 | 0.32 | 1.8 | 2.55 |

Table B.26: Summary of Energy Consumption for Audited Water Supply Schemes

| Description | Energy consumption component | | | |
|--------------------------------------------------------------|-----------------------------------------------------|-----------------|-------------------------------|------------------------------|
| | Raw water pumping | Treatment plant | Distribution pumping | |
| | | | Distribution pumping from WTP | Distribution booster Pumping |
| Hallala Water Supply Scheme | | | | |
| Audit duration | 9.00 A.M. on 15 Dec 2012 - 9.00 A.M. on 16 Dec 2012 | | | |
| Production (m ³) | 9655 | | | |
| Energy consumption (kWh) | 2574 | 127.6 | 1128.5 | – |
| Total energy consumption (kWh) | 3857 | | | |
| Specific energy consumption (kWh/m ³) | 0.267 | 0.013 | 0.117 | |
| Specific energy consumption (kWh/m ³ /m lift) | 0.008 | – | 0.005 | |
| Specific energy consumption (kWh/m ³ /m lift/ km) | 0.013 | – | 0.005 | |
| Total specific energy consumption (kWh/m ³) | 0.397 | | | |
| % of total energy consumption | 67.3 | 3.3 | 29.4 | |
| Ruhunupura Water Supply Scheme | | | | |
| Audit duration | 9.00 A.M. on 4 Jan 2013 - 9.00 A.M. on 5 Jan 2013 | | | |
| Production (m ³) | 8030 | | | |
| Energy consumption (kWh) | 999 | 25.2 | 4695 | 1116 |
| Total energy consumption (kWh) | 6835 | | | |
| Specific energy consumption (kWh/m ³) | 0.124 | 0.003 | 0.724 | |
| Specific energy consumption (kWh/m ³ /m lift) | 0.005 | – | 0.005 | |
| Specific energy consumption (kWh/m ³ /m lift/ km) | 0.003 | – | 0.001 | |
| Total specific energy consumption (kWh/m ³) | 0.851 | | | |
| % of total energy consumption | 14.6 | 0.4 | 85.1 | |

Table B.26: Summary of Energy Consumption for Audited Water Supply Schemes (Continued)

| Description | Energy consumption component | | | |
|--------------------------------------------------------------|-----------------------------------------------------|-----------------|-------------------------------|------------------------------|
| | Raw water pumping | Treatment plant | Distribution pumping | |
| | | | Distribution pumping from WTP | Distribution booster Pumping |
| Hapugala Water Supply Scheme | | | | |
| Audit duration | 7.00 A.M. on 7 Jan 2013 - 7.00 A.M. on 8 Jan 2013 | | | |
| Production (m ³) | 17768 | | | |
| Energy consumption (kWh) | 1680.5 | 311.18 | 8674.3 | 2932 |
| Total energy consumption (kWh) | 13598 | | | |
| Specific energy consumption (kWh/m ³) | 0.095 | 0.018 | 0.653 | |
| Specific energy consumption (kWh/m ³ /m lift) | 0.005 | – | 0.005 | |
| Specific energy consumption (kWh/m ³ /m lift/ km) | 0.033 | – | 0.002 | |
| Total specific energy consumption (kWh/m ³) | 0.766 | | | |
| % of total energy consumption | 12.3 | 2.3 | 85.4 | |
| Malimbada Water Supply Scheme | | | | |
| Audit duration | 7.00 A.M. on 16 Jan 2013 - 7.00 A.M. on 17 Jan 2013 | | | |
| Production (m ³) | 36007 | | | |
| Energy consumption (kWh) | 5257.6 | 467.9 | 15620.6 | 1044 |
| Total energy consumption (kWh) | 22390 | | | |
| Specific energy consumption (kWh/m ³) | 0.146 | 0.013 | 0.463 | |
| Specific energy consumption (kWh/m ³ /m lift) | 0.004 | – | 0.006 | |
| Specific energy consumption (kWh/m ³ /m lift/ km) | 0.013 | – | 0.003 | |
| Total specific energy consumption (kWh/m ³) | 0.622 | | | |
| % of total energy consumption | 23.5 | 2.1 | 74.4 | |

Table B.26: Summary of Energy Consumption for Audited Water Supply Schemes (Continued)

| Description | Energy consumption component | | | |
|-------------------------------------------------------------|-----------------------------------------------------|-----------------|-----------------------|----------------------|
| | Raw water pumping | Treatment plant | Distribution Pumping | |
| | | | Treated water pumping | Distribution Pumping |
| Tangalle Water Supply Scheme | | | | |
| Audit duration | 9.00 A.M. on 19 Jan 2013 - 9.00 A.M. on 20 Jan 2013 | | | |
| Production (m ³) | 10464 | | | |
| Energy consumption (kWh) | 1396 | 31 | 2904 | 691 |
| Total energy consumption (kWh) | 5022 | | | |
| Specific energy consumption (kWh/m ³) | 0.133 | 0.003 | 0.344 | |
| Specific energy consumption (kWh/m ³ /m lift) | 0.007 | – | 0.006 | |
| Specific energy consumption (kWh/m ³ /m lift/km) | 0.003 | – | 0.003 | |
| Total specific energy consumption (kWh/m ³) | 0.48 | | | |
| % of total energy consumption | 27.8 | 0.6 | 71.6 | |

Appendix C

Detailed Audit Data and Calculations for Energy Conservation Potentials

Table C.1: Energy Saving Potential of Modifying Filter Backwash Frequency

| Description | Tangalle WSS | Ruhunupura WSS |
|-------------------------------------------------------------------------------|---------------------|-----------------------|
| No. of operating hours of WTP per month (30 days) | 720 | 720 |
| No. of filter backwashing per month for 24h duration backwashing | 30 | 30 |
| No. of filter backwashing per month for 48h duration backwashing | 15 | 15 |
| Reduction in number of backwashing per month | 15 | 15 |
| Reduction in number of backwashing per month | 45 | 66 |
| Volume of water saved per month (m ³ /month) | 675 | 990 |
| Specific energy consumption up to clear water sump (kWh/m ³) | 0.136 | 0.127 |
| Total energy saving per month (kWh) | 92 | 126 |
| Total energy saving per year (kWh) | 1117 | 1530 |
| Specific energy saving per unit volume of treated water (kWh/m ³) | 0.0003 | 0.0004 |
| Total specific energy consumption of WSS (kWh/m ³) | 0.418 | 0.719 |
| % Energy saving per unit volume of treated water | 0.07 | 0.06 |

Table C.2: Energy Saving Potential of Modifying Filter Backwash Water Recovery

| Description | Water Supply Scheme | | | | |
|---------------------------------------------------------------------------------|---------------------|------------|----------|-----------|----------|
| | Hallala | Ruhunupura | Hapugala | Malimbada | Tangalle |
| Time duration between filter backwash | 48 | 24 | 48 | 48 | 24 |
| Volume of backwash water (m ³ /day) | 130 | 195 | 225 | 450 | 135 |
| Potential volume to recover (m ³ /day) | 117 | 175.5 | 202.5 | 405 | 121.5 |
| Specific power consumption for backwash recovery (kWh/m ³) | 0.067 | 0.067 | 0.051 | 0.067 | 0.067 |
| Specific power consumption for raw water pumping (kWh/m ³) | 0.267 | 0.124 | 0.095 | 0.146 | 0.133 |
| Energy saving per day (kWh/day) | 23.4 | 10 | 8.9 | 32 | 8 |
| Energy saving per month (kWh/month) | 702 | 300 | 267 | 960 | 241 |
| Energy saving per year (kWh/year) | 8541 | 3651 | 3252 | 11678 | 2927 |
| Average treated water production per day (m ³ /day) | 9223 | 7388 | 19255 | 42236 | 10458 |
| Specific energy saving per unit volume of recovered water (kWh/m ³) | 0.2 | 0.057 | 0.044 | 0.079 | 0.066 |
| Energy requirement for additional treatment (kWh/m ³) | 0.15 | 0.15 | 0.15 | 0.15 | 0.15 |
| Energy saving per unit volume of recovered water (kWh/m ³) | 0.05 | - | - | - | - |
| Energy saving per unit volume of treated water (kWh/m ³) | 0.002 | - | - | - | - |
| Total specific energy consumption (kWh/m ³) | 0.399 | - | - | - | -- |
| % saving per unit volume of treated water | 0.5 | - | - | - | - |

Table C.3: Overall Efficiency of Pump and Motor Systems in Audited Water Supply Schemes

| Unit Process | Pump | Measured Parameters | | | | | Water Power (kW) | Motor Power (kW) | Overall Efficiency of pump & motor system (%) |
|--------------------------------------------------------------------------------------------------------|--------------------------|---------------------|-------------|--------------|----------|--------------------------|------------------|------------------|-----------------------------------------------|
| | | Voltage (V) | Current (A) | Power Factor | Head (m) | Flow (m ³ /h) | | | |
| Hallala Water Supply Scheme : Audit Duration - 9.00 A.M. (15/12/2013) - 9.00 A.M.(16/12 2012) | | | | | | | | | |
| Raw water pumping | Raw water pump set 1 | 390 | 180 | 0.85 | 54 | 420 | 62 | 103 | 60 |
| | Raw water pump set 2 | 390 | 82 | 0.85 | 43 | 220 | 26 | 47 | 55 |
| Treated water pumping | Treated water pump set 1 | 390 | 87 | 0.85 | 24 | 420 | 27 | 50 | 55 |
| | Treated water pump set 2 | 390 | 38 | 0.85 | 19.8 | 250 | 13 | 22 | 62 |
| Ruhunupura Water Supply Scheme : Audit Duration - 9.00 A.M. (04/01/2013) -9.00 A.M.(05/01/2013) | | | | | | | | | |
| Raw water pumping | Intake pump set | 400 | 78 | 0.85 | 28 | 375 | 29 | 46 | 63 |
| Treated water pumping | Treated water pump set | 400 | 400 | 0.85 | 163 | 365 | 162 | 234 | 69 |
| Hapugala Water Supply Scheme : Audit Duration - 7.00 A.M. (07/01/2013) - 7.00 A.M.(08/01/2013) | | | | | | | | | |
| Raw water pumping | Intake Pumps | 406 | 125 | 0.79 | 23 | 748 | 47 | 69 | 68 |
| Treated water pumping | Pumping set 1 | 407 | 168 | 0.86 | 93 | 271 | 69 | 101 | 68 |
| | Pumping set 2 | 400 | 245 | 0.87 | 128 | 285 | 99 | 147 | 68 |
| | Pumping set 3 | 400 | 72 | 0.88 | 94 | 98 | 25 | 38 | 66 |
| | Pumping set 4 | 405 | 278 | 0.83 | 100 | 405 | 110 | 161 | 69 |
| | Pumping set 5 | 408 | 214 | 0.86 | 118 | 244 | 90 | 129 | 70 |

Table C.4: Overall Efficiency of Pump and Motor Systems in Audited Water Supply Schemes (Continued)

| Unit Process | Pump | Measured Parameters | | | | | Water Power (kW) | Motor Power (kW) | Overall Efficiency of pump & motor system (%) |
|--------------------------------------------------------------------------------------------------------|-------------------|---------------------|-------------|--------------|----------|--------------------------|------------------|------------------|-----------------------------------------------|
| | | Voltage (V) | Current (A) | Power Factor | Head (m) | Flow (m ³ /h) | | | |
| Malimbada Water Supply Scheme : Audit Duration - 7.00 A.M. (16/01/2013) - 7.00 A.M.(17/01/2013) | | | | | | | | | |
| Raw water pumping | Raw water pumps | 394 | 353 | 0.97 | 38 | 1590 | 165 | 232 | 71 |
| Treated water pumping | Pumping set 1 | 394 | 620 | 0.97 | 127 | 780 | 280 | 408 | 69 |
| | Pumping set 2 | 394 | 159 | 0.97 | 96 | 220 | 75 | 105 | 72 |
| | Pumping set 3 | 394 | 342 | 0.97 | 91 | 650 | 161 | 225 | 72 |
| | Pumping set 4 | 394 | 113 | 0.97 | 56 | 260 | 53 | 74 | 71 |
| Tangalle Water Supply Scheme : Audit Duration - 09.00 (19/01/2016) - 07.00 (20/01/2016) | | | | | | | | | |
| Raw water pumping | Intake pump set 1 | 400 | 39 | 0.75 | 27 | 145 | 11 | 20 | 53 |
| | Intake pump set 2 | 400 | 45 | 0.75 | 29 | 170 | 13 | 23 | 58 |
| | Intake pump set 3 | 400 | 28 | 0.75 | 25 | 128 | 9 | 14 | 63 |
| Treated water pumping | Pump set 1 | 414 | 84 | 0.97 | 55 | 220 | 33 | 58 | 62 |
| | Pump set 2 | 414 | 64 | 0.97 | 64 | 180 | 31 | 55 | 57 |
| | Pump set 3 | 414 | 26 | 0.97 | 90 | 36 | 9 | 18 | 53 |

Specimen Calculation for Raw water pump set 1 of Hallala WSS

From Equation 2.3 Water power = $\gamma Q h_p / 1000 = 9.81 * 1000 * (420/3600) * 54 / 1000 = 61.80 \text{ kWh} = 62 \text{ kWh}$

From Equation 2.9 Motor power = $\sqrt{3} \cdot V \cdot I \cdot \cos \phi = 1.732 * 390 * 180 * 0.85 / 1000 = 103.34 \text{ kWh} = 103 \text{ kWh}$

From Equation 2.4 Overall pump and motor efficiency = Water power / Motor power = $62 / 103 * 100 = 60\%$

Table C.5: Percentage Energy Saving and Annual Energy Saving Potential of Improving Overall Efficiency of Pump and Motor Systems in Audited Water Supply Schemes

| Unit Process | Pump | SEC of Pump & Motor System (kWh/m ³) | SEC of Pump & Motor System at 70% Efficiency (kWh/m ³) | Specific Energy Saving (kWh/m ³) | Total Specific Energy Saving (kWh/m ³) | Percentage Energy Saving (%) | Annual Energy Saving (kWh) |
|--------------------------------------------------------------------------------------------------------|--------------------------|--------------------------------------------------|--------------------------------------------------------------------|----------------------------------------------|----------------------------------------------------|------------------------------|----------------------------|
| Hallala Water Supply Scheme : Audit Duration - 9.00 A.M. (15/12/2013) - 9.00 A.M.(16/12 2012) | | | | | | | |
| Raw water pumping | Raw water pump set 1 | 0.2569 | 0.2206 | 0.0363 | 0.0624 | 15.7 | 219894 |
| | Raw water pump set 2 | 0.0098 | 0.0077 | 0.0021 | | | |
| Treated water pumping | Treated water pump set 1 | 0.1112 | 0.0878 | 0.0234 | | | |
| | Treated water pump set 2 | 0.0056 | 0.0050 | 0.0006 | | | |
| Ruhunupura Water Supply Scheme : Audit Duration - 9.00 A.M. (04/01/2013) -9.00 A.M.(05/01/2013) | | | | | | | |
| Raw water pumping | Intake pump set | 0.1283 | 0.1148 | 0.0135 | 0.0212 | 2.5 | 62054 |
| Treated water pumping | Treated water pump set | 0.6577 | 0.6501 | 0.0076 | | | |
| Hapugala Water Supply Scheme : Audit Duration - 7.00 A.M. (07/01/2013) - 7.00 A.M.(08/01/2013) | | | | | | | |
| Raw water pumping | Intake Pumps | 0.0946 | 0.0917 | 0.0029 | 0.0146 | 1.9 | 94480 |
| Treated water pumping | Pump set 1 | 0.0869 | 0.0841 | 0.0028 | | | |
| | Pump set 2 | 0.153 | 0.1479 | 0.0051 | | | |
| | Pump set 3 | 0.0191 | 0.0180 | 0.0011 | | | |
| | Pump set 4 | 0.1327 | 0.1299 | 0.0028 | | | |
| | Pump set 5 | - | - | - | | | |

Table C.6: Percentage Energy Saving and Annual Energy Saving Potential of Improving Overall Efficiency of Pump and Motor Systems in Audited Water Supply Schemes (Continued)

| Unit Process | Pump | SEC of Pump & Motor System (kWh/m ³) | SEC of Pump & Motor System at 70% Efficiency (kWh/m ³) | Specific Energy Saving (kWh/m ³) | Total Specific Energy Saving (kWh/m ³) | Percentage Energy Saving (%) | Annual Energy Saving (kWh) |
|--------------------------------------------------------------------------------------------------------|-------------------|--------------------------------------------------|--------------------------------------------------------------------|----------------------------------------------|----------------------------------------------------|------------------------------|----------------------------|
| Malimbada Water Supply Scheme : Audit Duration - 7.00 A.M. (16/01/2013) - 7.00 A.M.(17/01/2013) | | | | | | | |
| Raw water pumping | Raw water pumps | - | - | - | - | - | - |
| Treated water pumping | Pump set 1 | 0.2304 | 0.2258 | 0.0047 | 0.0047 | 0.8 | 61327 |
| | Pump set 2 | - | - | - | | | |
| | Pump set 3 | - | - | - | | | |
| | Pump set 4 | - | - | - | | | |
| Tangalle Water Supply Scheme : Audit Duration - 9.00 A.M. (19/01/2013) - 7.00 A.M.(20/01/2013) | | | | | | | |
| Raw water pumping | Intake pump set 1 | 0.0465 | 0.0352 | 0.0113 | 0.0820 | 17.1 | 313301 |
| | Intake pump set 2 | 0.0536 | 0.0442 | 0.0094 | | | |
| | Intake pump set 3 | 0.0334 | 0.0287 | 0.0047 | | | |
| Treated water pumping | pump set 1 | 0.134 | 0.1086 | 0.0254 | | | |
| | pump set 2 | 0.1021 | 0.0832 | 0.0189 | | | |
| | Pump set 3 | 0.0415 | 0.0291 | 0.0124 | | | |

Table C.7: Reasons for Water Losses and the Average NRW of Audited Water Supply Schemes

| NRW component | Quantity (number) | | | |
|---------------------------------------------|------------------------------------------------------------------------|--------------|---------------|--------------|
| | Ruhunupura WSS | Hapugala WSS | Malimbada WSS | Tangalle WSS |
| Physical losses | | | | |
| Pipe breakdowns (major) | 2 | 6 | 8 | 4 |
| Pipe breakdowns (minor) | 13 | 50 | 70 | 20 |
| Reservoir overflow | Automatic reservoir level monitoring systems available (no overflows) | | | |
| Apparent losses | | | | |
| Free water | All water services are measured and revenue generated | | | |
| Defective meters | 426 | 756 | 2000 | 920 |
| Illegal connections | 50 | 90 | 150 | 100 |
| Average production (m ³ /day) | 7388 | 19255 | 42236 | 10458 |
| NRW (%) | 35 | 26 | 26 | 33 |

Table C.8: Components of Non-Revenue Water in Audited Water Supply Schemes

| NRW component | Volume of Non-Revenue Water (m ³ /day) | | | |
|--------------------------|---------------------------------------------------|--------------|---------------|--------------|
| | Ruhunupura WSS | Hapugala WSS | Malimbada WSS | Tangalle WSS |
| Physical losses | | | | |
| Pipe breakdowns | 920 | 2200 | 3000 | 1200 |
| Leakage | 1376 | 2364 | 7011 | 1693 |
| House connection leakage | | | | |
| Reservoir overflows | 0 | 0 | 0 | 0 |
| Total Physical losses | 2296 | 4564 | 10011 | 2893 |
| Apparent losses | | | | |
| Defective meters | 170 | 302 | 800 | 368 |
| Illegal connections | 120 | 140 | 170 | 190 |
| Free water | 0 | 0 | 0 | 0 |
| Total losses | 2586 | 5006 | 10981 | 3451 |

Note: Link between Table C.5 and C.6

| | |
|--------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Minor leak (for 63-110 mm pipe diameters) | : 40 m ³ /minor leak |
| Major leak (for 150 mm and above pipe diameters) | : 200 m ³ /major leak |
| Defective meters | : 0.4 m ³ /day/defective meter |
| Illegal Connections | : Commercial (10% of the suspected number) -0.5 m ³ /day/connection : Domestic (90% of the suspected number) -10 m ³ /day/connection |

Table C.9: Energy Conservation Potential of Reducing Physical Losses in Audited Water Supply Schemes

| Description | Unit | Water Supply Scheme | | | |
|-----------------------------------------------------------------|---------------------|---------------------|--------------|---------------|--------------|
| | | Ruhunupura WSS | Hapugala WSS | Malimbada WSS | Tangalle WSS |
| Number of Connections (Nc) | Number | 10647 | 25200 | 51800 | 18375 |
| Lowest elevation (MSL) | m | 116 | 477 | 437 | 196 |
| Highest elevation (MSL) | m | 250 | 640 | 570 | 300 |
| Average operating pressure (P) | m | 67 | 80 | 66 | 52 |
| Economic Level of Leakage | L/connection/day | 155 | 155 | 155 | 155 |
| Economic Level of Leakage | m ³ /day | 1650 | 3906 | 8029 | 2848 |
| Total physical losses | m ³ /day | 2296 | 4564 | 10011 | 2893 |
| Possible reduction of physical losses | m ³ /day | 646 | 658 | 1982 | 45 |
| Specific energy consumption of water supply | kwh/m ³ | 0.851 | 0.765 | 0.622 | 0.48 |
| Energy conservation potential of reducing physical water losses | kWh/day | 550 | 503 | 1233 | 22 |
| Energy conservation potential of reducing physical water losses | kWh/Year | 200750 | 183596 | 766962 | 8030 |
| Average production per day | m ³ /day | 7388 | 19255 | 42236 | 10458 |
| % of Economic Level of Leakage | % | 22 | 20 | 19 | 27 |
| % of physical losses | % | 31 | 24 | 24 | 28 |
| % Energy saving per unit volume of treated water | % | 9 | 4 | 5 | 1 |

Table C.10: Energy Conservation Potential of Reducing Commercial Losses and Total Potential of Energy Conservation Through Reducing Non-Revenue Water in Audited Water Supply Schemes

| Description | Unit | Water Supply Scheme | | | |
|-------------------------------------------------------------------------------------|---------------------|---------------------|--------------|---------------|--------------|
| | | Ruhunupura WSS | Hapugala WSS | Malimbada WSS | Tangalle WSS |
| Possible reduction of losses by reducing defective meters down to 1% | | | | | |
| Number of defective meters at 1% | Number | 106 | 252 | 518 | 184 |
| Reduction of defective meters | Number | 320 | 504 | 1452 | 736 |
| Reduction of water losses by reducing defective meters | m ³ /day | 128 | 202 | 581 | 294 |
| Possible reduction of losses by reducing illegal connections down to by 0.1% | | | | | |
| Number of illegal connections at 0.1% | Number | 11 | 25 | 52 | 18 |
| Reduction of illegal connections | Number | 39 | 65 | 98 | 82 |
| Reduction of water losses by reducing illegal connections | m ³ /day | 58 | 128 | 125 | 108 |
| Total reduction of commercial losses | | | | | |
| % of commercial losses | % | 3.9 | 2.3 | 2.3 | 5.3 |
| Possible reduction of commercial losses | m ³ /day | 186 | 330 | 706 | 402 |
| Specific energy consumption of water supply | kwh/m ³ | 0.851 | 0.765 | 0.622 | 0.480 |
| Energy conservation potential of reducing commercial losses | kWh/day | 158 | 252 | 439 | 193 |
| | kWh/Year | 57774 | 92033 | 160238 | 70500 |
| % Energy saving per unit volume of treated water | % | 2.5 | 1.7 | 1.7 | 3.8 |
| Total energy conservation potential | | | | | |
| Total energy conservation potential of NRW reduction | kWh/Year | 258524 | 275629 | 927200 | 78530 |
| % Energy saving per unit volume of treated water | % | 12 | 6 | 7 | 5 |

Table C.11: Active Power Consumption and Total Electricity Cost of Ruhunupura Water Supply Scheme

| Month | Active Power Consumption (kWh) | | | Total Cost (LKR x 10 ⁶) |
|-----------------------------------------|--------------------------------|---------------|---------------|-------------------------------------|
| | Peak | Day | Off Peak | |
| Ruhunupura Water Treatment Plant | | | | |
| Jan-12 | 12,811 | 75,325 | 43,672 | 1.5 |
| Feb-12 | 22,667 | 77,188 | 45,654 | 1.7 |
| Mar-12 | 15,346 | 67,580 | 39,862 | 1.6 |
| Apr-12 | 21,612 | 76,168 | 43,825 | 1.8 |
| May-12 | 21,757 | 80,119 | 45,856 | 1.9 |
| Jun-12 | 22,706 | 84,616 | 46,074 | 2 |
| Jul-12 | 20,362 | 68,770 | 36,942 | 1.7 |
| Aug-12 | 24,819 | 75,522 | 45,312 | 1.9 |
| Sep-12 | 21,933 | 82,279 | 43,581 | 1.9 |
| Oct-12 | 23,982 | 79,100 | 45,079 | 2 |
| Nov-12 | 20,324 | 78,432 | 41,276 | 1.9 |
| Dec-12 | 23,515 | 76,387 | 43,279 | 1.9 |
| Average | 20,986 | 76,791 | 43,368 | 1.8 |
| Ruhunupura Intake Pump House | | | | |
| Jan-12 | 2,445 | 10,461 | 5,991 | 0.2 |
| Feb-12 | 4,343 | 16,198 | 9,042 | 0.3 |
| Mar-12 | 3,626 | 14,862 | 8,540 | 0.4 |
| Apr-12 | 4,191 | 15,691 | 8,811 | 0.4 |
| May-12 | 4,698 | 16,827 | 9,375 | 0.4 |

| Month | Active Power Consumption (kWh) | | | Total Cost (LKR x 10 ⁶) |
|----------------|--------------------------------|---------------|--------------|-------------------------------------|
| | Peak | Day | Off Peak | |
| Jun-12 | 6,376 | 21,356 | 11,865 | 0.5 |
| Jul-12 | 3,522 | 10,534 | 5,517 | 0.3 |
| Aug-12 | 5,442 | 15,985 | 9,653 | 0.4 |
| Sep-12 | 5,920 | 20,416 | 10,776 | 0.5 |
| Oct-12 | 4,477 | 13,699 | 7,827 | 0.4 |
| Nov-12 | 4,436 | 15,814 | 8,641 | 0.4 |
| Dec-12 | 5,191 | 15,768 | 8,988 | 0.4 |
| Average | 4,556 | 15,634 | 8,752 | 0.4 |

Table C.12: Active Power Consumption and Total Electricity Cost of Hapugala and Malimbada Water Supply Schemes

| Month | Active Power Consumption (kWh) | | | Total Cost (LKR x 10 ⁶) |
|-------------------------------------------------------------|--------------------------------|----------------|---------------|-------------------------------------|
| | Peak | Day | Off Peak | |
| Hapugala Water Treatment Plant and Intake Pump House | | | | |
| Jan-12 | 45,103 | 203,023 | 67,183 | 3.7 |
| Feb-12 | 48,052 | 210,412 | 75,671 | 4 |
| Mar-12 | 38,121 | 215,761 | 81,582 | 4 |
| Apr-12 | 40,657 | 225,472 | 92,272 | 4.1 |
| May-12 | 37,434 | 233,072 | 86,285 | 4.2 |
| Jun-12 | 47,054 | 243,460 | 89,602 | 4.4 |
| Jul-12 | 38,674 | 226,801 | 79,422 | 4.1 |
| Aug-12 | 44,983 | 231,360 | 83,162 | 4.2 |
| Sep-12 | 49,762 | 219,855 | 73,712 | 4.1 |
| Oct-12 | 47,760 | 246,948 | 75,492 | 4.4 |
| Nov-12 | 41,177 | 245,167 | 82,154 | 4.3 |
| Dec-12 | 43,783 | 236,101 | 70,413 | 4.2 |
| Average | 43,547 | 228,119 | 79,746 | 4.2 |
| Malimbada Water Treatment Plant | | | | |
| Jan-12 | 30,005 | 286,310 | 76,390 | 6 |
| Feb-12 | 31,657 | 275,980 | 78,780 | 5.9 |
| Mar-12 | 32,550 | 264,886 | 80,830 | 5.9 |
| Apr-12 | 35,919 | 291,090 | 88,100 | 6.4 |
| May-12 | 32,442 | 290,270 | 87,850 | 6.3 |
| Jun-12 | 33,455 | 296,160 | 90,620 | 6.6 |

| Month | Active Power Consumption (kWh) | | | Total Cost (LKR x 10 ⁶) |
|------------------------------------|--------------------------------|----------------|---------------|-------------------------------------|
| | Peak | Day | Off Peak | |
| Jul-12 | 31,578 | 287,700 | 79,810 | 6.2 |
| Aug-12 | 33,217 | 298,750 | 79,390 | 6.3 |
| Sep-12 | 31,470 | 269,980 | 91,820 | 6.1 |
| Oct-12 | 33,083 | 202,030 | 83,430 | 5.3 |
| Nov-12 | 32,945 | 293,720 | 76,750 | 6.2 |
| Dec-12 | 31,554 | 280,770 | 65,730 | 5.8 |
| Average | 32,490 | 278,137 | 81,625 | 6.1 |
| Malimbada Intake Pump House | | | | |
| Jan-12 | 16,181 | 68,612 | 30,005 | 1.7 |
| Feb-12 | 18,098 | 69,081 | 31,657 | 1.8 |
| Mar-12 | 18,968 | 65,442 | 32,550 | 1.7 |
| Apr-12 | 19,836 | 70,583 | 35,919 | 1.9 |
| May-12 | 20,613 | 70,271 | 32,442 | 1.8 |
| Jun-12 | 20,837 | 73,302 | 33,455 | 1.9 |
| Jul-12 | 18,896 | 72,604 | 31,578 | 1.9 |
| Aug-12 | 20,437 | 76,302 | 33,217 | 2 |
| Sep-12 | 22,110 | 68,246 | 31,470 | 1.8 |
| Oct-12 | 21,005 | 81,278 | 33,083 | 2 |
| Nov-12 | 20,176 | 79,846 | 32,945 | 2 |
| Dec-12 | 17,786 | 77,673 | 31,554 | 1.9 |
| Average | 19,579 | 72,770 | 32,490 | 1.8 |

Table C.13: Active Power Consumption and Total Electricity Cost of Tangalle Water Supply Scheme

| Month | Active Power Consumption (kWh) | | | Total Cost (LKR x 10 ⁶) |
|---------------------------------------|--------------------------------|---------------|---------------|----------------------------------------|
| | Peak | Day | Off Peak | |
| Tangalle Water Treatment Plant | | | | |
| Jan-12 | 15,297 | 53,144 | 25,779 | 1.1 |
| Feb-12 | 17,101 | 56,075 | 27,563 | 1.2 |
| Mar-12 | 17,437 | 55,055 | 28,903 | 1.3 |
| Apr-12 | 17,299 | 55,295 | 29,531 | 1.4 |
| May-12 | 17,988 | 55,786 | 30,185 | 1.4 |
| Jun-12 | 18,757 | 59,899 | 32,584 | 2 |
| Jul-12 | 17,657 | 54,140 | 29,428 | 1.3 |
| Aug-12 | 19,716 | 58,474 | 33,999 | 1.5 |
| Sep-12 | 21,908 | 63,099 | 37,263 | 1.6 |
| Oct-12 | 18,605 | 58,372 | 32,445 | 1.5 |
| Nov-12 | 15,762 | 52,623 | 28,244 | 1.3 |
| Dec-12 | 17,358 | 52,759 | 26,702 | 1.3 |
| Average | 17,907 | 56,227 | 30,219 | 1.4 |
| Tangalle Intake Pump House | | | | |
| Jan-12 | 6,982 | 24,499 | 12,244 | 0.5 |
| Feb-12 | 7,170 | 23,844 | 12,095 | 0.5 |
| Mar-12 | 6,910 | 22,849 | 11,689 | 0.6 |
| Apr-12 | 7,429 | 24,639 | 13,138 | 0.6 |

| Month | Active Power Consumption (kWh) | | | Total Cost (LKR x 10 ⁶) |
|----------------|--------------------------------|---------------|---------------|----------------------------------------|
| | Peak | Day | Off Peak | |
| May-12 | 8,072 | 25,546 | 14,057 | 0.6 |
| Jun-12 | 7,931 | 25,991 | 13,943 | 0.6 |
| Jul-12 | 6,801 | 21,216 | 11,457 | 0.5 |
| Aug-12 | 7,153 | 22,324 | 12,578 | 0.6 |
| Sep-12 | 7,815 | 23,055 | 13,603 | 0.6 |
| Oct-12 | 7,095 | 22,825 | 12,318 | 0.6 |
| Nov-12 | 6,293 | 21,634 | 11,207 | 0.5 |
| Dec-12 | 6,668 | 20,943 | 10,655 | 0.5 |
| Average | 7,193 | 23,280 | 12,415 | 0.6 |

Table C.14: Analysis of Potential Energy Saving From Shifting Consumption from Peak Time to Off Peak time of Electricity Tariff Structure

| Component | Peak | Day | Off Peak | Off Peak | No of Peak Hours compensated | Cost Saving (LKR/day) | Cost Saving (LKR/Year) x 10 ⁶ | Total Cost Saving (LKR/Year) x 10 ⁶ |
|---------------------------------------|------------------------------|------------------------------|------------------------------|--------------------------|------------------------------|-----------------------|------------------------------------------|------------------------------------------------|
| | Consumption per Hour (kWh/h) | Consumption per Hour (kWh/h) | Consumption per Hour (kWh/h) | Spared Consumption (kWh) | | | | |
| Ruhunupura Water Supply Scheme | | | | | | | | |
| WTP | 172 | 210 | 178 | 256 | 1.5 | 1600 | 0.58 | 0.71 |
| Intake | 37 | 43 | 36 | 55 | 1.5 | 343 | 0.13 | |
| Hapugala Water Supply Scheme | | | | | | | | |
| WTP & Intake | 358 | 625 | 328 | 2,378 | 3 | 6711 | 2.45 | 2.45 |
| Malimbada Water Supply Scheme | | | | | | | | |
| WTP | 267 | 762 | 335 | 3,413 | 3 | 5007 | 1.82 | 2.92 |
| Intake | 161 | 199 | 134 | 527 | 3 | 3017 | 1.1 | |
| Tangalle Water Treatment Plant | | | | | | | | |
| WTP | 147 | 154 | 124 | 239 | 1.5 | 1380 | 0.5 | 0.7 |
| Intake | 59 | 64 | 51 | 102 | 1.5 | 554 | 0.2 | |

Table C.15: Analysis of Total Energy Conservation Potentials of Audited Water Supply Schemes

| Description | Hallala | Ruhunupura | Hapugala | Malimbada | Tangalle |
|-------------------------------------------------------------------------------------|----------------|-------------------|-----------------|------------------|-----------------|
| Average daily production (m ³ /day) | 9,223 | 7,388 | 19,255 | 42,236 | 10,458 |
| Annual production (m ³ /Year x 10 ⁶) | 3.4 | 2.7 | 7 | 15.4 | 3.8 |
| Specific energy saving potential (kWh/m ³) | 0.0687 | 0.1762 | 0.1072 | 0.1 | 0.16 |
| Annual energy saving potential (kWh/Year x 10 ⁶) | 0.23 | 0.48 | 0.75 | 1.54 | 0.61 |
| Average electricity charge including surcharges (LKR/ kWh) | - | 11.44 | 11.44 | 11.44 | 11.44 |
| Annual cost saving potential from reducing consumption (LKR/Year x10 ⁶) | - | 5.5 | 8.6 | 17.6 | 7 |
| Annual cost saving potential from shifting consumption (LKR/Year x10 ⁶) | - | 0.7 | 2.4 | 2.9 | 0.7 |
| Regional annual energy cost (LKR/Year x10 ⁶) | - | 91 | 94 | 201 | 91 |
| % Cost saving from regional annual energy cost | - | 7.9 | 11 | 10.2 | 8.5 |

