

NEUTRAL CURRENT MITIGATION IN LOW VOLTAGE INSTALLATIONS

A dissertation submitted to the

Department of Electrical Engineering, University of Moratuwa
in partial fulfillment of the requirements for the

Degree of Master of Science

By MOHAMED IHLAAS SADAM AMEER

Supervised by Eng. Rienzie Fernando Eng. Upuli Jayatunga

Department of Electrical Engineering
University of Moratuwa
Sri Lanka

2010

94555

Abstract

Power quality problems with the ever increasing use of electrical and electronic loads has risen to a greater extent. It is quite common to blame the supply authority for lower power quality issues. CEB and LECO the main utilities in Sri Lanka are blamed of this problem. But what the consumers do not understand is that power generation is not low in power quality. It is the consumer himself, who makes the network a poor quality one. The bitter part is that consumers are in the losing side due to this poor network quality, which they take time to realize.

This research was intended to consider the energy loss caused due to unbalance and heavy neutral currents. Heavy neutral currents can be for two reasons. First may be due to unbalance in the network and second could be due to presence of harmonics. This current is a loss to the system in terms of cable losses, over capacity network requirement and added operation and maintenance cost. In turn presence of harmonics and unbalance currents distorts the voltage supplied to other equipment which in turn produces unbalance currents.

Several solution has been found by engineers to this problem. Finding the correct solution is important in this concept. The solution can be easily divided into two categories as energy efficient solutions and energy inefficient solution. For an example if a facility is having high neutral current with high temperature in the neutral current, one solution will be to overate the neutral cable to accommodate the extra current. But on the other hand this will be an inefficient solution, which is trying to accommodate the waste energy comfortably. But if a solution is looked into reducing the neutral current by phase balancing or reducing harmonics, this will be an energy efficient solution. I have extensively discussed energy efficient solutions as a rectification to this problem and other solutions should be discouraged.

The case studies done at varying consumer location proved a much promising solution to, this problem with a sustainable saving from the bills. I have also



implemented a logical unit which will reduce the time consumed for manual phase swapping by fast load flow analysis of the network.

Declaration

The work submitted in this dissertation is the result of my own investigation, except where otherwise stated.

It has not already been accepted for any degree, and is also not being concurrently submitted for any other degree.

MIS Ameer

We endorse the declaration by the candidate.

Reinzie Fernando

UOM Verified Signature

Upuli Jayatunga

Contents

Declaration	iii
Abstract	vi
List of figures	viii
List of tables	ix
1.0 Introduction	1
1.1 Background	1
1.2 Motivation	5
2.0 Problems Faced Due To Heavy Neutral Currents	6
2.1 Introduction	6
2.2 Voltage unbalance problems	6
2.2.1 Three phase motors	6
2.2.2 Electrical network	10
2.3 Current unbalance problems	11
2.4 Harmonics problem Theses & Dissertations	12
3.0 Standards & Regulations	17
3.1 Why Standards?	17
3.2 Relevant Standards	18
3.2.1 IEC	18
3.2.2 BS EN 50160	20
3.2.3 IEEE	20
3.2.4 NEMA Standards	21
4.0 Prevention before Cure	22
4.1 Why prevention?	22
4.2 Prevention of current imbalance	22
4.2.1 Electrical system designer's role in avoiding the problem	22
4.2.2 Electrical maintenance engineer's role in avoiding the problem	23
4.3 Prevention of voltage imbalance	24

4.4 Prevention of harmonic problems	25
5.0 Case Studies for Existing Installations	28
5.1 Background	28
5.2 Data collection from various facilities	28
5.3 Equipment used	29
5.4 Study results	30
5.4.1 Case 1 – Apparel facility	30
5.4.2 Case 2 – Hospital facility	32
5.4.3 Case 3 – Mobile base station	33
5.4.4 Case 4 – Data centre	34
6.0 An Automated Solution	36
6.1 Introduction	36
6.3 Logical processes of the system	37
6.3.1 Solving current unbalance problem	37
6.3.2 Solving minimum network losses over a period of time	43
6.4 Case study done using the program. Theses & Dissertations	46
7.0 Conclusion	49
References:	50

Acknowledgement

A special gratitude is due to my supervisors who guided and fulfilled my dream of achieving this goal. Namely Eng. Rienzie Fernando, a very senior engineer in the industry with a lot experience in Sri Lanka and overseas gave me his fullest support despite his busy schedules. Also I will not forget the encouragement given by Eng Upuli Jayatunga from the Department of Electrical Engineering of University of Moratuwa.

My sincere thanks go to the officers in Post Graduate Office, Faculty of Engineering, University of Moratuwa, Sri Lanka for helping in various ways to clarify the things related to my academic works in time with excellent cooperation and guidance. Sincere gratitude is also extended to the people who serve in the Department of Electrical Engineering office.

I would also appreciate the opportunities given to me by the company I'm employed, The EnergyTeam Solutions (Pvt) Ltd. The project wouldn't be a success unless for the measurement equipment borrowed from the company and for the test installation provided to me for the studies.

Lastly, I should thank many individuals, friends and colleagues of my batch who have not been mentioned here personally in making this educational process a success. I could not have made it without your supports.

List of figures

Figure 1: A balanced system	2
Figure 2 : An unbalanced system	2
Figure 3 : Current waveforms of a load centre	3
Figure 4: Current waveforms of a linear, non linear and non linear with filtration syste	:m4
Figure 5 : Torque – speed curves under unbalance conditions	7
Figure 6: Variation of current and efficiency of a motor with voltage unbalance [1]	8
Figure 7 : Motor overheating with voltage imbalance [1]	9
Figure 8: Decrement of rated power with voltage imbalance [1]	10
Figure 9 : Phase currents of an industrial installation	11
Figure 10 : Burnt change over switch of an installation	12
Figure 11: Effects of presence of harmonics in phases to the neutral	14
Figure 12 : Current waveforms of different loads	16
Figure 13 : Motor derating with percentage unbalance	21
Figure 14: A well designed network for easy phase balancing	23
Figure 15: Filtration for non linear loads. Licomo Lineses & Dissertations	26
Figure 16: An active power filter used to eliminate negative and zero sequence	27
Figure 17: Power analyzer used for data collection	29
Figure 18: Logged data of the facility	30
Figure 19 : Logged data after balancing	31
Figure 20 : Logged data of the facility	32
Figure 21: Logged data of a mobile base station	33
Figure 22: Logged data of a computer data centre	35
Figure 23 : Flow chart for instantaneous phase balancing	40
Figure 24 : Flow chart for phase balancing over a period	44
Figure 25 : Sample network configuration	46
Figure 26 : Screen after data entry	47
Figure 27 : Output screen	48

List of tables

Table 1 : Harmonics regulations on IEC	19
Table 2 : Harmonics regulations on BS EN	20
Table 3 : Voltage regulations on IEEE	21
Table 4 : Equipment used for testing	29
Table 5 : Sample data entry table	38
Table 6: Matrix after the first step	41
Table 7: matrix after the second step	41
Table 8 : Sample data entry format for phase balancing over a period	45
Table 9: Input data to the software	47

