

Chapter 5

5. Voltage Stability Analysis

5.1. Interfacing standards

Maximum capacity of a wind plant that can be connected to a power system is primarily determined by the electrical system and power quality considerations.

Various countries adopt various standards to limit renewable integrations and to ensure the power quality. A rough rule of thumb to control the power quality has been to keep the renewable power plant capacity in MW less than the grid line voltage in kV, if the grid is stiff. On a weak grid, however, only 10 or 20 % of this capacity may be allowed.

On the other hand, it is convenient to meet the power-quality requirements by limiting the total renewable power rating less than a few percent of the short circuit MVA of the grid at the proposed interface. The limit is generally 2% in developed countries and 5 % in developing countries [14].

Some countries adopt a limit on the step change in voltage a customer can cause when loading or unloading a generating unit. This limit is $\pm 2\%$ in Spain for wind generators.

5.2. Voltage stability limit

The voltage fluctuation observed at the point of common coupling (PCC) following a sudden wind farm failure and the grid short circuit level at the PCC were taken in to account to in determining the voltage stability limit for the network during this study.

Since there is no wind interface standard developed for Sri Lanka, the allowable maximum voltage fluctuation is limited to approximately 2% at the PCC and the obtained figure was compared with the grid short circuit level at the same point to obtain a wind integration limit at that point of the grid.

5.3. Methodology and results

The voltage stability is considered as a local impact. Therefore it is necessary to identify the system configuration for wind integration in order to perform voltage stability studies.

Initially proper system configurations were identified for each study year and then the voltage stability studies were carried out for the selected configurations in order to identify the voltage stability limit.

Since local impact highly depends on the local loads, both night peak and off peak loading scenarios were appropriately taken in to account during the voltage stability analysis.

5.3.1. System analysis – Year 2010

This part of the study aims at obtaining a voltage stability limit for wind integration to the proposed year 2010 network at existing Puttlam GS.

At present Puttlam GS consists of 2x31.5MVA transformers. Holcim cement factory is supplied with power using two dedicated 33kV feeders. Two transformers are operated separately. Year 2010 Puttlam GS arrangement is shown in the figure 5.1.




Figure 5.1: Proposed Puttlam GS arrangement for year 2010

The impact of wind additions on the 33kV level is analyzed by considering two wind integration levels. They are 20MW and 35MW. Results are summarized in table 5-1.

Busbar	Observed voltage fluctuation	
	kV	% of nominal voltage
CEMENT	0.165	0.5
PUTTA-3	0.132	0.4

20MW penetration level at night peak scenario

Busbar	Observed voltage fluctuation	
	kV	% of nominal voltage
CEMENT	0.066	0.2
PUTTA-3	0.755	2.3

20MW penetration level at off peak scenario

Busbar	Observed voltage fluctuation	
	kV	% of nominal voltage
CEMENT	0.198	0.6
PUTTA-3	0.363	1.1

35MW penetration level at night peak scenario

Busbar	Observed voltage fluctuation	
	kV	% of nominal voltage
CEMENT	0.066	0.2
PUTTA-3	1.419	4.3

35MW penetration level at off peak scenario

Table 5-1: Observed voltage fluctuations at 33kV level of Puttlam GS

Short-circuit level at Puttlam 33kV busbar is obtained as 258MVA. Wind integration level as a percentage of short circuit level is depicted in table 5-2.

Busbar	Wind power as % of SCC	
	Integration level	
	35MW	20MW
PUTTA-3	13.6%	7.8%

Table 5-2: Wind power as a percentage of SCC – Year 2010

The maximum voltage fluctuation observed in the 33kV busbar is 4.3% following a sudden drop of 35MW wind plant. Around 2.3% variation can be observed following a sudden drop of 20MW wind farm. 20MW wind integration level is about 7.8% of SCC at PCC. Therefore the maximum wind absorption capability at 33kV level of the existing Puttlam GS is identified as 20MW for year 2010 when considering the voltage fluctuations.

5.3.2. System analysis – Year 2012

Voltage stability of the year 2012 network with wind additions into 132kV and 220kV levels was analyzed during this part of study. Year 2012 network arrangement around Puttlam area is depicted on figure 5.2.




Figure 5.2 : Proposed network arrangement for year 2012

85MW and 80MW wind integrations were considered respectively at 132kV and 220kV levels and the results are summarized in the table below.

Loading scenario	Observed voltage fluctuation As % of nominal voltage	Busbar	Observed voltage fluctuation As % of nominal voltage
Night peak	1.4%	Night peak	1.4%
Off peak	1.8%	Off peak	1.9%

85MW wind absorption at 132kV level

80MW wind absorption at 220kV level

Table 5-3: Observed voltage fluctuations at 132kV and 220kV busbars at Puttlam- Year 2012.

SCC at Puttlam 132kV and 220kV busbars and the wind integration levels as a percentage of SCC are depicted in table 5-4.

Voltage level	SCC (MVA)	Wind capacity (MW)	Wind power as % of SCC
132kV	1075	85	7.9%
220kV	1486	80	5.4%

Table 5-4: Wind power as a percentage of SCC – Year 2012

Results depict that there is a possibility of a slight increase in wind penetration at 220kV level; however there is a frequency stability limit at 90MW. Therefore this study proposes limiting the total wind integration to 90MW and splitting that amount between the above two voltage levels such that 85MW at 132kV level and 80MW at 220kV level will not be exceeded.

5.3.3. System analysis – Year 2014

Voltage stability of the year 2014 network with wind additions in to 132kV and 220kV levels was studied in this section. The network arrangement is shown in figure 5.3. The results are summarized in table 5-5:




Figure 5.3 : Proposed network arrangement for year 2014

Voltage level	SCC (MVA)	Wind capacity (MW)	Observed voltage fluctuation As % of nominal voltage	Wind power as % of SCC
132kV	1738	90	1.8%	5.2%
220kV	3506	95	2.0%	2.7%

Table 5-5: Observed voltage fluctuations and SCC at 132kV and 220kV busbars at Puttlam- Year 2014.

There are no frequency stability or steady state violations observed for the above wind penetration levels. Therefore the wind interconnection limit at 132kV and 220kV levels at Puttlam substations is identified as 90MW and 135MW correspondingly for year 2016 network.



University of Moratuwa, Sri Lanka.
Electronic Theses & Dissertations
www.lib.mrt.ac.lk